

70 30 – sanaTis aRweril oba da teqnikuri specifikaciеби

sazogadoebrivi adgil is gasanaTebel i sanaTi Sesabamisi 70 vt naTurebi T.

sanaTis korpusi da safari damzadebul i unda iyos maRal xarisxiani, myari al uminis SenadnobiT (miRebul i civi teqnol ogi iT), xol o 0optikuri ganyofil eba Sedgebodes pol irebul i da anodizirebul i al uminis refl eqtorisa da pol ikarbonatis proteqtorisagan.

korpusi dafarul i unda iyos pol iesteris fxvnili iT, feri **RAL grey 7001**.

sanaTi mowyobil oba unda akmayofil ebdes Semdeg parametrebs:

- hermetizaciis done: **IP 65**
- gamZI eoba dartymis mimarT (PC): **IK 08**
- el eqtrul i saizol acio kl asi: I
- umaRI esi xarisxis fotometria.

ganaTeba – Tbil i naTeba.

Seni Svna (14) – sanaTis sagarantio vada unda Seadgendes minimum 10 (aTi) wel s, xol o naTuris sagarantio vada unda Seadgendes minimum 2 (ori) wel s.

Seni Svna (15) – Sesazi ebel ia ukeTesi sanaTis mowodeba, Tumca aseT SemTxvevaSi tenderSi monawi l em unda warroadgi nos Sesabamisi daskvna.