

Legal basis of Ten Year Network Development Plan

Ten Year Network Development Plan of Georgia is elaborated according Article 3² of “Law Of Georgia On Electricity And Natural Gas” and the amendment in paragraph 3 of Article 2 of “Law Of Georgia On Electricity And Natural Gas” (12 December 2014).

Author of Ten Year Network Development Plan

Ten Year Network Development Plan of Georgia is elaborated by the TSO of Georgia JSC Georgian State Electrosystem (GSE) by agreement with agreement of transmission licensees Energotrans LTD and JSC Sakrusenergo.

The consultations regarding use of information, materials and analysis given in in Ten Year Network Development Plan, also about the implementation of requirements of this plan may be provided by TSO. Tel.: +(99532) 2 510 202.

Email: archil.kokhtashvili@gse.com.ge;
giorgi.vakhtangadze@gse.com.ge.

The responsible persons:

Archil Kokhtashvili, Chief of Electrical Regimes and Development Service;

Giorgi Vakhtangadze, Chief of Transmission network planning and development section.

The discussion and approval of Ten Year Network Development Plan

The plan discussed and agreed by the Government on December 8 of 2017 session.

The plan approved by the Minister of Energy on December 28, 2017 by # 1-1/579 order.

Ministry of Energy, Georgian National Energy and Water Supply Regulatory Commission the transmission system operator, electricity transmission licensees, other agencies and interested took part in discussions of Ten Year Network Development Plan.

Action of Ten Year Network Development Plan

Ten Year Network Development Plan is obligatory implemented act.

The plan is designed for the period 2018 to 2028 (inclusive).

Licensees/subjects responsible for implementation of the plan are shown in Annex D-5.

The implementation of Ten Year Network Development Plan is controlled by the Ministry of Energy.

Table of Contents

| | | |
|----------|---|-----------|
| 1 | Executive Resume | 4 |
| 1.1 | Data Management | 5 |
| 1.2 | Planning Period | 6 |
| 1.3 | Operating strategy, security of supply and adequacy level of Power system | 6 |
| 1.4 | Bottlenecks and Development Drivers of Georgian Transmission Network..... | 7 |
| 1.5 | Forecasted Energy and Capacity Balances | 10 |
| 1.6 | Development Scenarios and Methodology..... | 11 |
| 1.7 | Generation Adequacy..... | 13 |
| 1.8 | Identified Projects and Required Investments..... | 16 |
| 1.9 | Major Calculation Results..... | 19 |
| 1.10 | Georgian Transmission System Development Indicators | 20 |
| 1.11 | Capabilities of Power Exchange with Neighbouring States in 2022-2027 Time Span..... | 22 |
| 1.12 | Opportunities of integration of renewable energy sources into the transmission network of Georgia..... | 23 |
| 1.13 | Ten-year development plan of SCADA and information technology (IT)..... | 24 |
| 1.14 | New challenges and relevant solutions..... | 24 |
| 1.15 | Strategic Environmental Assessment..... | 24 |
| 1.16 | Conclusion | 25 |
| 2 | Introduction..... | 26 |
| 2.1 | Legal Compliance..... | 26 |
| 2.2 | Process of Preparation of the Unified 10-Year Network Development Plan | 29 |
| 2.3 | Data Management / Softwares used for calculations..... | 31 |
| 2.4 | Differences compared with the previous 2016-2026 version of ten-year plan | 32 |
| 2.5 | Structure..... | 33 |
| 3 | Present Situation | 35 |
| 3.1 | Transmission System Operator | 35 |
| 3.1.1 | System Dispatch..... | 35 |
| 3.1.2 | Power Transmission | 35 |
| 3.1.3 | Mission | 35 |
| 3.2 | 2015 Statistics | 36 |
| 3.3 | Generation Data | 37 |
| 3.4 | Current Opportunities for Power Exchange with Neighbouring Countries | 40 |
| 3.5 | Main Present Power Exchange Flows | 42 |
| 3.6 | Operating strategy, security of supply and adequacy level of Power system | 45 |
| 3.7 | Main Network Bottlenecks of the Georgian transmission network and projects to eliminate them | 52 |
| 3.8 | Specifications of 500/400/330/220 kV overhead lines of Georgian transmission system | 55 |
| 3.9 | Installed Capacities of Autotransformers Installed in 500/400/330/220 kV Substation of Georgian Transmission Network..... | 57 |
| 4 | Inputs for Network Development Planning | 59 |
| 4.1 | Time Span 2017-2031..... | 60 |
| 4.2 | Forecasted balance scenarios/growth of consumption..... | 60 |
| 4.2.1 | Growth of consumption of country | 60 |

| | | |
|-----------|--|------------|
| 4.2.2 | Consumed energy, bln. kwh (gross domestic consumption) ¹ | 60 |
| 4.3 | Forecasted installed capacity (MW)..... | 60 |
| 4.4 | Generation data | 60 |
| 4.4.1 | HPPs (According to signed MoUs)..... | 60 |
| 4.4.2 | TPPs..... | 62 |
| 4.4.3 | Solar ⁴ , wind ⁵ , geothermal ⁶ or other ⁷ renewables..... | 62 |
| 4.4.4 | Power plants to be decommissioned..... | 63 |
| 4.5 | Forecasted prices of transmission system elements | 63 |
| 4.6 | Agreements with neighboring TSOs and their TYNDPs..... | 63 |
| 4.7 | The minimum technical requirements for power stations and generators..... | 69 |
| 4.8 | Special requirements for Back to Back stations | 70 |
| 4.9 | The changes made into the projects according to instruction made by Ministry of Energy and The MoUs signed between the Government of Georgia and Power plants | 70 |
| 4.10 | Information for the request of the postponement of existent projects by transmission licensees | 70 |
| 5 | Drivers of Georgian Transmission System Development | 71 |
| 5.1 | Primary Development Drivers of Georgian Transmission Network..... | 71 |
| 6 | Strategy, Scenarios and Methodology for Planning Ten-Year Development of Georgian Transmission Network | 76 |
| 6.1 | Development Strategy | 76 |
| 6.2 | Planning Methodology | 80 |
| 6.2.1 | Technical Planning | 80 |
| 6.2.2 | Technical Criteria for Planning..... | 83 |
| 6.2.3 | Grid Analysis..... | 84 |
| 6.2.4 | Criteria for Assessment of Consequences | 85 |
| 6.3 | Cost Benefit Analysis | 87 |
| 6.4 | Scenarios of Georgian Transmission Network Development..... | 87 |
| 7 | Forecasted Energy and Capacity Balances | 89 |
| 7.1 | Hydropower Booming by 2027 | 89 |
| 7.2 | Annual Energy Balances | 90 |
| 7.3 | Specific regimes of Georgian Electrical System (Power Balances)..... | 91 |
| 7.4 | Specific working regimes for Georgian Grid (Power Balances)..... | 102 |
| 7.5 | Generation Adequacy..... | 107 |
| 8 | Identified Projects and Investment Needs for Infrastructure strengthening | 112 |
| 8.1 | Identified Projects | 112 |
| 8.2 | Cost-Benefit Analysis of the Projects | 147 |
| 8.3 | Summary investment needs by years | 167 |
| 8.3.1 | Plan of transmission network rehabilitation | 168 |
| 8.4 | Strategic Environmental Assessment..... | 169 |
| 9 | Development of Georgian Electric Power System and Integration of HPPs | 192 |
| 10 | Power Flow Analysis..... | 212 |
| 10.1 | Steady Mode Analysis..... | 212 |
| 10.2 | Losses by operating modes | 213 |
| 10.3 | Voltage Analysis..... | 220 |
| 10.4 | Analysis of needs of the strengthening of substations | 225 |
| 11 | Short Circuit Analysis..... | 232 |
| 12 | Dynamic Stability Analysis | 237 |

| | | |
|-----------|---|------------|
| 13 | Harmonic Analysis..... | 241 |
| 14 | Georgian Transmission System Development Indicators for 2017-2027 | 252 |
| 15 | Power Exchange capabilities with Neighbouring States and opportunities of connection of generation and consumption | 257 |
| 15.1 | Capabilities of Power Exchange and NTC values for 2017-2027 | 257 |
| 15.1.1 | Capabilities of Power Exchange | 257 |
| 15.1.2 | NTC values to neighboring states for 2017-2027 time span | 258 |
| 15.2 | Opportunities of connection of new power to transmission network | 263 |
| 16 | Ten Year Plan of SCADA and Information Technologies (IT) Development | 268 |
| 16.1 | Ten Year Plan of SCADA and Information Technologies (IT) Development | 268 |
| 17 | State-of-the-Art Technologies | 279 |
| 17.1 | Emergency Control System (ECS) | 279 |
| 17.2 | Akhalstikhe HVDC Back-to-Back Station..... | 279 |
| 17.3 | SCADA Central SCADA Software Support and Server Update Project | 280 |
| 18 | Opportunities of integration renewable energy sources into the Georgian power system | 283 |
| 18.1 | Foreword | 283 |
| 18.2 | Contributing factors of assimilation of Wind and Solar energy | 283 |
| 18.3 | Challenges of power system in case of wind and solar energy integration..... | 283 |
| 18.4 | Necessary factors for integration of large wind and solar power plants..... | 283 |
| 18.5 | Research results | 285 |
| 18.5.1 | Possibility of integration of wind power plants | 285 |
| 18.5.2 | Possibility of integration of solar power plants | 286 |
| 19 | Vision about Development for future 2029-2050 Time Span | 288 |
| 20 | Conclusions and Recommendations | 296 |
| | Abbreviations | 299 |
| | References | 301 |

Annexes:

| | |
|---------|--|
| Annex 1 | Power Flow Schemes |
| Annex 2 | Results of Dynamic Stability Analysis |
| Annex 3 | Short Circuit Currents |
| Annex 4 | Cost Estimates of Planned Projects |
| Annex 5 | Three Year Investment Plan |
| Annex 6 | Data for 110 kV OHLs impacting on reliability of 220/110 kV substations |
| Annex 7 | General requirements on power plants and units/blocks (extracts from legislation) |
| Annex 8 | Single line diagram of transmission network of Georgia and names of overhead lines |

1 Executive Resume

Electric power sector composes an important part of the national economy having enormous influence on the social status of Georgia's population, and therefore development of the energy infrastructure constitutes the countrywide strategic goal.

The emerged cross-border electricity trade opportunities, high electricity demand growth and need for evacuation of the energy generated by the planned power plants, call for investments in the transmission infrastructure for ensuring adequate development of the network. Such objective targets availability of the transmission network capable ensuring of the consistent response to generation and demand growth by reliable and safe transportation of electricity, without any interruptions caused by outage of any single network element.

This Ten-Year Plan presents the time-tagged program designed for reinforcing infrastructure of the national transmission system, addressing the existing problems, responding to the future challenges and implementing the opportunities. It assumes adequate evolution of Georgian power system considering realistic scenarios and projects relevant to 2017-2027 time span.

The Ten-Year Plan aims at presentation and analysis of the future environment and reduction of uncertainties to obtain plausible projections and establish unified and well-structured vision about transmission grid development.

In general, development of the transmission system is a long-term process targeting reinforcement, expansion and upgrading of the network in line with generation and demand growth.

This document covers all components relevant to the development of Georgian power system. However, other projects that are not included in this Ten-Year Plan may also be reviewed in current and/or subsequent years. In addition, some projects described herein may be modified, implemented in shorter timeframes or delayed. All such changes will be accounted for in 2018-2028 version of this plan.

The goal of GSE is development of stable, reliable, cost-effective and efficient transmission system ensuring at any development stage:

- Security of Supply, network reliability, Power quality;
- Sufficient transfer capacity for both integration of renewable energy sources into the network and power exchange with neighbouring countries;
- Preparedness for integration into ENTSO-E's Ten-Year Network Development Plan.

The reason of long-term development planning is explained by the need for the future transmission network satisfying all applicable design requirements, main from which is **single contingency (N-1) criterion**.

In case additional reasonable projects will be identified, they will be considered in the next Ten-Year Network Development Plan of Georgia.

The planning process shall consist of the following major stages:

- a) Data collection;
- b) Data processing;

- c) Modelling;
- d) removing or mitigating any deficiencies;
- e) Preparation of the unified transmission grid development plan.




Fig. 1.1 Preparation stages of Unified Georgian Transmission Network Development Plan

1.1 Data Management

Inputs for Ten year Plan include: Information on installed capacities, outputs, geographical locations, categories and their commissioning years of the planned hydropower plants as well as decommissioning dates of aged power plants represent; forecasted characters of consumption growth in power system; agreements with neighboring countries about construction of cross-border infrastructure; Assignments from Ministry of Energy and memorandums of Georgian government, based on which changes in projects are implemented; Minimal technical requirements on power plants and their units and specific requirements on back-to-back stations.

By support of the Ministry of Energy preliminary design data of above generation facilities required for dynamic stability and harmonic analyses have been provided. Whenever such data were not available, the standard values were applied using typical generators' characteristics given in the databases developed by GSE's specialists.

Power flow, losses, system stability and short circuit analyses were performed using the model developed by PSS/E (Power System Simulator for Engineers) software, for Harmonic analysis – Digsilent PowerFactory software.

1.2 Planning Period

The planning period was divided into the following three time spans:

1. **Short-Term Planning Period** extended over 3 years after the base year (2016), i.e. the period of 2017-2019. Consulting companies have already been performing or they have already completed feasibility studies for the projects planned for such period. Required investments are clarified and new ones are identified. Three year Investment Plan for these three-year period is shown in Annex-5.
2. **Mid-Term Planning Period**, covering 4th and 5th years from the base year (2016), i.e. the period of 2020-2021. Feasibility studies of the projects envisaged for such period have not started yet, however the major project features and estimated technical and economical data have already been specified. It is expected that technical feasibility studies for these projects will commence shortly and in result forecasted features may be changed in some extent.
3. **Long-Term Planning Period**, including 6th to 10th years from the base year (2016), i.e. the period from 2022 to 2027. Feasibility studies of the projects planned for this period have not been started yet, however necessity for these projects have already been identified, and it is expected that their feasibility studies will commence within 2-3 years. In result of such studies certain project parameters may be changed.

1.3 Operating strategy, security of supply and adequacy level of Power system

Operation strategy. For purposes of analyzing power system security and designing appropriate control systems, it is helpful to conceptually classify the system-operating conditions into five states: normal, alert, emergency, in extremis and restorative.




Fig. 1.2 Power system operating states

In the normal state, all system variables are within the normal range and no equipment is being overloaded. The system operates in a secure manner and is able to withstand a contingency without violating any of the constraints. This means there are enough reserves of generation in power system

as well as enough reserves of transmission system capacity. System meets N-1, G-1 and N-G-1 conditions.

The system enters the alert state if the security level falls below a certain limit of adequacy, or if the possibility of a disturbance increases because of adverse weather conditions such as the approach of severe storms. In this state, all system variables are still within the acceptable range and all constraints are met. However, the system has been weakened to a level where a contingency may cause an overloading of equipment that places the system in an emergency state. If the disturbance is very severe, the in extremis (or extreme emergency) state may result directly from the alert state.

Preventive action, such as generation shifting (security dispatch) or increased reserve, can be taken to restore the system to the normal state. If the restorative steps do not succeed, the system remains in the alert state.

The system enters the emergency state if a sufficiently severe disturbance occurs when the system is in the alert state. In this state, voltages at many buses are low and/or equipment loadings exceed short-term emergency ratings. The system is still intact and may be restored to the alert state by the initiating of emergency control actions: fault clearing, excitation control, fast-valving, generation tripping, generation run-back, HVDC modulation, and load curtailment. If the above measures are not applied or are ineffective, the system is in extremis; the result is cascading outages of possibly a shut-down of a major portion of the system. Control actions, such as load shedding and controlled system separation, are aimed at saving as much of the system as possible from a widespread blackout.

The restorative state represents a condition in which control action is being taken to reconnect all the facilities and to restore system load. The system transits from this state to either the alert state or the normal state, depending on the system conditions.

Whenever all elements are in normal state as well as all parameters are within their normal range, operation of Georgian transmission network corresponds to the “alert state”. Therefore, **the most critical problem of Georgian transmission network is security of supply and leitmotif of transmission network development within next ten years will be security of supply and its improvement as well as upgrade of system reliability.**

In order to improve network reliability and stability, construction of tie-lines from 220 kV OHLs to power plants below 100 MW is maximally avoided due to two reasons:

- 1) Substation of power plant will be constructed on transmission route which will complicate harmonization of modern relay protection and automatic and the rest systems.
- 2) Both ends of overhead lines are being switched off in case of short circuit in power plant.

3/2 (1.5) scheme is used for 500 kV substation, as for 220 kV substations – double system with bypass bus bars.

1.4 Bottlenecks and Development Drivers of Georgian Transmission Network

Main network bottlenecks. Georgian transmission network is predominantly oriented from west to east (except SS Batumi located at the south and connected to the West Georgia’s system via long 220 kV OHLs that causes one more system wide problem). The most of the energy is generated in the west part of the country (total installed capacity of the HPPs located at the west amounts to 2080 MW), with the main consumption in the east part (Tbilisi-Rustavi node). Such imbalance is especially explicit during spring and summer, when due to the high water flows available in Georgian rivers, the thermal power units located at the east (near Gardabani) are not operated, and the power flows in the west-to-east direction.

The problem is faced in the west part of the system (500/220 kV mains along Enguri-Zestaponi route) during tripping of 500 kV OHL Imereti, because 220 kV mains are unable to transfer full load flow.

Cross border lines of Georgian transmission network are not basically backed-up and their outages create risk of emergency. Furthermore, there are several 220 kV dead-end lines trip of which is some threat for system stability. Additional supply of Batumi region is performed by long 220 kV lines what makes it difficult to keep parameters of power quality in permissible ranges.

Below are listed weaknesses experienced along this route:


- Interconnection lines
 - Kavkasioni, 500 kV
 - Gardabani, 330 kV
 - Alaverdi, 220 kV
 - Meskheti, 400 kV
 - Adjara, 220 kV
- Radial Network of West Georgia
 - Imereti, 500 kV
 - Zekari, 500 kV
 - Autotransformer at Enguri, 500/220 kV
 - Egrisi 1,2
 - Kolkhida 2a
 - Kolkhida 2
- Batumi supply grid
 - Paliastomi 1,2
- 220 kV dead end transmission lines
 - Kolkhida 3
 - Derchi
 - Lomisi
 - Manavi
 - Paravani

Development Drivers. A large majority of Georgian transmission network elements were designed/installed during Soviet era and assumed parallel operation with the North Caucasus and Armenian/Azeri power systems. Specifically, generation of the HPPs located in the West Georgia was transmitted to Russia, while the power plants located in the East Georgia were supplied with fuel from Azerbaijan.

After Georgia re-gained independence, prices for fuel supply for thermal units of Georgia grew much, and currently eastern part of Georgia is supplied with power from the HPPs located at the west. Meanwhile, Turkish energy markets becomes steadily attractive entailing construction of the HVDC back-to-back station in Akhaltsikhe, as well as encouraging the majority of the greenfield projects that are under development in Georgia. Due to its geographical location, Georgian transmission network may be used for energy transit between 1) Russia and Armenia/Iran, 2) Azerbaijan and Turkey, 3) Russia and Turkey, and 4) Armenia/Iran and Turkey.

It should also be noted that automatic governors and regulators of the existing hydro power plants are obsolete or inoperable, and the most of thermal power units are fully depreciated. Therefore, the governors/regulators shall be rehabilitated, and thermal power units shall be replaced with the new cost-efficient analogs.

Georgian power system endures acute shortage of operating reserves resulting in low power quality in isolated regimes. In addition, when any large power unit fails, emergency control system initiates load shedding. For dealing with such situation, sufficient operating reserves shall be provided by both construction of regulated hydro power plants (with water storage) and Thermal power plants as well as rehabilitation of the existing generation facilities.



- Prospective regulated HPPs
- Prospective seasonal HPPs
- Prospective demand growth
- Thermal power plants scheduled for decommissioning
- New combined cycle thermal power plants
- ↔ Necessary upgrades of cross-border (inter-system) links
- ↔ Necessary upgrades of internal network links
- Existing bulk generation region
- Existing bulk demand region

Fig. 1.3 Map illustrating development drivers of Georgian electric power network

Assuming above, the main development drivers of Georgian transmission network development drivers will be targeted to:

- Uninterruptable transmission of the existing generation;
- Fulfillment of single contingency (N-1) criterion (improvement of reliability)
- Reclamation of the new energy resources / integration of new HPPs into the network;
- Increasing network potential with respect to power transit;
- Establishment of reliable power supply centres for promoting development of potential production/tourist centres;
- Responding to the (naturally) growing demand in the power system;
- Replacement of the aged thermal units with flexible and cost-effective combined cycle thermal power plants;
- Provision of sufficient operating reserves;
- Improvement of the power quality.

1.5 Forecasted Energy and Capacity Balances




Fig. 1.4 Installed capacities of the existing power plants




Fig. 1.5 Installed capacities of power plants as for 2027

At present, total installed capacity of electric power plants operated in Georgia amounts to 4106 MW. From this, 2226 MW is generated by the so called “regulated” HPPs (with water storage), 934 MW by “seasonal” (run-of-river) HPPs, 110 MW by Gas Turbines and 815 MW by thermal power plants (Fig. 1.4). Roughly 77% of the total in-country installed capacity is provided by HPPs, including 54% generated by regulated hydro power plants.

For 2027, the total installed capacity available in Georgian power system will grow to 7595 MW (Fig. 1.5). From this, 4239 MW will be attributed to regulated HPPs, 2180 MW to seasonal HPPs, 20 MW to Wind Power Plants, 110 MW to Gas turbines and 1045 MW to high efficiency combined cycle as well as coal thermal power plants, which will replace the older Gardabani TPP’s Units Nos. 3, 4 and 9. For 2027, percentage share of hydropower in total national installed capacity will grow to 85%, including 56% regulated hydro power plants. This will ensure use of the water stored during flood season for low flow periods, thus reducing dependence on import of electricity and fossil fuels necessary for operation of thermal power plants.

The annual electric energy balances have been developed based on forecasted growth of generation and demand for all considered scenarios (table 1.1, fig. 1.6). Energy balance for basic scenario (Table 1.1, Picture 1.6) is shown below, which includes timely integration of all generation objects into the network, as well as annual 5% growth of consumption.

Table 1.1. Forecasted annual energy balances of Georgian electric power system (bln kWh)

| Year | Generation | HPPs | TPPs | Wind Farms | Consumption | Export |
|------|------------|-------|------|------------|-------------|--------|
| 2016 | 11.37 | 9.08 | 2.29 | - | 11.25 | 0.12 |
| 2017 | 12.9 | 10.23 | 2.58 | 0.093 | 11.64 | 1.26 |
| 2018 | 12.97 | 10.76 | 2.12 | 0.093 | 12.05 | 0.92 |
| 2019 | 14.61 | 11.99 | 2.53 | 0.093 | 12.47 | 2.14 |
| 2020 | 17.61 | 14.12 | 3.4 | 0.093 | 12.9 | 4.71 |
| 2021 | 18.3 | 15.37 | 2.84 | 0.093 | 13.35 | 4.95 |
| 2022 | 19.51 | 17.08 | 2.34 | 0.093 | 13.82 | 5.69 |
| 2023 | 20.15 | 17.63 | 2.43 | 0.093 | 14.3 | 5.85 |
| 2024 | 23.84 | 21.2 | 2.55 | 0.093 | 14.8 | 9.04 |
| 2025 | 25.66 | 22.96 | 2.61 | 0.093 | 15.32 | 10.34 |
| 2026 | 26.15 | 22.96 | 3.09 | 0.093 | 15.86 | 10.29 |
| 2027 | 26.3 | 22.96 | 3.24 | 0.093 | 16.4 | 9.9 |




Fig. 1.6 Georgian generation, consumption and export graphs

Summary. Based on forecasted balances presented above, it may be concluded that construction of the new cross-border lines with neighbouring states is necessary. The most critical period in terms of intensity of the power export is flood season, including so called Summer Maximum and Summer Minimum regimes. According to capacity balances, 2100 MW should be available for export in 2020, that will grow to 3100 MW in 2021 and 4100 MW in 2022.

1.6 Development Scenarios and Methodology

Planning scenarios are defined to represent the future environment. Scenario analysis is necessary to obtain realistic picture of a future. Scenarios are means to approach the uncertainties and acknowledge interaction between these uncertainties.

Each scenario encompasses several planning cases, i.e. particular situations that may occur within the framework of the specific planning scenario.

At least the following three time horizons shall be considered:

- Short-term horizon (typically 1-3 years);
- Mid-term horizon (typically 4-5 years);
- Long-term horizon (typically 6-10 years).

Investments encompassed for transmission network reinforcement which correspond transmission network development plan should include all the represented cases and should encompass commissioning dates of new network elements.




Fig. 1.7 Process of technical analysis of the scenarios

Analysis and network impact tests shall be performed for each design case to identify future problems and adequate technical requirements for network reinforcements. **The line of critical importance for the country is selected based on requirement of fulfilling N-1 criterion without the need of shedding the customer loads.**

The following studies have been performed for checking the planned network reliability status:

- Power flow analysis
- Short circuit analysis
- Voltage analysis
- Stability analysis
- Harmonic analysis

Several scenarios of Georgian transmission network development were reviewed. Information about prospective generation facilities to be integrated into the network was used as the input data for planning. Such facilities were divided into the following categories:

- Category 1** Power plants under construction, which are provided with relevant executed Memorandums;
- Category 2** Power plants that are objects of interests formally expressed by reputable investor companies, which feasibility studies have been commenced;
- Category 3** Large strategic power plants of country wide importance, which feasibility studies will commence in the nearest future.

The estimated annual demand growth rate of 3.5% approved by the Ministry of Energy was applied for the base scenario, along with 1% and 5% growth rates for “optimistic” and “pessimistic” cases.

Table 1.2

| GROWTH OF LOAD GENERATION | “G1” 100% K1, 50% K2 | “G2” 100% K1, 50% K2, 25% K3 | “G3” 100% K1, 100% K2, 100% K3 |
|--------------------------------|-------------------------|------------------------------------|--------------------------------------|
| 1 % growth “L1” | L1G1 | L1G2 | L1G3 |
| 3.5 % growth “L2” | L2G1 | L2G2 | L2G3 |
| 5 % growth “L3” | L3G1 | L3G2 | L3G3 |

The table above shows various cases with different growth rates regarding demand (load) and generation, L2G3 scenario has been selected as general one which means 3.5% growth of load and commissioning 100% of all three categories of new power plants. Calculations presented in this plan are based on L2G3 scenario.

Generally, development of transmission grid depends on scenario of integration of new generation and power demand growth rate. Anyway, in case of development by any scenario until 2027-2031 all three categories of new hydro power plants will be integrated into the grid. As for demand – it represents combination of internal demand and power export. In other words, if internal demand is being less increased, then power export will be increased more and vice-versa. Hence, **in case of development of generation and demand by any scenario, transmission grid shall be developed by the same option which corresponds timely integration of generation – L2G3.**

1.7 Generation Adequacy

Adequacy – ability of the electricity system to uninterruptedly satisfy the consumers’ requirements on electricity, taking into account the both scheduled and unscheduled outages of system elements.

Adequacy of power generation is determined by 2 methods:

1. Deterministic - minimizes time required for calculations (although based on just a few scenarios). This requires deep knowledge of the system and may not cover all accidents;
2. Probabilistic – requires software with mathematical equipment; Requires more time for calculations (a second, or tenths of seconds), although reflects the influence of reliability of each element of the system on the adequacy of generation.

Adequacy may be expressed as the ability of Power System's generation to satisfy 100% of peak load with 95% probability. If less than 100% of peak load is satisfied, then the system treated as inadequate and installation of new generation sources and reinforcement of cross border transmission is required.


In addition, by adding of generation, 10% of total transfer capacity (NTC) of cross-border overhead lines can be used.

LSI Index (Load Supply Index) shows correlation between generation capacity and peak load capacity of the Country.

For the estimation of Generation Adequacy LSI (Load Supply Index) was estimated, which shows the ratio between generation capacity (generation availability plus 10% of NTC) and peak load of country.

If $LSI > 1.0$ then the generation and interconnection capacity of power system is treated as adequate otherwise system is inadequate and new generation sources and the reinforcement of transmission capacity is required.

LSI levels for L2G3 base scenario for summer and winter seasons are given on fig. 1.8






Fig. 1.8-b LSI for winter period




Fig. 1.8-c LSI for winter period (corrected)

() – Corrected data based on the information obtained in January 2017

Hence, in order to avoid the abrupt reduction of security of supply and the adequacy of power system, following recommendations have to be taken into account:

1. Increase the reliability of power transfer from Enguri Pool to the consumption centers which are located in Eastern Georgia by construction of parallel 500 kV OHL for 500 kV OHL “Imereti”;
2. Interconnection transmission lines have to be commissioned at list on time;
3. Avoiding postponing of commissioning of prospective generation objects;
4. Full technical reconciliation of existing generation objects;
5. HPPs with Reservoirs (for example Khudoni and Nenskra HPPs, Namakhvani, Tskhenistskali cascade) have to be commissioned on time in order to “save energy” in summer period for winter one.
6. It’s recommended to construct pumped-storage HPPs which will increase system adequacy, stability, flexibility as well as will create opportunity to integrate variable energy sources (Sun and Wind) into the grid.
7. Other measures to ensure power efficiency and mitigate consumption growth.

1.8 Identified Projects and Required Investments

The projects planned for implementation have been divided into the following three groups:

1. **Internal Projects**, including the projects affecting power transit and reliability;
2. **Cross-Border Projects**, i.e. the projects affecting capacity and reliability of the transit flows among the power systems of Georgia and its neighbouring states;
3. **Local Projects**, comprising 220 kV and 110 kV dead-end feeder lines.

Transmission Licensee does not implement local projects. The direct affect on development of the transmission network is provided only by Cross-Border and Internal Projects. Therefore 15 of such projects were selected for detail review.




Fig. 1.9 Summarized Data of internal system and cross-border importance Projects

The Cost-Benefit Analysis (CBA) has been performed for the foregoing 15 projects planned for implementation in the transmission network during 2017-2027. Applying the CBA methodology,

expected benefits were weighted against estimated investment costs and environmental impacts individually for each project.

According to appraisal of the planned projects applying CBA methodology, the highest ranked interconnection projects (implying the most needs) are: 1) **Jvari-Tskaltubo-Akhaltsikhe** integrating more than 2100 MW hydropower into the network, increasing network transfer capacity and reliability and ensuring compliance with N-1 criteria; 2) **Ksani-Stepantsminda-Mozdok** which will improve reliability of the parallel operation with Russian power system and stability of Georgian network, as well as will integrate up to 170 MW hydropower generation; 3) **Jvari-Khorga**, improving security of supply, implementing power evacuation of Khobi HPP cascade, upgrading flexibility of OHL Kavkasioni, ensuring power supply of Poti Industrial Zone, reducing amount of consumers to be tripped by system automatic.

The nameplate capacity of 500/400/330/220/110 kV autotransformers installed in Georgian transmission network will increase by about 3500 MVA, and the total length of 500/400/330/220/110 kV overhead transmission lines by 1200 km. This will ensure improved reliability of the network along with satisfying the single contingency (N-1) criterion at each development stage, allow Georgia to undertake transit hub function, provide for more than 1000 MW exchange in both east-west and north-south directions, and integration of additional 3500-4000 MW hydropower into the network. Total forecasted investment value of the foregoing projects amounts to about 750 million Euros.

Jvari-Tskaltubo-Akhaltsikhe 30 points




Fig. 1.10 Jvari-Tskaltubo-Akhaltsikhe Project; Total score: 30

Ksani-Stepantsminda-Mozdok 27 points




Fig. 1.11 Ksani-Stepantsminda-Mozdok Project; Total score: 27

Jvari-Khorga 27 points




Fig. 1.12 Jvari-Khorga Project; Total score: 27

1.9 Major Calculation Results

Power flow analysis. In the base case, nodal voltages and power flows in the transmission remain within acceptable limits for the total planning horizon of 10 years. Meantime, during 2017-2019 (i.e. prior to the planned construction of 500 kV OHL Jvari-Tskaltubo), 220 kV network in the West Georgia is overloaded under single contingency (N-1) case, namely if 500 kV OHL Imereti is lost. In result, ECS initiates shedding of 200-300 MW load in the eastern part of Georgia along with adequate generation reduction in Enguri-Vardnili node to remove surpass load from transmission system.

Power losses. Power losses in Georgian transmission network at 500/400/330/220 kV voltage levels vary in the range of 2.27-4.76 percent.




Fig. 1.13 Dynamics of transmission losses during 2017-2027 by seasons

Short circuit analysis. For the Ten-Year Network Development Plan of Georgia, the maximum and minimum short circuit currents have been calculated for the most critical and characteristic years (2017, 2019, 2023, 2027). The maximum short circuit currents were calculated assuming operation of all generators and cross-border lines of Georgian electric power system, while the case when the fewer number of generators appropriate to the summer minimum regime are operated, and all cross-border OHLs are switched off was considered when calculating the minimum short circuit current values. As calculations showed, in certain substations, the estimated short-circuit currents for 2027 are 70%-80% higher than for 2019 and may two times exceed the current values. Therefore, electrodynamic and thermal ratings of the equipment installed in power plants and substations should be verified to timely make relevant replacements.

Dynamic Stability Analysis studies power system behaviour and ability of maintaining synchronous operation of the generators during limited contingencies. Such analysis was performed for maximum summer demand mode of Georgian power system for 2020, 2023 and 2027, considering the following disturbances: Emergency tripping of 500 kV OHLs; Outage of 500/220 kV autotransformers; Tripping of back-to-back link or 400 kV Georgia-Turkey line; Shutdown of the power units of Enguri HPP, 9th Thermal Unit and Khudoni HPP.

According to results of the analysis, Georgian transmission network (power system) maintains stability during any disturbances, subject to the following preconditions: During 2017-2019, in cases involving tripping/shutdown of 500 kV OHL Imereti, 500 kV OHL Kavkasioni, power unit of Enguri HPP or 9th Thermal Unit, ECS should intervene for shedding of the appropriate customer loads and/or generation facilities. During 2020-2027, system stability is naturally maintained in case of any disturbances.

Harmonic analysis. The most powerful source of harmonics in Georgian electric power system is 700 MW Akhaltsikhe HVDC back-to-back station. In near future new HVDC links will be added to Georgian transmission network, such as 350 MW HVDC station planned at Batumi, and additional 350 MW link scheduled at SS Akhaltsikhe. In addition, construction of 700 MW HVDC back-to-back station in Armenia near to Georgian border is planned. For the base case (N), analysis included calculation of individual and summarized harmonic distortion factors, while for single contingency (N-1) cases (considering failure of 220 kV or 500 kV lines), only the Total Harmonic Distortion (THD) was calculated. According to derived results, all THDs, for both N and N-1 modes are within the standard limits. However, certain deviation from standard value of 13th harmonic has been observed that should not have any negative effect on the network, but still needs performance of more accurate calculations.

Summary: based on results of above analyses, the planned transmission network is reliable, provides stability of the power system and maintains system parameters within the limits set forth in the Grid Code.

1.10 Georgian Transmission System Development Indicators

Future constructions of 500/400/220/154/110 kV OHLs and substations planned during next ten year are mainly intended for integration of the new hydro power plants, necessity of improving reliability and security of supply as well as increment of transit potential.

Table 1.3

| Overhead Lines | | Substation autotransformers and Back-to-Back Links | |
|--------------------|-------------|--|----------------|
| Rated Voltage (kV) | Length (Km) | Rating (kV) | Capacity (MVA) |
| 500 | 841 | 500/400 | 875 |
| 400 | 32 | 500/330 | 0 |
| 330 | 21 | 500/220 | 2800 |
| 220 | 1616 | 330/220 | 400 |
| 110 | 3528 | 220/110 | 5145 |
| Sum | 6081 | Sum | 9220 |

The following diagram illustrates dynamics of total generation capacity (MW), installed apparent capacity of 500/400/330/220/110 kV transformers and autotransformers (MVA) and total length of transmission lines expressed in 500 kV OHL equivalent (km).




Fig. 1.14 Dynamics of Georgian generation and 500/400/330/220/154/110 kV transmission infrastructure development during 2016-2027

Several indicators describing development of Georgian transmission network were calculated from the diagram given on Fig. 1.14, such as length of overhead line needed for evacuation of 1 MW installed generation capacity (in 500 kV OHL equivalents) and total installed capacity of 500/400/330/220/110 kV (auto)transformers.




Fig. 1.15 Relationship between development of Georgian transmission network and generation infrastructure

Summary: Despite reduction of unit equivalent length of the transmission network and specific capacity of (auto)transformers per evacuated 1 MW generation, the calculations show that during 2024-2027, Georgian power system will be more stable comparing to 2017-2019 time span. Therefore, it is apparent that improvement of the reliability is accompanied by improvement of network effectiveness and cost-efficiency.

1.11 Capabilities of Power Exchange with Neighbouring States in 2022-2027 Time Span

The existing cross-border links serve for power exchange between Georgia and Russia and transit from Russia and Azerbaijan to Turkey, as well as for bidirectional power exchange between Georgia and Turkey, Azerbaijan and Armenia. However, such power flows are restricted due to both limitations stemmed from the acceptable operating modes of national power system and physical capacities of above cross-border OHLs (tab. 1.4 and fig. 1.17).

For 2022-2027 horizon, Georgia, due to its geographical location, will gain an important role in the planned regional integration of the power systems of the Caucasian (and Black Sea) countries assuming promotion of energy trading between these countries and development and use of Georgian hydropower resources.

For 2022-2027, cross-border links between Georgian and its neighbouring power systems will significantly advance, allowing 1400 MW power exchange with Turkey, 1400 MW with Russia and 700 MW with Armenia. There is already possibility of 700-1000 MW power exchange between powers systems of Georgia and Azerbaijan.

Table 1.4 Power exchange capabilities with neighbouring power systems

| Country | Cross-border line, conductor | Nom. Voltage (kV) | Exchange | TTC (MW) | Mode |
|------------|--|-------------------|----------|----------|-------|
| Russia | „Kavkasioni“ AC-3x300 | 500 | Export | 700 | ≈ |
| | | | Import | 700 | ≈ |
| | „Stepantsminda“ (Ksani-Stepantsminda-Mozdok) AC-3x300, ²⁰²¹ | 500 | Export | 1000 | ≈ |
| | | | Import | 1000 | ≈ |
| | „Salkhino“ AC-400 | 220 | Export | 50 | Isl |
| | | | Import | 150 | Isl |
| Azerbaijan | „Mukhranis Veli“ AC-3x300 | 500 | Export | 700 | ≈ |
| | | | Import | 700 | ≈ |
| | „Gardabani“ AC-480 | 330 | Export | 320 | ≈ |
| | | | Import | 320 | ≈ |
| Armenia | „Alaverdi“ AC-300 | 220 | Export | 150/100 | ≈/Isl |
| | | | Import | 150/100 | ≈/Isl |

| | | | | | |
|--------|---|-----|--------|------|-----------|
| Turkey | „Marneuli“ (Marneuli-Ayrum) AC-3x330, ²⁰¹⁸ | 400 | Export | 700 | B2B * |
| | | | Import | 700 | B2B |
| | „Meskheti“ AC-3x500 | 400 | Export | 1050 | B2B * |
| | | | Import | 1050 | B2B * |
| | „Tao“ (Akhalsikhe-Tortum) AC-3x500, ^{2019 (2020)} | 154 | Export | 350 | B2B * |
| | | | Import | 350 | B2B * |
| | Batumi-Muratli ²⁰²⁰ | 220 | Export | 150 | Isl (res) |
| | | | Import | 150 | Isl (res) |

≈ synchronous mode

Isl isolated mode

B2B operation with Back-to-back station

In particular, each of the 400 kV OHLs “Tao” and “Meskheti” can transfer up to 1500 MW but their total transfer capacity is limited by the ones of Akhalsikhe HVDC back-to-back units, value of which will equal to 1050 MW after 2021.



Fig. 1.16 Cross-border transfer capacities between power systems of Georgia and its neighbouring countries as for 2027

1.12 Opportunities of integration of renewable energy sources into the transmission network of Georgia

Georgian power system is a small size one. More than 80% of consumption is covered by “Green energy” produced by HPPs. On the other hand, due to the small size (low inertia constant) and radial layout of

Georgian system, security of supply is important challenge. Fulfil of this is possible by constructing powerful seasonal regulating HPPs which will ensure both power reserves and stability (inertia constant). As for integration of renewables (Solar, wind), it's restricted. Total capacity of 100 MW is acceptable for Georgian power system till 2021, in 2025-2030 (with the consideration of commissioning of all planned regulating HPPs and cross-border lines) this value equals to 400 MW but not more than 45 MW for each geographic region (9 regions in total).

1.13 Ten-year development plan of SCADA and information technology (IT)

Georgian State Electrosystem (GSE) is the transmission system operator serving the function to maintain system stability and reliability for short-term and long-term periods. Especial challenge is to balance the system usage-supply and export-import in real time (online) so that to maintain power quality parameters within normal limits. Another challenge is to manage energy system, and to maintain stability and integrity in emergency modes. In order the company to be able to generate and exchange all required accurate data for energy management, it is necessary to integrate a variety of information technology platforms applied to GSE system, which should correspond to the Ten-Year Network Development Plan of Georgia. This is the basis for SCADA and Information Technology (IT) Development Plan.

1.14 New challenges and relevant solutions

1. **Electromobiles** – Possible drastic increase of peak load; “prosumers” – system decentralization and nonpredictability and customers with changing requirements. *Solution/mitigation:* construction of Hydro Power Plants (HPPs) with reservouis, enhance energy efficiency, introduce power storage stations and batteries, construct thermal plants and inter-system power transmission infrastructure. Complete control and operation system, introduce “smart networks”, introduce dynamic patency of transmission lines, optimal integration of wind and solar power stations (possibly with storage batteries), introduce VSC PLUS and FACTS equipment, utilize up-to-date planning and modelling devices. **Challenges associated with the construction of new transmission lines, by the end of next decade:** *solution/mitigation:* visual-friendly constructions, installation of multiple current towers and, under some exceptions, construction of cable transmission lines.
2. **Challenges associated with market liberalization.** *Solution/mitigation:* renewal of system control program and readiness for the trade with the Europe's domestic power market before-day and within-day, as well as rehabilitation of existing power stations as per “systemic service concept”.
3. **Possible cyber attack risks and informational safety challenges.** *Solution/mitigation:* GSE conducts personnel awareness and introduction of ISO 27001 safety standard. Besides, foreign cyber security experience is adopted and relevant GSE staff ensures cyber security at all times.

1.15 Strategic Environmental Assessment

GSE aims for the construction of transmission infrastructure, which will provide reliable consumption, as well as minimal adverse enironmental effect. This 10-year plan envisages strategic environmental assessment of all main projects.

1.16 Conclusion

Transmission system operator, together with transmission licensee strives to provide reliable and high quality services to its customers and develop its own infrastructure that is necessary for supporting to economical development of Georgia. The projects presented and discussed in this Ten-Year Plan represent an adequate response to the changes in economical and energy environment. GSE believes that implementation of these projects will meet wishes of Georgian society as well as will allow the national economy to effectively address the challenges and ensure the better future.

2 Introduction

Power transmission system of Georgia operates at 500/400/330/220/110 kV voltage levels and undertakes a vital role in provision of power supply, ensuring reliable and safe transportation of electrical energy from the generation facilities to the customers, as well as energy export/import with neighbouring countries.

Electric power sector composes important part of the national economy having enormous influence on the social status of Georgia's population, and therefore development of the power infrastructure constitutes the countrywide strategic goal.

This Ten Year Network Development Plan of Georgia (hereinafter "Ten-Year Plan") specifies challenges and drivers relevant to development of the grid, and describes projects and investment needs for the period of 2017-2027.

The planning period subject of review has been divided into the following three time spans:

Short-Term Planning Period extended over 3 years after the base year of 2016, i.e. the period of 2017-2019. Consulting companies have already been performing or they have already completed feasibility studies for the projects planned for such period. Required investments are clarified and new ones are identified. Three year Investment Plan for these three-year period is shown in Annex-5.

Mid-Term Planning Period, covering 4th and 5th years from the base year of 2016, i.e. the period of 20120-2021. Feasibility studies of the projects envisaged for such period have not started yet, however the major project features and estimated technical and economical data have already been specified. It is expected that technical feasibility studies for these projects will commence shortly and in result forecasted features may be changed in some extent.

Long-Term Planning Period, including 6th to 10th years from the base year, i.e. the period from 2022 to 2027. Feasibility studies of the projects planed for this period have not been started yet, however necessity for these projects have already been identified, and it is expected that their feasibility studies will commence within 2-3 years. In result of such studies certain project parameters may be changed.

Network components and projects discussed in this Ten-Year Plan have been divided into the following three groups:

1. **Internal Projects**, including the projects affecting power transit and reliability;
2. **Cross-Border Projects**, i.e. the projects affecting capacity and reliability of the transit flows among the power systems of Georgia and its neighbouring states;
3. **Local Projects**, comprising 220 kV and 110 kV dead-end feeder lines.

2.1 Legal Compliance

This Ten-Year Plan has been prepared by Georgian State Electrosystem with due account of the situation prevailing in Georgian power sector and applicable best European practice.

The underlying statutory base for this Ten-Year Plan is provided by "Georgian Law on Electricity and Natural Gas" and the Grid Code approved by Georgian National Energy and Water Regulatory Commission ("GNERC").

- According to 3² article (**Ten-Year Network Development Plan of Georgia**) of Georgian Law about “Electricity and Natural Gas”:

1. *The purpose of working out the Ten-year Transmission Network of Georgia Development Plan shall be the reliability, safety, and sustainable development of the transition network, provision of electricity of adequate quality, and raising the transit capacity of the electricity network of the country.*

2. *The Ten-year Transmission Network of Georgia Development Plan implies:*

a) information on the present and future (forecast) electricity requirements and supply;

b) rational forecast of electricity generation, transmission, consumption, and the volume of exchange of electricity with other countries;

c) information on the transmission network infrastructure to be built or improved in the next 10 years, with the indication of concrete timeframes for implementing investment;

d) information on agreed investment and on identifying the new investment that is to be implemented in the next 3 years;

e) information on integrating new generation facilities (including, renewable energy sources) in the network;

f) information on transmission capacity of each node of the future network for the purposes of integration of new generation facilities;

g) defining short circuit currents for the purposes of selecting power equipment for the units to be planned;

h) information on the development of the internal network of generation facilities.

3. *The state agencies and organizations in the field of economy, finance and statistics, and the organizations in the field of energy, shall, within the sphere of their respective authority, according to the legislation of Georgia, provide the information, data and forecast that are to be considered in the Ten-year Transmission Network of Georgia Development Plan.*

4. *The transmission system operator shall, in agreement with electricity transmission licencees, annually, during the next 10 year, work out/update a draft Ten-year Transmission Network of Georgia Development Plan (this process shall involve carrying out all necessary research and assessment). The draft plan shall be forwarded to the Ministry and the Commission not later than 1 October of the respective year. The Commission shall consider the Ten-year Transmission Network of Georgia Development Plan within 1 month after receiving the draft, and shall present to the Ministry its Notes and Recommendations on the draft plan.*

5. *The Ministry shall consider the Ten-year Transmission Network of Georgia Development Plan and the submitted Notes and Recommendations together with the Commission, the transmission system operator, and the electricity transmission licensees. The Ministry shall, based on the consent of the Government of Georgia, not later than the completion of the respective year, ensure the approval of the Ten-year Network Development Plan of Georgia.*

6. *Introducing ad hoc amendments to the Ten-year Transmission Network of Georgia Development Plan shall be possible, observing the procedures provided for by this Article. The draft ad hoc amendments to the plan may be worked out and submitted for consideration at any time during the calendar year.*

- According to Article 29 of the Grid Code (**“Transmission Grid Planning”**):

1. *Dispatch Licensee shall prepare Transmission Network Development Plan, as well as complete all required studies and assessments.*

2. *Dispatch Licensee (GSE) shall provide for collection and coordination of the data from Transmission Licensees, Transmission Grid Users and Transmission Applicants, as well as ensure information exchange with power system operators of neighbouring states.*

3. *Dispatch Licensee (GSE) shall prepare the unified transmission grid development plan for 10-year period, and submit it to Georgian National Energy and Water Regulatory Commission and the Ministry of Energy of Georgia.*

- According to Article 30 of the Grid Code (**“Major Principles”**):

1. *Inter alia, the following shall be taken into account during planning process:*

a) *Technical reliability requirements;*

b) *Issues related to economic and operative control, maintenance, relay protection and automation;*

c) *Issues related to coordination with electricity generation, consumption and distribution facilities;*

d) *Issues related to information technologies and environmental protection.*

2. *The unified transmission grid development plan shall consider the issues related to planning of system reliability, cost effectiveness, environmental protection, forecasted development, intersystem links and local transmission network.*

3. *The following two criteria are used in this Code for assessing reliability of the transmission grid:*

a) *Adequacy – Ability of the power system to satisfy the aggregate electrical demand and energy requirements of the customers at all times, taking into account scheduled and unscheduled outages of system elements;*

b) *Stability – Ability of the electric systems to withstand sudden disturbances such as electric short circuits or unanticipated loss of system elements.*

4. *Above planning criteria shall be taken into account during assessment of various development scenarios and likelihood of contingencies.*

5. *The long-term plans shall be reviewed annually.*

6. *The planning process shall consist of the following major stages:*

a) *Data collection;*

b) *Data processing;*

- c) *Modelling;*
 - d) *Drafting the optimal plan for removing or mitigating any deficiencies;*
 - e) *Preparation of the unified transmission grid development plan.*
7. *The planning process shall include:*
- a) *Assessment of electric power system performance by individual seasons;*
 - b) *Detail study of electric power system performance anticipated for short-term period;*
 - c) *Requirements for strategic planning applicable to medium and long-term periods.*
8. *The planning process shall begin with assessment of power system performance.*
- Any identified potential risks shall be analyzed in detail to ensure their elimination or mitigation.*
9. *The power system development plan shall allow elimination and/or reduction of identified risks.*
- According to Article 35 of the Grid Code ("**Transmission Network Planning Criteria**"):
1. *Planning of the transmission network shall be based on maintaining the standard power quality parameters ..., under forecasted load and generation values..*
 2. *Transmission network development planning shall provide avoidance of system emergencies and implementation of system stability measures during expected contingencies that may be caused by:*
 - a) *Failure of a single system element (N-1);*
 - b) *Failure of any system element plus emergency outage of one thermal/hydro power unit (N-G-1);*
 - c) *Failure of any system element during maintenance outage of other element (N-1-1).*

2.2 Process of Preparation of the Unified 10-Year Network Development Plan

This Unified 10-Year Network Development Plan has been prepared by GSE based on information received by support of the Ministry of Energy of Georgia (generation, consumption growth). Preliminary network development plan has been drafted, which specified:

- Planned OHLs, including rated voltages, lengths and estimated investments;
- Planned substation capacities, rated voltages and estimated investments.

The important dates from preparation process of TYNDP document are represented below:

May 2017 – Obtain initial information from the Ministry of Energy of Georgia regarding changes in the utilization of prospective HPPs.

June 6, 2017 – Obtain information from the Ministry of Energy of Georgia regarding date commissioning of potential HPPs – “Namakhvani” cascade, “Khudoni” HPP and “Guria” HPP.

June 2017 – Modification of “North Ring” Project.

July 11, 2017 – Clarification of prospective HPP commissioning and dynamics of consumption growth. Correction of 2017-2027 data.

Untill August 25, 2017 – Completion of technical estimates and influence tests of prospective scheme.

August 25, 2017 – Discussion of initial draft of 10-year plan within GSE;

August 25-29, 2017 – Refinement of initial draft of 10-year plan;

August 29, 2017 – Submission of draft 10-year Plan to licensees for approval;

August 31, 2017 – Agreement of 10-year plan by “Energotrans Ltd”;

September 1, 2017 - Agreement of 10-year plan by “Sakrusenergo”;

September 1, 2017 – Submission of initial draft 10-year Plan to the Ministry of Energy and Energy and Water Supply Regulatory Commission.

September 1, 2017 – Notes and recommendations from the Ministry of Energy;

September 29, 2017 – Obtain recommendations from Energy and Water Supply Regulatory Commission;

November 28, 2017 – Submit final revised version of 10-year plan to the Ministry, for approval;

December 8, 2017 – Agreement of 10-year Network Development Plan of Georgia 2018-2028 with the Government of Georgia;

December 28, 2017 – Approval of “Network Development Plan of Georgia 2018-2028 by the Ministry of Energy.




Fig. 2.1 Timeline of preparation of the Unified Georgian Power Network Development Plan



Fig. 2.2 Preparation Stages of Unified Georgian Transmission Network Development Plan

2.3 Data Management / Softwares used for calculations

Transmission system undergoes continuous development in line with modifications and changes made to power network development projects. The projects envisaged in this Ten-Year Plan (2017-2027) represent the ones considered in previous 2016-2016 years, their modification or the projects existing of which become necessary due to the network security and new reality.

Information on installed capacities, outputs, geographical locations, categories and commissioning years of the planned hydropower plants was received by support of the Ministry of Energy (in August 2016). In addition, annual 3.5% growth of demand was assumed. These data have been used in the power flow analysis.

Also, by support of the Ministry of Energy design data of above generation facilities required for dynamic stability and harmonic analyses has been obtained. Whenever such data were not available, the standard values were applied using typical generators' characteristics given in the databases developed by GSE's specialists.

The most recent available and regularly updated information maintained by GSE was used for obtaining data and conditions of the existing OHLs, substations, transformers, reactors, HVDC links and power plants/generators.

GSE specialists collected standard data from feasibility studies of relevant projects, regarding prospective transmission lines, substations, transformer units, HVDC back-to-back stations and reactors.

The analyses were conducted by GSE's specialists.

Power flow, system reliability and short circuit analyses were performed using the model developed by PSS/E (Power System Simulator for Engineers) software, including the following elements:

- 500/400/330/220/110 kV voltage elements of Georgian power network, as well as part of the lower voltage network used for interconnection of the generation facilities with 110 kV and higher voltage grid.
- Models and/or equivalents covering Azeri, Armenian, Turkish and South Russian electric power systems.
- Synchronous generators with 3 MW and higher rated capacities.

Harmonic analysis was performed by using Digsilent PowerFactory software taking into account the same elements as ones used in modelling by PSS/E.

Time of exploitation of transmission infrastructure projects represents the end of relevant year.

2.4 Differences compared with the previous 2016-2026 version of ten-year plan

As it has been already mentioned, the transmission network is experiencing continuous development as well as projects of transmission network development are being changed and modified. Such changes are depended on several factors – forecasts of generation and consumption, dates of commissioning of new power plants and decommissioning of aged power plants etc. In addition, calculations for ten-year plan and/or analysis methods are being improved annually. Therefore, below are the changes, which was carried out in comparison with 2017-2017 version of the ten-year plan.

- 1. The changes in commissioning dates and list of perspective power plants.** As far as construction of transmission network infrastructure is significantly intended for provision of reliable evacuation of generated power of power plants, therefore, the updating of data of power plants results in changes in transmission network projects. It is noteworthy new cascade in Svaneti region, river Enguri, possibly in 2029, with total capacity of 550 MW.
- 2. Change in forecasted characteristics of consumption growth.** Pessimistic, moderate and optimistic forecasted characteristics 3%, 5% and 7% have been changed to 1%, 3.5% and 5% respectively.
- 3. The changes in projects and the new ones.**
 - 3.1. "North Ring – Tskaltubo".** In this project, the 500/220/110 kV substation was replaced by 500/220/110 kV substation "Nenskra". Therefore, OHL "Khudoni-Mestia" was replaced by OHL "Nenskra-Mestia", within 220 kV range, but will initially operate on 110 kV. Double-circuit 220 kV transmission line "Khudoni-Jvari" was replaced by single-circuit 500 kV OHL "Nenskra-Jvari". OHL "Kavkasioni" will be tie-lined to "Nenskra-500", and the new OHL "Jvari-Nenskra" will be tie-lined to "Khudoni" HPP. New 500/220/110 kV substation will be constructed in Lajanuri to replace SS "Tsageri-500", where Kheledula HPP, Tskhenistskali Cascade and Oni Cascade will be connected. "Lajanuri-500" will be connected two SS "Tskaltubo" through 500kV OHL. "Sadmeli-220" and double-circuit OHL "Sadmeli-Zestaponi" where removed from the project; "Kheledula" HPP will be connected to SS "Lajanuri", instead of SS "Jakhunderi". Thus, double-circuit OHL "Kheledula-Jakhunderi" will be replaced with double-circuit OHL "Kheledula-Lajanuri",

- which will be constructed within 220 kV range, since “Tskhenistskali” cascade HPPs shall be tie-lined to this line;
- 3.2. “Jvari-Tskaltubo-Akhaltzikhe”. Considering scope of works, estimated date of exploitation of this project was postponed to 2021. Length of double-circuit OHL “Tskaltubo-Akhaltzikhe” (160km) was changed to 110 km;
 - 3.3. “Marneuli”. Construction of 500 kV OHL “Marneuli-Airum” was postponed till end of 2020;
 - 3.4. “Akhaltzikhe-Tortumi”. Date of exploitation of third block of HVDC back-to-back station was postponed to 2023;
 - 3.5. New 220/110 kV SS “Teleti” and tie-line of 220kV OHL “Algeta” to this substation where added to substation development project. Besides, this project includes addition of 2 new autotransformers to SS “Gldani 220”;
 - 3.6. Reinforcement of SS “Telavi” with 220 kV wing, as well as new 110/35 kV substation in Napareuli and 110 kV OHL Telavi-Napareuli were added to Kakheti Infrastructural Development Project;
4. **Possible types of conductors are replaced by transfer capacity.** Transfer capacity is given on 25°C temperature.
 5. **Strategic Environmental Assessment is provided for all projects.**
 6. **New challenges and relevant solutions are discussed.**

2.5 Structure

This Ten-Year Network Development Plan of Georgia has the following structure:

Chapter 1 – Executive Resume, provides brief overview of major purpose, content, outputs, projects, development scenarios, conclusions and recommendations applicable to the entire Ten-Year Plan.

Chapter 2 – Introduction, reviews legal compliance, planning criteria, process of preparation of the Ten-Year Plan, data management and engineering simulation softwares used for estimations.

Chapter 3 – Existing Situation, presents characteristics of Georgian transmission network and entire electric power system, capacities of OHLs and transformers, data about generation, capacities of cross-border lines, possible extremal power flows, network operation strategy, security level and network bottlenecks.

Chapter 4 – Inputs for Network Development Planning, provides information on capacities, outputs, categories and commissioning years of the planned power plants; information about decommissioning of aged power plants; forecasted annual demand growth percentages, estimated prices of substations of different voltage levels and costs of 1 km lines for different voltage level; Agreements with transmission system operators of neighboring countries and their network development close to Georgia border. Minimal technical requirements to power plants and units and special requirements to the back-to-back stations. Changes in projects based on assignments of ministry of energy and signed memorandums between government and power plants.

Chapter 5 – Georgian Transmission Network Development Drivers, Network security, transmission of existing generation, integration of new power plants and consumers, decommissioning of aged power plants, power system adequacy etc.

Chapter 6 – Strategy and Methodology for Development of Georgian Transmission Network, discusses the major principles and visions with respect to Georgian transmission network development, as well as describes its feasible development scenarios.

Chapter 7 – Forecasted Capacity and Energy Balances, annual energy balances (generation, consumption, export and import) and power balances (Summer and Winter Maximum and Minimum) for 2017-2027 time span, peak load forecasts for individual substations, generation adequacy.

Chapter 8 – Identified Projects and Required Investments, discusses and briefly describes transmission grid development projects envisaged for 2017-2027 time span, as well as their purpose, estimated costs and single line diagrams, their CBA (cost-benefit analysis) and assessment of individual projects. Summary investment needs by years.

Chapter 9 – Sequence of Georgian Transmission Network Developments, specifies commissioning years of the generation facilities and matching development of the transmission network.

Chapter 10 – Load Flow Analysis, deals with normal established modes for 2017-2027, and results of transmission losses and single contingency (N-1) analysis. Analysis of voltage, reactive power and substation reinforcement needs.

Chapter 11 – Short Circuit Analysis, specifies maximum and minimum short circuit currents in 500/400/330/220 kV bus bars.

Chapter 12 – Dynamic Stability Analysis, describes behaviour of the power system under single contingencies (N-1).

Chapter 13 – Harmonic Analysis, presents results of power quality study in normal (N) and single contingency (N-1) modes for 2017-2027 period.

Chapter 14 – Analysis of Georgian Transmission Network Development Indicators, provides information on length and capacities of the planned OHLs and substations needed for evacuation of the power output of generation facilities to the network.

Chapter 15 – Power Exchange Capabilities (NTC) and opportunities of integration of generation and consumption into the grid, specifies maximum feasible power flows to be transferred via cross-border lines, while ensuring stability and reliability of the power system. Except the power already considered in ten-year plan, which additional amount of generation and consumption is possible to connect in 500/220 kV nodes.

Chapter 16 – State-of-the-Art Technologies, describes SCADA, HVDC stations and emergency control system.

Chapter 17 – Ten Year Plan of SCADA and Information Technologies (IT) Development, development of optical connection and dispatch control of power system operation.

Chapter 18 – Opportunities of integration renewable energy sources into the Georgian power system. Challenges in case of integration of Wind and Solar energy as well as opportunities of their integration according to the conducted analysis are presented in this chapter.

Chapter 19 – Vision for 2028-2050 Horizon

Chapter 20 – Conclusions and Recommendations.

Abbreviations and Terminology

Reference

Annexes

3 Present Situation

According to Grid Code, transmission network development plan, besides other information must include information about operational characteristics:

- a. General characteristics of transmission network including cross-border connections with neighboring countries;
- b. Current situation of transmission network and analysis about locations not satisfying planning criteria;
- c. ... capacity of high voltage overhead lines;
- d. Power flow analysis of transmission network in case of maximum loads;

3.1 Transmission System Operator

Joint Stock Company “Georgian State Electrosystem” (GSE) – Dispatch Licensee became Transmission System Operator according to amendments (12 December 2014) to the “Georgian Law on Electricity and Natural Gas”. The parent company of GSE holding 100% of its shares is the state-owned JSC Georgian Partnership Fund. GSE was founded in 2002 in result of merger of former state-owned electricity transmission and dispatch companies (JSC Electrogadatsema and Electrodispatch Ltd.). Based on the Licenses and tariffs charged for transmission and dispatch services approved by Georgian National Energy and Water Regulatory Commission (GNERC), GSE implements technical control of the power system for ensuring stable supply/consumption regimes, and transmission of locally generated and imported power to distribution companies, eligible customers and neighbouring states’ power systems. GSE holds power transmission and dispatch licenses approved by GNERC on 20 December 2002.

3.1.1 System Dispatch

The National Dispatch Centre (NDC) located in GSE’s headquarters undertakes operating control of Georgian power system, and is responsible for sound operation of 500/400/330/220/110/35 kV transmission facilities and overall stability of the system as in the steady state, so under contingencies. This facility is equipped with state-of-the-art technologies allowing collection of the system information in on-line regime, remote control of the system and effective response to disturbances. For this, NDC receives comprehensive data from dispatched substations and power plants, maintains continuously updated database and promptly reacts to emergencies.

3.1.2 Power Transmission

The balance sheet assets owned by GSE and its daughter company Energotrans consist of 500/400/330/220/110/35 kV overhead lines with total length of 4,380 km and 93 substations with aggregated installed capacity of 12,114 MVA, including strategically important seven 500 kV and twenty-four 220 kV substations.

3.1.3 Mission

Gaining leading position in the regional energy sector, increasing the transit potential of the country and provision of domestic and foreign customers with high quality, reliable power transmission services.

3.2 2015 Statistics

| | |
|--|----------|
| Peak Load (MW) | 1 869 |
| Generation of Seasonal HPPs (mln kWh) | 3 335.23 |
| Generation of Regulated HPPs (mln kWh) | 5 118.53 |
| Generation of Thermal Power Plants (mln kWh) | 2 378.75 |
| Export (mln kWh) | 701.01 |
| Import (mln kWh) | 699.9 |
| Total Consumption (mln kWh) | 10 730.1 |
| Total Generation (mln kWh) | 10 832.5 |




Fig. 3.1

The total annual power output of seasonal power plants amounted to 3335.23 mln kWh, i.e. 9.14 mln kWh in average daily. The peak demand (1869 MW) was experienced on 31 December 2015. During the whole year, the frequency was maximally closed to the standard value (50 Hz) fluctuating in the range of 49.8-50.2 Hz. First in practise Energy export from Georgia to Turkey through Back-to-Back station has been implemented in 2014, resulting increase of loading of Georgian transmission network. However, level of technical losses was near 2% as well as outage statistic was the same as in previous years.




Fig. 3.2 Outages, 2003-2015




Fig. 3.3 Technical Losses in Transmission System (%), 2003-2015

3.3 Generation Data

Georgian power system is characterized by asymmetric generation/consumption pattern due to low demand and high generation in summer and high demand and low generation in winter allowing

Georgia to export the power during summer period. During winter, when less water is available for HPPs, thermal power's share in total generation increases to 28% from the less than 1% in summer.

The third of aggregated energy produced in the country comes from the largest Enguri HPP having installed and operating capacities of 1,300 MW and 1,200 MW respectively. This plant in tandem with Vardnili Cascade HPPs (second largest hydropower facility in Georgia) and other relatively lower capacity HPPs compose the pool of regulated hydro power plants with total installed capacity of about 1,990 MW.

By the end of 2017, total installed capacity will equal to 4059 MW, which includes installed capacity of HPPs 3113 MW and installed capacity of thermal power plants of 925 MW. It is anticipated that in 2018-2028, additional capacity of new HPPs will be added, which will provide the increase of total installed capacity from the existing 4059 MW to 4734 MW by 2020, 6093 MW by 2022 and 7590 MW by 2028.

In line with growth of hydropower generation, Georgia's dependence on imported and thermal power gradually decreased. In 2007, the total power output generated by HPPs amounted to 6.8 bln kWh, i.e. 82% of full national demand. In 2010, total hydropower generation grew to 9.4 bln kWh covering 93% of the demand. In 2013, domestic hydropower generation decreased to 8.3 bln kWh, as for 2016 – 9.3 bln kWh. Such variations in hydropower generation is explained by varying hydrology conditions, as well as rehabilitation of the existing plants.

Georgian power system is connected to the Russia, Turkey, Azerbaijan and Armenia and biggest part of electricity trade comes from first two countries. Energy import from mentioned power systems is implemented in order to satisfy demand increased in winter period, as for energy export – due to the surplus of electricity generated during natural fluid period in summer. Energy exchange between Georgia and Armenia is carried out by smaller volumes, relatively.

During 2006-2010, energy export volumes were continuously increasing year-by-year. In 2011-2013, due to the increased internal consumption, volume of electricity export was decreased, during 2014 – implemented energy export was equal to 0.6 bln kWh, which was 25% increase compared to the same indicator for 2013. It is noteworthy that in 2014, due to the increased consumption, 0.85 bln kWh energy import was implemented – an increase of 75% from the same data of 2013. In 2015-2016, export / import volumes are slightly different.

Tab. 3.1 Existing Power Plants in Georgian Power System for the end of 2017

| No | Power Plant | Installed capacity (MW) | Number of units | Type | Commissioning years |
|----|-----------------------|-------------------------|-----------------|--------------|---------------------|
| 1 | Enguri HPP | 1300.0 | 5x260 | Regulating | 1978 |
| 2 | Vardnili 1 HPP | 220.0 | 3x73.33 | Regulating | 1971 |
| 3 | Khrami 1 HPP | 113.5 | 3x37.6 + 1x0.65 | Regulating | 1947 |
| 4 | Khrami 2 HPP | 110.0 | 2x55 | Regulating | 1963 |
| 5 | Shaori HPP | 38.4 | 4x9.6 | Regulating | 1955 |
| 6 | Dzevrula HPP | 80.0 | 4x20 | Regulating | 1956 |
| 7 | Jinvali HPP | 130.0 | 4x32.5 | Regulating | 1984 |
| 8 | Rioni HPP | 48.0 | 4x12 | Run-of-River | 1933 |
| 9 | Gumati HPP cascade | 66.7 | 4x11 + 3x7.6 | Run-of-River | 1958-1956 |
| 10 | Vartsikhe HPP cascade | 184.0 | 8x23 | Run-of-River | 1976-1977 |
| 11 | Lajanuri HPP | 111.8 | 3x37.28 | Run-of-River | 1960 |

| | | | | | |
|----|---------------------|------|--------------|--------------|------|
| 12 | Zahesi HPP | 36.8 | 4x3.2 + 2x12 | Run-of-River | 1927 |
| 13 | Ortachala HPP | 18.0 | 3x6 | Run-of-River | 1954 |
| 14 | Chitakhevi HPP | 21.0 | 3x7 | Run-of-River | 1949 |
| 15 | Atshesi HPP | 16.0 | 2x8 | Run-of-River | 1937 |
| 16 | Satskhene HPP | 14.0 | 2x7 | Run-of-River | 1992 |
| 17 | Khadori HPP | 26.0 | 2x13 | Run-of-River | 2004 |
| 18 | Larsi HPP | 19.5 | 2x6.5 | Run-of-River | 2014 |
| 19 | Paravani HPP | 87.0 | 2x45 | Run-of-River | 2014 |
| 20 | Bjuja HPP | 12.2 | | Small HPP | 1956 |
| 21 | Tetrikhevi HPP | 13.6 | | Small HPP | 1952 |
| 22 | Alazani HPP | 4.8 | | Small HPP | 1942 |
| 23 | Abhesi HPP | 2.0 | | Small HPP | 1928 |
| 24 | Sioni HPP | 9.1 | | Small HPP | 1964 |
| 25 | Ritseula HPP | 6.3 | | Small HPP | 1967 |
| 26 | Chala HPP | 1.5 | | Small HPP | 1941 |
| 27 | Chkhori HPP | 5.4 | | Small HPP | 1967 |
| 28 | Dashbashi HPP | 1.3 | | Small HPP | 1935 |
| 29 | Mashavera HPP | 1.0 | | Small HPP | 1949 |
| 30 | Kabala HPP | 1.5 | | Small HPP | 1953 |
| 31 | Kakhareti HPP | 2.1 | | Small HPP | 1957 |
| 32 | Martkopi HPP | 3.9 | | Small HPP | 1952 |
| 33 | Intsoba HPP | 1.5 | | Small HPP | 1998 |
| 34 | Stepantsminda 2 HPP | 3.8 | | Small HPP | 1951 |
| 35 | Energetiki HPP | 0.5 | | Small HPP | 2006 |
| 36 | Algeta HPP | 1.3 | | Small HPP | 2006 |
| 37 | Matchakhela HPP | 1.6 | | Small HPP | 1957 |
| 38 | Misaktsieli HPP | 3.0 | | Small HPP | 1964 |
| 39 | Skuri HPP | 1.0 | | Small HPP | 1958 |
| 40 | Tiriponi HPP | 3.2 | | Small HPP | 1951 |
| 41 | Khertvisi HPP | 0.3 | | Small HPP | 1950 |
| 42 | Kinkisha HPP | 0.9 | | Small HPP | 1954 |
| 43 | Atchi HPP | 1.0 | | Small HPP | 1958 |
| 44 | Rustavi HPP | 0.5 | | Small HPP | 2009 |
| 45 | Sulori HPP | 0.8 | | Small HPP | 2009 |
| 46 | Okami 2007 HPP | 1.6 | | Small HPP | 2009 |
| 47 | Boldoda HPP | 2.5 | | Small HPP | 2009 |
| 48 | Zvareti HPP | 0.2 | | Small HPP | 2010 |
| 49 | Pshavela HPP | 1.0 | | Small HPP | 2010 |
| 50 | Igoeti HPP | 2.0 | | Small HPP | 1953 |
| 51 | Sanalia HPP | 3.0 | | Small HPP | 2007 |
| 52 | Mini khadori 1 HPP | 0.0 | | Small HPP | 2011 |
| 53 | Khadori 2 HPP | 6.0 | | Small HPP | 2012 |
| 54 | Khani HPP | 0.3 | | Small HPP | 2012 |
| 55 | Racha HPP | 11.0 | | Small HPP | 2013 |
| 56 | Dagva HPP | 0.1 | | Small HPP | 2013 |
| 57 | Alazani 2 HPP | 6.0 | | Small HPP | 2013 |
| 58 | Shilda HPP | 5.0 | | Small HPP | 2013 |
| 59 | Stepantsminda HPP | 6.0 | | Small HPP | 2014 |
| 60 | Bakhvi-3 HPP | 10.0 | | Small HPP | 2013 |

| | | | | | |
|-----|-------------------------------|---------------|---------|---------------------|-------|
| 61 | Pantiani HPP | 0.4 | | Small HPP | 2012 |
| 62 | Aragvi HPP | 8.5 | | Small HPP | 2014 |
| 63 | Akhmeta HPP | 9.1 | | Small HPP | 2014 |
| 64 | Pshavela HPP | 2.0 | | Small HPP | 2015 |
| 65 | Kazreti HPP | 2.5 | | Small HPP | 2014 |
| 66 | Dariali HPP | 108.0 | | Run-of-River | 2016 |
| 67 | Saguramo HPP | 4.2 | | Run-of-River | 2016 |
| 68 | Kintrisha HPP | 6.0 | | Run-of-River | 2016 |
| 69 | Shuakhevi HPP | 187.0 | | Daily Reg | 2016 |
| 70 | Skhalta HPP | 6.0 | | Run-of-River | 2016 |
| 71 | Khelvachauri-1 HPP | 47.5 | | Daily Reg | 2016 |
| 72 | Unit №9 | 300.0 | 1x300 | Thermal Power Plant | 1991 |
| 73 | Units №3, №4 | 272.0 | 130+142 | Thermal Power Plant | 1963 |
| 74 | Gas turbine | 110.0 | 2x55 | Thermal Power Plant | 2006 |
| 75 | Tkibuli Coal TPP | 13.0 | 2x6.5 | Thermal Power Plant | 2011 |
| 76 | Gardabani CCGT | 230.0 | 2x75+80 | Thermal Power Plant | 2015* |
| 77 | Wind Farm | 20.7 | | Wind farm | 2016 |
| I | Sum of Regulating HPPs | 2226.4 | | | |
| II | Sum of RoR HPPs | 934.3 | | | |
| III | HPPs in total | 3160.7 | | | |
| IV | TPPs in total | 925.0 | | | |
| V | System | 4106.4 | | | |

3.4 Current Opportunities for Power Exchange with Neighbouring Countries

In result of its geographical location, Georgia can gain an important function in course of the planned regional integration of the power systems of the Caucasian (and Black Sea) countries assuming promotion of energy trading between these states and development and use of Georgian hydropower resources.

At present, power exchange between Georgian power system and its neighbouring systems is carried out by 500/400/330/220 kV overhead lines.

Energy exchange is implemented: From Georgia to Russia, Turkey, Azerbaijan, Armenia and vise-versa as well as From Russia to Turkey, from Azerbaijan to Turkey. Cross-border overhead lines serve for realization this task, however, such “international” power flows are restricted due to both limitations stemmed from the acceptable operating modes of national power system (tab. 3.2, fig 3.4) and transmission capacities of above mentioned cross-border OHLs.

Table 3.2 Present power exchange capabilities with neighbouring power systems

| Country | Cross-border line, conductor | Nom. Voltage (kV) | Exchange | TTC (MW) | Mode |
|---------|------------------------------|-------------------|----------|----------|------|
| Russia | „Kavkasioni“ AC-3x300 | 500 | Export | 700 | ≈ |
| | | | Import | 700 | ≈ |
| | „Salkhino“ | 220 | Export | 50 | isl |

| | | | | | |
|------------|------------------------------|-----|--------|---------|-----------|
| | AC-400 | | Import | 150 | isl |
| Azerbaijan | „Mukhranis Veli“ AC-3x300 | 500 | Export | 700 | ≈ |
| | | | Import | 700 | ≈ |
| | „Gardabani“ AC-480 | 330 | Export | 320 | ≈ |
| | | | Import | 320 | ≈ |
| Armenia | „Alaverdi“ AC-300 | 220 | Export | 150/100 | ≈/isl |
| | | | Import | 150/100 | ≈/isl |
| Turkey | „Meskhethi“ AC-3x300 | 400 | Export | 700 | B2B * |
| | | | Import | 700 | B2B |
| | „Adjara“ AC-400 | 220 | Export | 150 | isl (res) |
| | | | Import | 150 | isl (res) |



Fig. 3.4 Cross-border transfer capacities between power systems of Georgia and its neighbouring countries

3.5 Main Present Power Exchange Flows

As noted above, the major Georgian generation sources are concentrated in Enguri River basin, and include Enguri HPP and Vardnili HPP. During summer flood period (May-June-July), the total power generated by these plants amounts to 1250 MW. From this, one part (250 MW) is transmitted to Abkhazia by OHL Kolkhida-3 (Vardnili HPP – Ochamchire), other part (100 MW) is used for feeding

Zugdidi, Menji and Batumi substations (110 kV double circuit OHL Shesheleti-1,2 (Vardnili-Gali). Remaining almost 900 MW is transported to the east by 500 kV OHL Imereti, and distributed between export to Turkey through SS Akhaltsikhe (350 MW) and power supply of Tbilisi-Rustavi load centre. Meantime, demand of the bulk load centres of Tskaltubo-Kutaisi (100 MW) and Zestaponi (250 MW) is mainly balanced by several local hydro power plants located in Kutaisi-Tskaltubo (320 MW) and Zestaponi (30 MW) regions. Thus, roughly 900 MW power is available for transfer through OHL Imereti to the east. From this, about 550 MW is required for feeding Tbilisi-Rustavi and Khashuri-Gori load centres, and remaining 350 MW may be transferred to Turkey. Since OHL Imereti is unable to transport more than 900 MW, during summer months, possibilities for power transit from Russia to Turkey are limited, even Georgian and Russian power systems operate in parallel regime. In result of such load flow pattern, 350 MW conversion/transmission capacity of the HVDC back-to-back station located in SS Akhaltsikhe remains “vacant” that may be dedicated to transferring power inflows from Azerbaijan and/or Armenia under the island layout.

It should be noted that, assuming such loading of OHL Imereti, its loss should lead to overloading and tripping of 220 kV transmission mains connecting Enguri HPP and SS Zestaponi that is avoided by operation of Emergency Control System (ECS), which initiates generation reduction in Enguri basin and load/export shedding in Tbilisi-Rustavi/Akhaltsikhe, such as to keep the power flow within acceptable limits.

Therefore, the eastward transmission capacity must be increased by means of constructing parallel branch to 500 kV Imereti that will allow avoidance of generation/load shedding by ECS, i.e. development of the transmission network should ensure fulfilment of single contingency (N-1) criterion under any operating mode.




Fig. 3.5 Bulk power flows during flood period

3.6 Operating strategy, security of supply and adequacy level of Power system

Operation strategy. For purposes of analyzing power system security and designing appropriate control systems, it is helpful to conceptually classify the system-operating conditions into five states: normal, alert, emergency, in extremis and restorative.




Fig. 3.6 Power system operating states

In the normal state, all system variables are within the normal range and no equipment is being overloaded. The system operates in a secure manner and is able to withstand a contingency without violating any of the constraints. This means there are enough reserves of generation in power system as well as enough reserves of transmission system capacity. System meets N-1, G-1 and N-G-1 conditions.

The system enters the alert state if the security level falls below a certain limit of adequacy, or if the possibility of a disturbance increases because of adverse weather conditions such as the approach of severe storms. In this state, all system variables are still within the acceptable range and all constraints are met. However, the system has been weakened to a level where a contingency may cause an overloading of equipment that places the system in an emergency state. If the disturbance is very severe, the in extremis (or extreme emergency) state may result directly from the alert state.

Preventive action, such as generation shifting (security dispatch) or increased reserve, can be taken to restore the system to the normal state. If the restorative steps do not succeed, the system remains in the alert state.

The system enters the emergency state if a sufficiently severe disturbance occurs when the system is in the alert state. In this state, voltages at many buses are low and/or equipment loadings exceed short-term emergency ratings. The system is still intact and may be restored to the alert state by the initiating of emergency control actions: fault clearing, excitation control, fast-valving, generation

tripping, generation run-back, HVDC modulation, and load curtailment. If the above measures are not applied or are ineffective, the system is in extremis; the result is cascading outages of possibly a shut-down of a major portion of the system. Control actions, such as load shedding and controlled system separation, are aimed at saving as much of the system as possible from a widespread blackout.

The restorative state represents a condition in which control action is being taken to reconnect all the facilities and to restore system load. The system transits from this state to either the alert state or the normal state, depending on the system conditions.

Present transmission grid of Georgia. Georgian Power system had been designed for parallel operation with big united power system and as well as for case of simultaneous operation of all interconnection line with Russia, Armenia and Azerbaijan. Hence 500 kV grid which had radial topology in territory of Georgia, was backed up by three neighbor countries simultaneously. Moreover, 500 kV grid was acting as one of the branch of big power system. Hence, emergency outage of any network element (500 kV OHL or big generation unit) in Georgian system didn't lead to limit consumers. Starting from 90's, due to the independent reasons, there was no possibility of parallel synchronous operation with more than one neighbor country, which caused leaving internal radial network of Georgia as well as any operating interconnection line without backup. Specific emergency situation was in case of island operation of Georgian power system. In such case, outage of any 500 kV OHL as well as any dead end 220 kV OHL (see below) and 100 MW or bigger generation unit (#3, #4, #9 unit in Gardabani and units in Enguri HPP) causes severe condition in emergency point of view. One of the reason of this situation is that there are no speed governors and excitation system in some part of generation units or, at least they are aged enough and decommissioned because they do not meet requirements of "technical operation rules" and "Grid Code", which leads to more difficult condition of voltage control as well as more difficult situation for frequency control in isolated mode.

At the end of 2016 the following projects in terms of transmission network reinforcement have been commissioned: 220/110 kV SS Khorga, 500/220 kV SS Jvari, double circuit 220 kV OHL Khorga-Menji (Khorga 1,2). At the beginning of 2017, construction of double circuit 220 kV OHL Jvari-Khorga (Odishi 1,2) will be completed, also SS Jvari will be tied to 500 kV OHL Kavkasioni. Network bottlenecks such as 500/220 kV AT Enguri, Double circuit 220 kV OHL Egrisi 1,2, 220 kV OHL Kolkhida-2a, 220 kV OHL Kolkhida-2 still stay unreserved despite implementation of above mentioned infrastructure. Reserving of these bottlenecks will be realized after commissioning of double circuit 220 kV OHL Jvari-Khorga. At the end of 2016, 220 kV OHL Sataplia 2 has been commissioned, as for 220 kV OHL Ajameti 3, it will be completed for the beginning of 2017. These two 220 kV OHLs will increase safe evacuation of the generation from Kutaisi-Tskaltubo node, also together with new infrastructure of Jvari-Khorga will increase reliability of 220 kV grid in West part of Georgia. Construction of double-circuit 220 kV OHL Batumi-Shuakhevi was completed in 2017, which, at first stage will ensure integration of Shuakhevi HPP into the grid. In addition, starting from 2018, in case of outage of 500 kV OHL Imereti, disconnected capacity of consumers will decrease significantly, since OHL Imereti will be reserved by at least three 220 kV OHLs. 220 kV line Surami – Urnisi – Liakhvi is not effectively reserved and in case of overload of 500 kV OHLs Kartli-2 and Vardzia, and in case of outage of either of them, there is a threat of overloading 220 kV route and splitting Georgia's power supply system. In case of outage of 220 kV lines connecting to SS Gldani, 220 kV OHL Aragvi might overload because of Gldani's increased consumption. Besides, 500/220 kV SS Marneuli was put into operation, and 500 kV OHL Asureti (Mukhrani) was tied-lined to it. As a result, the 500 kV network reliability was enhanced and Gardabani 500/220 kV transformer was fully reserved. Based on the above, several weaknesses in the network were eliminated.

Bottlenecks of transmission network of Georgia are:

- Interconnection lines
 - Kavkasioni, 500 kV
 - Gardabani, 330 kV
 - Alaverdi, 220 kV
 - Meskheta, 400 kV
 - Adjara, 220 kV
- Radial / Inefficiently reserved network of West Georgia
 - Imereti, 500 kV
 - Zekari, 500 kV
 - Autotransformer at Enguri, 500/220 kV
 - Egrisi 1,2
 - Kolkhida 2a
 - Kolkhida 2
- Batumi supply grid
 - Paliastomi 1,2
- 220 kV grid of Shida Kartli, reserved inadequately:
 - Surami
 - Urbnisi
 - Liakhvi
 - Aragvi
- 220 kV dead end transmission lines
 - Kolkhida 3
 - Derchi
 - Lomisi
 - Manavi
 - Paravani
 - Sno (Ksania-Dariali HPP)




Fig 3.7 Single line diagram of Georgian transmission network

As a conclusion from above mentioned, in case of outage of OHLs Kavkasioni, Alaverdi, Meskheti, Adjara, Imereti, Paliastomi 1,2, Kolkhida 3, Derchi, Lomisi and Manavi there is a risk of tripping of consumers/generation units, in addition there is risk of load shedding in case of outage of #3, #4 and #9 units in Gardabani and units of Enguri HPP. Hence, there is a huge risk to violation of N-1 criteria which will be shown in the table of statistic of emergency outage of network elements (Tab. 3.3), where we can find that the biggest challenge for system stability is the outage of 500 kV OHL Imereti which supplies the most part of East Georgia from Enguri bus bar during summer period. Hence, despite of existence of very high reliable emergency automatic in Georgia system, average level of energy not supplied caused by outage of OHL Imereti is about 1.20 ml. kWh/year. After Imereti, the most problematic elements of network in terms of emergency outage are 220 kV OHL Paliastomi 2 (because simultaneous outage of these two 220 kV OHLs led to complete blackout of Adjara region), then 220 kV OHL Kolkhida 3 (Abkhazia region), 9th unit of Gardabani, 2nd and 3rd units of Enguri and 500 kV OHL Kavkasioni (cross-border line with Russia). In this point of view, 400 kV OHL “Meskheti” connecting Georgian system to Turkish one worth to be separately noted because its outage led to 7.27 mln kWh nonrealized energy export, which is not energy not supplied to Georgian consumers, but it is energy had to be transferred as export to Turkey what would be significant revenue for Georgia and participants of its power system.

As a conclusion, operation mode of Georgian transmission network corresponds “alert mode” even if there are all the elements at normal operating condition and all the parameters are at their normal ranges. Therefore, **security of supply is the most critical problem of Georgian transmission network** and **increase of security of supply/system reliability is the main scope of transmission network development during nearest ten years.**

Hence, maintain of security criteria:

- N-1, G-1;
- Maintaining voltage level in permissible range;
- Maintaining frequency in permissible range.

will be goal of Georgian transmission network and whole power system, reaching of which requires reinforcement of transmission network and adding new element to the grid.

Tab 3.3

Reliability indicators and averaged statistic for 2012-2016 of emergency outage of 500, 400, 330, 220 kV OHLs and 100MW or more powerful generation units

| Element | | Voltage | N | T | U | DE |
|---------|--------------------|---------|-------------|-------------|-------|------------|
| Type | Name | kV | (Numb/year) | (Hour/year) | % | (kWh/year) |
| OHL | Kavkasioni | 500 | 21.8 | 124.39 | 1.42% | 206 103 |
| OHL | Imereti | 500 | 5.2 | 9.54 | 0.11% | 1 067 258 |
| OHL | Kartli 2 | 500 | 1.2 | 0.2 | 0.00% | 0 |
| OHL | Kartli 1 | 500 | 3.2 | 1.33 | 0.02% | 0 |
| OHL | Zekari | 500 | 9.8 | 115.15 | 1.32% | 0 |
| OHL | Vardzia | 500 | 37.6 | 51.31 | 0.59% | 0 |
| OHL | Gachiani | 500 | 0 | 0 | 0.00% | 0 |
| OHL | Asureti (Mukhrani) | 500 | 6.8 | 8.48 | 0.10% | 0 |
| OHL | Mukhranis Veli | 500 | 0 | 0 | 0.00% | 0 |

| | | | | | | |
|-----|---------------|-----|------|---------|-------|---------------------------|
| OHL | Meskheta | 400 | 17 | 66.31 | 1.90% | 0 ^{(7 276 827)*} |
| OHL | Gardabani | 330 | 13.5 | 11.6 | 0.19% | 24 061 |
| OHL | Egrisi 1 | 220 | 4 | 8.07 | 0.09% | 93 432 |
| OHL | Egrisi 2 | 220 | 2.4 | 4.51 | 0.06% | 0 |
| OHL | Paliastomi 1 | 220 | 5.2 | 34.51 | 0.40% | 45 726 |
| OHL | Paliastomi 2 | 220 | 11 | 40.18 | 0.46% | 804586 |
| OHL | Kolkhida 1 | 220 | 5 | 10.31 | 0.12% | 33 804 |
| OHL | Kolkhida 2 | 220 | 2.4 | 3.48 | 0.04% | 3733.4 |
| OHL | Kolkhida 2a | 220 | 4.8 | 7.05 | 0.08% | 1 920 |
| OHL | Sataflia | 220 | 2 | 7.23 | 0.08% | 0 |
| OHL | Derchi | 220 | 3 | 19.14 | 0.22% | 7 810 |
| OHL | Ajameti 1 | 220 | 1.4 | 3 | 0.03% | 4 535 |
| OHL | Ajameti 2 | 220 | 1.6 | 2.09 | 0.03% | 0 |
| OHL | Surami | 220 | 1.2 | 4.24 | 0.05% | 0 |
| OHL | Urbnisi | 220 | 3.2 | 0 | 0.00% | 0 |
| OHL | Liakhvi | 220 | 3.8 | 0.18 | 0.00% | 0 |
| OHL | Lomisi | 220 | 1.2 | 0.3 | 0.01% | 1 034 |
| OHL | Aragvi | 220 | 2.6 | 4.46 | 0.05% | 13 419 |
| OHL | Didgori 1 | 220 | 1.8 | 11.22 | 0.13% | 0 |
| OHL | Didgori 2 | 220 | 1.8 | 13.34 | 0.16% | 0 |
| OHL | Koda 1 | 220 | 2.8 | 0.01 | 0.00% | 0 |
| OHL | Koda 2 | 220 | 2.6 | 1.26 | 0.02% | 0 |
| OHL | Lomtagora | 220 | 0 | 0 | 0.00% | 0 |
| OHL | Lomtagora 2 | 220 | 0.8 | 0.002 | 0.00% | 0 |
| OHL | Varketili | 220 | 1 | 4.49 | 0.06% | 0 |
| OHL | Kukia | 220 | 2.4 | 3.16 | 0.04% | 0 |
| OHL | Navtlugi 1 | 220 | 0.2 | 1.32 | 0.02% | 0 |
| OHL | Navtlugi 2 | 220 | 0.2 | 0 | 0.00% | 0 |
| OHL | Veli 1 | 220 | 0.4 | 0 | 0.00% | 0 |
| OHL | Veli 2 | 220 | 1 | 0.01 | 0.00% | 0 |
| OHL | Algeta | 220 | 1.2 | 0.09 | 0.00% | 0 |
| OHL | Manavi | 220 | 4.6 | 31.1 | 0.36% | 17 097 |
| OHL | Didube 3 | 220 | 0.6 | 1.42 | 0.02% | 0 |
| OHL | Didube 4 | 220 | 0.8 | 0.47 | 0.01% | 0 |
| OHL | Pero 3 | 220 | 8.4 | 5.31 | 0.06% | 43 914 |
| OHL | Salxino | 220 | 3.2 | 6.5 | 0.08% | 13 583 |
| OHL | Adjara | 220 | 0.8 | 0.13 | 0.00% | 3 933 |
| OHL | Kolkhida 3 | 220 | 14.6 | 15.22 | 0.18% | 695 727 |
| OHL | Alaverdi | 220 | 8.6 | 15.28 | 0.18% | 12 549 |
| OHL | Senaki 1 | 220 | 1.4 | 0.43 | 0.01% | 0 |
| OHL | Senaki 2 | 220 | 0.8 | 0 | 0.01% | 0 |
| OHL | Rukhi | 220 | 1 | 0.06 | 0 | 0 |
| OHL | Khorga 1 | 220 | 0.2 | 0 | 0 | 0 |
| OHL | Khorga 2 | 220 | 0.2 | 0 | 0 | 0 |
| Gen | Enguri HPP g1 | 500 | 1 | 124.319 | — | 32 116 |

| | | | | | | |
|-----|-------------------|-----|-----|--------------|---|------------------|
| Gen | Enguri HPP g2 | 500 | 1.4 | 12.016 | – | 155 812 |
| Gen | Enguri HPP g3 | 500 | 0.4 | 0.368 | – | 30 658 |
| Gen | Enguri HPP g4 | 500 | 1.6 | 6.577 | – | 63 279 |
| Gen | Enguri HPP g5 | 500 | 0 | 0 | – | 0 |
| Gen | Gardabani unit N3 | 220 | 0 | 0 | – | 0 |
| Gen | Gardabani unit N4 | 220 | 0.2 | 8.799 | – | 662 |
| Gen | Gardabani unit N9 | 500 | 0.4 | 31.913 | – | 251 529 |
| | | | | Total | | 3 628 280 |

In Tab. 3.2: N – number of outages of element per year; T – Recovery time after emergency outage. U – Number of emergency outages (T/8760). DE – Amount of Energy not supplied during year. It should be noted that only parts of T and N correspond to DE because in most cases outage of element does not lead to interrupt energy transmission on appropriate OHL. Flow with little amount was in specific regime and N-1 criteria has been reached in case of outage of loading of its parallel branches.

* - Approximately 7.27 mln kWh nonrealized energy export caused by outages of 400 kV OHL “Meskheti”.

Low inertia phenomenon. Frequency shall be near nominal value to ensure reliable operation of the system.

Frequency is a system parameter, which is same at any given time (and changes similarly), at any point of the power supply system.

Frequency depends on the balance of actual capacity. Change of consumption of actual capacity or generation at one particular point of the system will result in the change of frequency in the whole supply system. Disconnection of power line of generator or system, results in capacity deficit and frequency reduction, and vice versa - higher load or line outage will cause increase of frequency.

Generator movement equation shall be written approximately in the following manner:

$$\frac{df}{dt} = \frac{1}{T_M} (P_m - P_e) \quad (1)$$

Where:

f = network frequency at instant;

T_M = constant of the total inertia of power system generators;

P_m = total generated mechanical capacity of generators (i.e. generated by their turbines);

P_e = total electric load capacity on generator shafts.

Equation shows that the frequency will be permanent, if total generated and total consumption capacities are equal. In addition, in case of excess generated (mechanical) capacity (occurs during load outage) frequency derivative will be positive; In case (electric) capacity of total system load is higher than generated capacity, frequency derivative will be negative, i.e. frequency will start to decrease. Besides, the more inertive the system is, the slower will change of frequency occur (i.e. more generators are connected in the system).

During capacity imbalance, in order to avoid unacceptable increase or decrease of frequency, system generators shall be equipped with capacity regulating equipment – speed regulators, which will ensure primary speed regulation according to their static coefficients.

It should be noted that speed regulators, as representing complex of electric-hydraulic-mechanical equipment, are characterized by long delay from receiving signal till its operation (1-2 seconds). Therefore, during this period, active capacity of turbines is unchanged, as well as deficit.

Therefore, frequency reduction depends on total system inertia only. Thus, as the movement equation shows, the higher system inertia is, the lower system deviation and vice versa, the lower system inertia, the more sensitive system frequency is towards small disturbances. Inertia constant depends on the mass of connected units, geometric dimensions, number of rotations and nominal capacity, although can be shown as value proportionate to nominal value of units.

$$T_M \approx \frac{P_n}{18}$$

Thus, (1) the equation may be formulated in the following manner, at $t = 1$ end of second:

$$\Delta f = \frac{18}{P_n} (P_m - P_e) t \quad (2)$$

Thus, the higher total nominal capacity of the system (connected units), the lower frequency deviation.

As summaration of above mentioned, frequency deviation for the end of first second, when there is 100 MW deficit in power system, for the system with 1200 MW installed capacity is 1.5 Hz (48.5 Hz), as for 2250 MW system – 0.8 Hz (49.2 Hz – activation setpoint for load shedding relays). Hence, nominal capacity of the system, in case of which loss of the biggest generation unit does not lead to the decrement of frequency below to 49.2 Hz is calculated as follows:

$$P_n = \frac{18}{\Delta f} (P_m - P_e) t = \frac{18}{0.8} (100 - 0) 1.0 = 2250 \text{ MW}$$

Taking into account that even in case of the most loaded scenario, ratio between summary installed capacity of operating generation units and total installed capacity of the system equals to 0.7, total installed capacity of Georgian power system in case of which loss of 250 MW generation unit does not lead to the activation of load shedding will be $2250/0.7 = 3214$ MW. This amount will be achieved during 2028-2030, before this period there will be deficit of inertia (installed capacity of power system).

3.7 Main Network Bottlenecks of the Georgian transmission network and projects to eliminate them

Transmission network of Georgia has predominantly axial arrangement i.e. it is oriented from west to east. The main 500 kV substations are “Enguri”, “Zestaponi”, “Akhaltsikhe”, “Ksani” and “Gardabani”. Transmission grid of Georgia may be theoretically divided into East and West districts, dividing bus bar of which is ss „Zestaponi”.

Power capacity of 500 kV OHL is about 5 times more than power capacity of 220 kV OHL, hence main part of power flows is implemented by 500 kV OHLs of Georgian Transmission network. Enguri HPP is connected to Zestaponi bus bar by 500 kV OHL Imereti. There is no parallel branch of this line in east part of Georgia and therefore, emergency outage of Imereti causes overload of 220 kV energy corridor Vardnili-Zugdidi-Menji-Kutaisi-Zestaponi. Hence, non-existence of 500 kV parallel connection of Imereti is the main bottleneck of West part and entire Georgian transmission network. Therefore, in order to meet N-1 criteria, system automatic should trip part of consumers in East Georgia and part of Generation in Enguri HPP in such manner that after fault in steady-state power flow on 220 kV OHLs in West part of Georgia will not exceed permissible ranges. In addition, emergency outage of 500 kV OHL Zekari (Zestaponi-Akhaltsikhe) may be the result of impossibility of power transit from Russia to Turkey in summer flooding period.

Despite 67 km 500 KV OHL line “Zekari” is backed up by OHLs “Qartli 2”, “Vardzia”, the sum of length of these two lines is near 325 km what makes impossible to backup OHL “Zekari” in case of bulk power flow on this line.

Supply of substation Batumi is carried out by long overhead lines – Paliastomi-1 (Menji-Batumi) and Paliastomi-2 (Vardnili-Batumi) 97 km and 150 km respectively. This lines represents the parallel branch of 220 kV energy corridor Vardnili-Zugdidi-Menji. Due to their lengths there are voltage problems in 220 kV ss Batumi. This issue is actual in case of power export from Batumi to Khopa (Turkey). In addition, outage of either Paliastomi-1 or Paliastomi-2 may result overload of 220 kV OHLs Kolkhida-2a and Kolkhida-2.

One of the weakest point of Georgian transmission network is 500/220 kV autotransformer in Enguri, power capacity of which is 450 MW (500 MVA). This restricts power flow in Vardnili direction by 220 kV double-circuit lines Egrisi-1,2. Outage of above mentioned AT causes voltage problems in Ajara-Abkhazia-Guria-Samegrelo districts.

Another one of the most problematic element of East part of Georgian transmission grid is 220 kV OHL Kolkhida-3 which serves power transit from Vardnili HPP to Abkhazia (250 MW). This is due to non-existence of parallel line of Kolkhida-3. Hence, outage of this line results abundance in system which is equal to power flow on Kolkhida-3 in pre-fault mode.

500 kV OHL Kavkasioni which is main connector of Georgian and Russian power systems is weak point of Georgian system as well due to its length (405.5 km) and difficult relief of highway (main ridge of Kavkasioni). Outage of above mentioned line has negative effect on stability of Georgian system and Power Quality (frequency control is mainly implemented by Russian system).

400 kV OHL Meskheti – connecting Georgia to Turkey. However length of this line is not critically huge (less than 150 km), it will serve in 700 MW transit and its emergency outage will cause huge abundance of power in Georgian power system.

220 kV OHL Alaverdi (Gardabani-Alaverdi) connects Georgia to Armenia and is weak point by which is possible to implement only 150 MW power exchange between this countries in synchronous mode and 100 MW in Island mode.

Disbalance of Active as well as reactive power may be the result of outage of 500 kV lines in Georgian system and action of system automatic. Hence, fast-acting, regulated reactive power compensator SVS or FACTS Device may be required in both East and West part of Georgian power system.

Thus, weak and problematic points of Georgian transmission networks are:

- 500 kV OHL Imereti;
- 500 kV OHL Zekari;
- 500 kV OHL Kavkasioni; 400 kV OHL Meskheti; 220 kV OHL Alaverdi;
- Security of Supply of Ajara-Abkhazia-Guria-Samegrelo districts;
- 220 kV OHL Kolkhida 3;
- 220 kV OHLs Ajameti-1,2; 220 kV OHL Sataplia;
- Enguri units;
- 9th thermal unit of Gardabani.

Several projects are considered in 10-year network development plan of Georgia which will resolve above mentioned problems, integrate new HPPs into the grid and reinforce transit ability of Georgian system.

Toghether Jvari-Khorga and Tskaltubo-Zestaponi (already in operation) projects:

1. Backs up the following present weak points:

- 500/220 kV Autotransformer Enguri;
- 220 kV double-circuit line Egrisi-1,2;
- 220 kV OHL Kolkhida 2a;
- 220 kV OHL Kolkhida 2;
- 220 kV OHLs Ajameti-1,2;

2. Reinforces Security of Supply of ss Batumi;

3. Partly backs up 500 kV OHL Imereti and reduces value of consumers to be tripped by system automatic in case of emergency outage of above mentioned line.

Jvari-Tskaltubo-Akhaltzikhe Project (in parallel of integration of Enguri HPP, Namakhvani HPP and other HPPs) will resolve the most problematic issue in Georgian transmission network – complete backup of 500 kV OHL Imereti, after outage of which system automatic will not trip consumers in Georgia.

Ksani-Stepantsminda-Mozdok Project, which is parallel line of 500 kV OHL Kavkasioni, will reserve it and reinforce stability of Georgian system. Outage of 500 kV OHL Kavkasioni will not result power abundance or deficit and therefore trip of consumers or generation by system automatic. This project will partly backup 500 kV OHL Imereti by North Caucasian network.

400 kV OHL Akhaltsikhe-Tortum will fully backup 400 kV OHL Meskheti (Akhaltsikhe-Borchkha) and power disbalance will not arise after outage of 400 kV OHL Akhaltsikhe-Tortum.

Marneuli Project (500 kV OHL Marneuli-Airum) will fully replace 220 kV OHL Alaverdi and ensure reinforcement of power transit ability among Russia-Georgia-Armenia-Iran.

This projects, besides of above mentioned goals may have some other designations, for example, integration of HPPs and increase of cross-border capacity (see chapter “Identified Projects and Investment Needs”).

Project “Akhaltsikhe – Batumi” will increase reliability of supply of “Adjara” region (besides integration of “Shuakhevi”, “Koromkheti” and other HPPs of Upper Adjara region) and will help to backup 500 kV OHL “Imereti” with projects “Jvari – Khorga” and “Tskaltubo – Zestaponi”.

Power plants “Khudoni HPP”, “Nenskra HPP” and “Namakhvani Cascade HPPs” are increase on one hand flexibility of the system and on the other hand inertia constant and with this respect they increase the sustainability of the Energysystem. Therefore after commissioning of these HPPs will not be problematic swiching of Enguri units and N9 block.

To ensure reliability of Kakheti region power supply, construction of 110 kV route Akhmeta-Telavi-Gurjaani is planned (within 220 kV range), as well as addition of 220 kV wing to SS Telavi, reinforcement of SS Telavi with 220 kV wing and 125 MW autotransformer, addition of new 220/110 kV 125 MW autotransformer at SS Gurjaani“.

Shida Kartli network reliability plan is under elaboration.

3.8 Specifications of 500/400/330/220 kV overhead lines of Georgian transmission system

Table 3.4 Parameters of Overhead lines of 500/400/330/220 kV transmission network of Georgia

| № | Name of OHL | From (SS) | To (SS) | Rated Voltage (kV) | Circuit | Conductors (Type, number, cross-section) | Length (km) | Capacity (MW) | |
|----|----------------|-------------|--------------|--------------------|---------|--|-----------------|---------------|--------|
| | | | | | | | | Winter | Summer |
| 1 | Kartli-1 | Ksani | Gardabani | 500 | Σ | AC-3x400/51 | 91 | 870 | 765 |
| 2 | Kartli-2 | Zestaponi | Ksani | 500 | Σ | AC-3x400/51 | 164 | 870 | 765 |
| 3 | Imereti | Enguri | Zestaponi | 500 | Σ | AC-3x400/51 | 127.5 | 870 | 765 |
| 4 | Lia | Enguri | Jvari | 500 | Σ | AC-3x300/66 | 16 | 650 | 572 |
| 5 | Mukhrani | Ksani | Marneuli | 500 | Σ | AC-3x330/43 | 75 | 650 | 572 |
| 6 | Vardzia | Akhaltsikhe | Gardabani | 500 | 1 | AC-3x330/43 | 77.72 | 1588 | 1397 |
| | | | | | 2 | AC-3x300/67 | 53.36 | | |
| | | | | | 3 | AC-3x400/93 | 29.63 | | |
| | | | | | Σ | | 160.7 | | |
| 7 | Zekari | Zestaponi | Akhaltsikhe | 500 | 1 | AC-3x330/43 | 3.72 | 1588 | 1397 |
| | | | | | 2 | AC-3x300/67 | 29.46 | | |
| | | | | | 3 | AC-3x300/204 | 34.19 | | |
| | | | | | Σ | | 67.31 | | |
| 8 | Kavkasioni | Jvari | Tsentralnaya | 500 | Σ | AC-3x300/66 | 89.5 [390.5] | 650 | 572 |
| 9 | Gachiani | Gardabani | Marneuli | 500 | Σ | AC-3x400/93 | 30 | 1926 | 1695 |
| 10 | Mukhranis Veli | Gardabani | Samukh | 500 | Σ | AC-3x330/43 | 19.5 [182] | 715 | 629 |
| 11 | Meskhети | Akhaltsikhe | Borchka | 400 | Σ | AC-3x500/64 | 32.6 [152.2] | 1794 | 1578 |
| 12 | Gardabani | Gardabani | Agstapa | 330 | Σ | ACO-480 | 21.1 [64] | 237 | 209 |
| 13 | Koda-1 | Marneuli | Lisi | 220 | Σ | AC 400/51 | 35.5 | 226 | 212 |
| 14 | Koda-2 | Gardabani | Lisi | 220 | Σ | AC 400/51 | 35.5 | 226 | 212 |
| 15 | Didgori-1 | Ksani | Lisi | 220 | Σ | AC 300/39 | 18.7 | 206 | 188 |
| 16 | Didgori-2 | Ksani | Lisi | 220 | Σ | AC 300/39 | 18.7 | 206 | 188 |
| 17 | Didube-3 | Didube | Lisi | 220 | Σ | AC 300/48 | 8.12 | 206 | 188 |
| 18 | Didube-4 | Didube | Lisi | 220 | Σ | AC 300/48 | 8.12 | 206 | 188 |
| 19 | Lomtagora-1 | Gardabani | Marneuli | 220 | Σ | AC 400/51 | 20.25 | 226 | 212 |
| 20 | Lomtagora-2 | Gardabani | Marneuli | 220 | Σ | AC 400/51 | 20.25 | 226 | 212 |
| 21 | Veli-1 | Rustavi | Gardabani | 220 | Σ | AC 500/64 | 21.5 | 226 | 212 |
| 22 | Veli-2 | Rustavi | Gardabani | 220 | Σ | AC 500/64 | 16.8 | 226 | 212 |
| 23 | Senaki-1 | Menji | Tskaltubo | 220 | Σ | AC 300/39 | 58.7 | 223 | 211 |
| 24 | Senaki-2 | Menji | Tskaltubo | 220 | Σ | AC 300/39 | 58.7 | 223 | 211 |
| 25 | Navtlugi-1 | Gard.Akhali | Gardabani | 220 | Σ | ACO-500 | 3.67 | 274 | 257 |
| 26 | Navtlugi-2 | Navtlugi | Gard.Akhali | 220 | Σ | ACO-480 | 34.2 | 257 | 240 |
| 27 | Manavi | Rustavi | Gurjaani | 220 | 1 | AC 500/64 | 8 | 195 | 185 |
| | | | | | 2 | AC 300/48 | 65.72 | | |
| | | | | | Σ | | 73.72 | | |
| 28 | Algeti | Navtlugi | Khrami-2 HPP | 220 | Σ | AC 400/93 | 65.51 | 233 | 225 |
| 29 | Varketili | Gldani | Rustavi | 220 | Σ | AC 500/64 | 46.8 | 274 | 257 |

TEN-YEAR NETWORK DEVELOPMENT PLAN OF GEORGIA 2018-2028

| | | | | | | | | | |
|----|--------------|--------------|--------------|-----|---|------------|----------------|-----|-----|
| 30 | Kukia | Gldani | Navtlugi | 220 | 1 | AC 400/51 | 16.42 | 223 | 206 |
| | | | | | 2 | AC 500/204 | 1 | | |
| | | | | | Σ | | 17.42 | | |
| 31 | Aragvi | Ksani | Gldani | 220 | 1 | ACO-480 | 28.2 | 223 | 206 |
| | | | | | 2 | AC 400/51 | 5.2 | | |
| | | | | | Σ | | 33.4 | | |
| 32 | Liakhvi | Gori | Ksani | 220 | 1 | AC 400/93 | 51.4 | 205 | 171 |
| | | | | | 2 | AC 480/51 | 4.57 | | |
| | | | | | Σ | | 55.83 | | |
| 33 | Urbnisi | Khashuri | Gori | 220 | 1 | AC 400/93 | 3.564 | 206 | 188 |
| | | | | | 2 | ACO-480 | 39.67 | | |
| | | | | | Σ | | 43.23 | | |
| 34 | Lomisi | Zhinvali HPP | Ksani | 220 | 1 | AC-300/39 | 40.71 | 171 | 171 |
| | | | | | 2 | AC-480 | 0.499 | | |
| | | | | | Σ | | 41.2 | | |
| 35 | Surami | Zestaponi | Khashuri | 220 | 1 | AC 400/93 | 24.6 | 206 | 188 |
| | | | | | 2 | ACO-480 | 42.65 | | |
| | | | | | Σ | | 67.24 | | |
| 36 | Pero-3 | Zestaponi | Pero | 220 | Σ | AC 400/51 | 6 | 137 | 130 |
| 37 | Ajameti-1 | Kutaisi | Zestaponi | 220 | Σ | AC 400/93 | 23.6 | 233 | 225 |
| 38 | Ajameti-2 | Kutaisi | Zestaponi | 220 | Σ | AC 400/93 | 21.6 | 206 | 195 |
| 39 | Ajameti-3 | Kutaisi | Zestaponi | 220 | Σ | AC 400/93 | 21.1 | 233 | 225 |
| 40 | Sataplia-1 | Tskaltubo | Kutaisi | 220 | 1 | AC 400/93 | 13.82 | 137 | 130 |
| | | | | | 2 | ACO-480 | 13.4 | | |
| | | | | | Σ | | 27.2 | | |
| 41 | Sataplia-2 | Tskaltubo | Kutaisi | 220 | Σ | AC 400/93 | 26.2 | 233 | 225 |
| 42 | Derchi | Lajanuri HPP | Tskaltubo | 220 | 1 | ACO-480 | 34.63 | 147 | 143 |
| | | | | | 2 | AC 400/93 | 13.82 | | |
| | | | | | Σ | | 48.5 | | |
| 43 | Kolkhida-1 | Menji | Kutaisi | 220 | Σ | AC 300/66 | 67.2 | 139 | 131 |
| 44 | Kolkhida-2 | Zugdidi | Menji | 220 | 1 | AC 300/66 | 29.7 | 202 | 192 |
| | | | | | 2 | AC 400/64 | 13.9 | | |
| | | | | | Σ | | 43.6 | | |
| 45 | Kolkhida-2a | Vardnili HPP | Zugdidi | 220 | 1 | AC 400/39 | 9 | 151 | 140 |
| | | | | | 2 | AC 300/48 | 13 | | |
| | | | | | Σ | | 22 | | |
| 46 | Egrisi-1 | Enguri HPP | Vardnili HPP | 220 | Σ | AC 500/64 | 11.5 | 226 | 212 |
| 47 | Egrisi-2 | Enguri HPP | Vardnili HPP | 220 | Σ | AC 500/64 | 11.5 | 226 | 212 |
| 48 | Paliastomi-1 | Menji | Batumi | 220 | Σ | AC 400/51 | 97.76 | 185 | 175 |
| 49 | Paliastomi-2 | Khorga | Batumi | 220 | Σ | AC 400/51 | 93.87 | 185 | 175 |
| 50 | Rukhi | Vardnili HPP | Khorga | 220 | Σ | AC 400/51 | 55.21 | 185 | 175 |
| 51 | Kolkhida-3 | Vardnili HPP | Sokhumi | 220 | Σ | AC 300/66 | 31.5 | 245 | 216 |
| 52 | Iveria-1 | Tkvarcheli | Sokhumi | 220 | Σ | AC 400/51 | 61.7 | 297 | 261 |
| 53 | Iveria-2 | Sokhumi | Bzipi | 220 | Σ | AC 400/51 | 78.2 | 297 | 261 |
| 54 | Alaverdi | Gardabani | Alaverdi | 220 | Σ | AC 300/66 | 28.5 [51.9] | 195 | 185 |
| 55 | Adjara | Batumi | Khopa | 220 | Σ | ACK 400/51 | 12.3 [30] | 127 | 112 |
| 56 | Salkhino | Bzipi | Psou | 220 | Σ | ACK 400/51 | 38 [43] | 297 | 261 |
| 57 | Faravani | Faravani HPP | Akhaltsikhe | 220 | Σ | AC 300/39 | 33.6 | 255 | 224 |
| 58 | Khorga-1 | Khorga | Menji | 220 | Σ | AC 400/51 | 12.74 | 212 | 200 |
| 59 | Khorga 2 | Khorga | Menji | 220 | Σ | AC 400/51 | 12.73 | 212 | 200 |

Summarized data:

Total length of 500 kV OHLs: 841 km

Total length of 400 kV OHLs: 32.6 km

Total length of 330 kV OHLs: 21.1 km

Total length of 220 kV OHLs: 1689.2 km

As a result of temperature fluctuation, operational characteristics of OHLs are being changed. Hence, thermal capacity of the overhead lines are given for winter (25°C) and summer (35°C) temperatures, as for different conditions they can be calculated by use of following ratios (K_T):

| T_{amb} | 20 °C | 25 °C | 30 °C | 35 °C | 40 °C | 45 °C | 50 °C |
|-----------|-------|-------|-------|-------|-------|-------|-------|
| K_T | 1.05 | 1.00 | 0.94 | 0.88 | 0.81 | 0.74 | 0.67 |

3.9 Installed Capacities of Autotransformers Installed in 500/400/330/220 kV Substation of Georgian Transmission Network

Table 3.5

| Substation | Voltage (kV) | Capacities of ATs (MVA) | |
|-----------------|--------------|-------------------------|---------|
| Gardabani | 500/220 | 800 | 3x267 |
| Ksani | 500/220 | 500 | 3x167 |
| Zestaponi | 500/200 | 500 | 3x167 |
| Akhaltsikhe | 500/220 | 500 | 3x167 |
| Enguri | 500/220 | 500 | 3x167 |
| Gardabani | 330/220 | 400 | 3x133 |
| Gurjaani | 220/110 | 125 | 1x125 |
| Gardabani | 220/110 | 250 | 2x125 |
| Rustavi | 220/110 | 400 | 2x200 |
| Marneuli | 220/110 | 125 | 1x125 |
| Navtlugi | 220/110 | 250 | 2x125 |
| Gldani | 220/110 | 250 | 2x125 |
| Didube | 220/110 | 250 | 2x125 |
| Lisi | 220/110 | 250 | 2x125 |
| Ksani | 220/110 | 250 | 2x125 |
| Gori | 220/110 | 125 | 1x125 |
| Khashuri | 220/110 | 250 | 2x125 |
| Zestaponi | 220/110 | 400 | 2x200 |
| Pero | 220/110 | 400 | 2x200 |
| Kutaisi | 220/110 | 250 | 2x125 |
| Tskaltubo | 220/110 | 125 | 1x125 |
| Menji | 220/110 | 125 | 2x63 |
| Zugdidi | 220/110 | 125 | 2x63 |
| Batumi | 220/110 | 250 | 2x125 |
| Tkvarcheli | 220/110 | 120 | 3x40 |
| Sokhumi | 220/110 | 250 | 2x125 |
| Bzipi | 220/110 | 125 | 1x125 |
| Vardnili | 220/110 | 200 | 1x200 |
| Khrami-2 | 220/110 | 250 | 2x125 |
| Akhaltsikhe B2B | 500/400 | 875 | 2x437.5 |
| Gardabani | 500/220 | 800 | 3x267 |
| Ksani | 500/220 | 500 | 3x167 |
| Zestaponi | 500/200 | 500 | 3x167 |

Summarized data:

| | |
|---------------|------------------|
| 500/220 kV | 3960 MVA |
| 220/110 kV | 5733 MVA |
| 330/220 kV | 400 MVA |
| 500/400 kV | 875 MVA |
| Total: | 10968 MVA |

4 Inputs for Network Development Planning

According to paragraph 2 of article 3² (Network Development Plan of Georgia) of Georgian law on “Electricity and Natural Gas”:

2) *Georgian Ten Year Network Development Plan should contain:*

- a) *Information about existing and predicted demand supply;*
- b) *Reasonable forecast about generation, supply, load and transmission to other countries.*

According to network rules, article 39, paragraph 6:

transmission network development plan, along with other information should include information about the operational characteristics of the transmission network, which includes:

...

- g) transmission network development, which is based on forecast of consumption growth;*
- h) transmission network development, which is based on plans of construction of new power plants.*
- i) offers about construction of new interconnection lines and substations.*
- j) planned interflows with neighbouring countries.*

The initial information for transmission grid development are following: 1. Load and Generation data, specifically, type of new object, installed capacity, annual output, commissioning date, category; Decommissioning dates of old power plants, load growth scenarios. 2. Approximate prices of new transmission elements. 3. Agreements about construction of trans boundary infrastructure, between Georgia and neighboring countries and Development of surrounding grid. 4. Special requirements for generators and dc links. 5. Assignments about changes to be made in TYNDP, coming from Ministry of energy/Government.

Data about load and generation (4.1 .. 4.4) was received from Ministry of energy by letter #03/3376 dated 13/08/2015.

Information about forecasted prices (4.5) has been defined based on current projects.

Development of surrounding grid of Georgia (4.6) is one the most important factor for TYNDP, which represents technical basis about development of trans boundary infrastructure. This information has been provided by TSOs of neighboring networks and/or was found in internet. As for legal basis, it is based on agreements, memorandums and protocols between governments, TSOs and other companies.

Minimal technical requirements for power plants, generating units and dc links (4.7 and 4.8) has been developed by GSE engineers. This is because GSE, as a transmission system operator, provides real time operation and maintains dynamic stability of the power system, which is mainly implemented by dispatching power plants (active/reactive power increase/decrease, switch on/off of units. Therefore, it is very important new plants, units, dc links not to have worse dynamic parameters and possibilities than is allowed from the system point of view considering dynamic stability.

4.1 Time Span 2017-2031

4.2 Forecasted balance scenarios/growth of consumption

4.2.1 Growth of consumption of country

| Scenario | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 |
|--------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| Pessimistic | 1% | 1% | 1% | 1% | 1% | 1% | 1% | 1% | 1% | 1% | 1% | 1% | 1% | 1% | 1% |
| Normal | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% | 3.5% |
| Optimistic | 5% | 5% | 5% | 5% | 5% | 5% | 5% | 5% | 5% | 5% | 5% | 5% | 5% | 5% | 5% |

4.2.2 Consumed energy, bln. kwh (gross domestic consumption)¹

| Scenario | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 |
|--------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| Pessimistic | 11.36 | 11.48 | 11.59 | 11.71 | 11.82 | 11.94 | 12.06 | 12.18 | 12.30 | 12.43 | 12.55 | 12.68 | 12.80 | 12.93 | 13.06 |
| Normal | 11.64 | 12.05 | 12.47 | 12.91 | 13.36 | 13.83 | 14.31 | 14.81 | 15.33 | 15.87 | 16.42 | 17.00 | 17.59 | 18.21 | 18.85 |
| Optimistic | 11.81 | 12.40 | 13.02 | 13.67 | 14.36 | 15.08 | 15.83 | 16.62 | 17.45 | 18.33 | 19.24 | 20.20 | 21.21 | 22.27 | 23.39 |

¹ population growth in unknown

4.3 Forecasted installed capacity (MW)

| Energy source | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | 2031 |
|----------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| hydro | 3229 | 3374 | 3874 | 4044 | 4438 | 4706 | 4927 | 5717 | 6419 | 6419 | 6419 | 6419 | 6419 | 6419 | 6419 |
| thermal | 925 | 925 | 655 | 1205 | 905 | 905 | 905 | 905 | 905 | 1155 | 1155 | 1155 | 1155 | 1155 | 1155 |
| wind | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 | 21 |
| solar | | | | | * | * | * | * | * | * | * | * | * | * | * |
| biomass | | | | * | * | * | * | * | * | * | * | * | * | * | * |
| Other* | | | | | | | | | | | | | | | |
| sum | 4175 | 4320 | 4550 | 5270 | 5364 | 5632 | 5853 | 6643 | 7345 | 7595 | 7595 | 7595 | 7595 | 7595 | 7595 |

* On studying stage

² Integration of Wind farms with total installed capacity of 100 MW and more is related to: 1) Construction of second 500 kV cross-border line between Georgia and Russia, 2) Construction of Khudoni, Namakvani HPPs and Tskhenistskali cascade HPPs, 3) Rehabilitation of speed governors and excitation systems in existing power plants, 4) Integration into united energy market.

* on studying stage but total capacity coming from Wind and Solar power plants must not exceed 400 MW.

4.4 Generation data

4.4.1 HPPs (According to signed MoUs)

| No | Name | Installed Capacity (MW) | Generation (Gwh) | Type | Commissioning date | Category ³ |
|----|---------------|-------------------------|------------------|--------------|--------------------|-----------------------|
| 1 | Rachkha HPP | 10.3 | 31.5 | Run-of-River | 09.09.2017 | 1 |
| 2 | Jonouli HPP 1 | 1.1 | 5.1 | Run-of-River | 11.09.2017 | 2 |
| 3 | Nabeglavi HPP | 2 | 13 | Run-of-River | 2017 | 1 |
| 4 | Squrididi HPP | 1.3 | 6.8 | Run-of-River | 16.09.2017 | 1 |
| 5 | Shilda HPP 1 | 1.9 | 11.4 | Run-of-River | 15.10.2017 | 1 |
| 6 | Kirnati HPP | 51.3 | 219 | Daily Reg | 31.12.2017 | 1 |
| 7 | Ifari HPP | 3.2 | 14.2 | Run-of-River | 12.01.2018 | 3 |
| 8 | Khelra HPP | 3.1 | 12.1 | Run-of-River | 12.01.2018 | 3 |
| 9 | Avani HPP | 4.6 | 18.6 | Run-of-River | 29.01.2018 | 2 |

| | | | | | | |
|----|----------------------|------|-------|--------------|------------|---|
| 10 | Kasleti HPP 1 | 8.1 | 45.8 | Run-of-River | 01.02.2018 | 2 |
| 11 | Kobi HPP 1 | 60 | 320 | Run-of-River | 20.08.2018 | 3 |
| 12 | Kobi HPP 2 | 41.6 | 191.4 | Run-of-River | 20.08.2018 | 1 |
| 13 | Lukhuni HPP 2 | 12 | 73.6 | Run-of-River | 30.09.2018 | 1 |
| 14 | Goginauri HPP | 1.8 | 9.3 | Run-of-River | 01.10.2018 | 1 |
| 15 | Oqropilauri HPP | 1.8 | 9.4 | Run-of-River | 01.10.2018 | 1 |
| 16 | Kasleti HPP 1 | 8.1 | 46.4 | Run-of-River | 31.12.2018 | 3 |
| 17 | Kheori HPP | 1 | 6.7 | Run-of-River | 31.12.2018 | 3 |
| 18 | Aragvi HPP 2 | 2 | 11 | Run-of-River | 01.01.2019 | 3 |
| 19 | Bochorma HPP | 7.5 | 32.2 | Run-of-River | 01.01.2019 | 3 |
| 20 | Nakra HPP | 13.8 | 73.3 | Run-of-River | 12.01.2019 | 3 |
| 21 | Natanebi HPP 2 | 7.5 | 52.5 | Run-of-River | 23.01.2019 | 3 |
| 22 | Natanebi HPP 3 | 11.5 | 78 | Run-of-River | 08.02.2019 | 3 |
| 23 | Mtkvari HPP | 53 | 230 | Run-of-River | 16.02.2019 | 1 |
| 24 | Mestiachala HPP 2 | 27 | 115 | Run-of-River | 28.02.2019 | 2 |
| 25 | Kheledula HPP 3 | 60.4 | 255 | Seasonal reg | 29.03.2019 | 2 |
| 26 | Stori HPP 1 | 14 | 69.4 | Run-of-River | 13.06.2019 | 2 |
| 27 | Sashuala HPP 1 | 5.1 | 35.5 | Run-of-River | 01.10.2019 | 2 |
| 28 | Sashuala HPP 2 | 5 | 34.3 | Run-of-River | 01.10.2019 | 2 |
| 29 | Samkuristskali HPP | 13.1 | 68.3 | Run-of-River | 2019 | 3 |
| 30 | Chapala HPP | 0.5 | 3 | Irrigation | 2019 | 3 |
| 31 | Nenskra HPP | 280 | 1200 | Seasonal reg | 2019 | 1 |
| 32 | Khokhnistskali HPP 3 | 3.1 | 18 | Run-of-River | 01.01.2020 | 3 |
| 33 | Vedi HPP | 19.4 | 96.8 | Run-of-River | 01.01.2020 | 3 |
| 34 | Tsirmindi HPP | 13.4 | 65.8 | Run-of-River | 01.01.2020 | 3 |
| 35 | Zekari HPP | 1.6 | 8.2 | Run-of-River | 01.01.2020 | 3 |
| 36 | Mleta HPP | 5.5 | 36.2 | Daily Reg | 01.01.2020 | 3 |
| 37 | Qvesheti HPP | 10.1 | 67.4 | Daily Reg | 01.01.2020 | 3 |
| 38 | Narovani HPP | 4.1 | 18.6 | Run-of-River | 01.01.2020 | 3 |
| 39 | Qvedi HPP | 1.7 | 9.9 | Run-of-River | 01.01.2020 | 3 |
| 40 | Tsablari HPP 2 | 14.6 | 63.2 | Run-of-River | 01.01.2020 | 3 |
| 41 | Baramidze HPP | 8.4 | 42 | Run-of-River | 31.01.2020 | 2 |
| 42 | Buja HPP 1 | 1.6 | 8.7 | Run-of-River | 31.01.2020 | 3 |
| 43 | Buja HPP 2 | 1 | 5.2 | Run-of-River | 31.01.2020 | 3 |
| 44 | Buja HPP 3 | 2.3 | 12.3 | Run-of-River | 31.01.2020 | 3 |
| 45 | Lajanuri HPP 1 | 4.3 | 23.6 | Run-of-River | 22.03.2020 | 3 |
| 46 | Lajanuri HPP 2 | 5.8 | 31.2 | Run-of-River | 22.03.2020 | 3 |
| 47 | Lajanuri HPP 3 | 4.3 | 23.6 | Run-of-River | 22.03.2020 | 3 |
| 48 | Lakhami HPP | 8.8 | 50 | Run-of-River | 17.04.2020 | 2 |
| 49 | Darchi HPP | 16.9 | 93.6 | Run-of-River | 31.12.2020 | 3 |
| 50 | Ubisa HPP | 7.6 | 35 | Run-of-River | 2020 | 3 |
| 51 | Artana HPP | 2.5 | 13.5 | Run-of-River | 2020 | 3 |
| 52 | Lopota HPP 1 | 8 | 46 | Run-of-River | 2020 | 3 |
| 53 | Paldo HPP | 6.8 | 48.9 | Run-of-River | 2020 | 3 |
| 54 | Khadori HPP 3 | 5.4 | 38.8 | Run-of-River | 2020 | 3 |
| 55 | Samkuristskali HPP 2 | 13.1 | 68.3 | Run-of-River | 30.11.2020 | 3 |
| 56 | Akavreta HPP | 19 | 82 | Run-of-River | 01.01.2021 | 3 |
| 57 | Metekhi HPP 1 | 23.8 | 131 | Daily Reg | 01.01.2021 | 3 |
| 58 | Metekhi HPP 2 | 21.2 | 116 | Daily Reg | 01.01.2021 | 3 |
| 59 | Kvirila HPP | 6.6 | 40 | Run-of-River | 01.01.2021 | 3 |
| 60 | Khokhnistskali HPP 1 | 1.3 | 7.9 | Run-of-River | 01.01.2021 | 3 |
| 61 | Khokhnistskali HPP 2 | 1.3 | 7.5 | Run-of-River | 01.01.2021 | 3 |
| 62 | Machakhela HPP 1 | 23 | 127 | Run-of-River | 01.01.2021 | 3 |
| 63 | Machakhela HPP | 19 | 115 | Daily Reg | 01.01.2021 | 3 |
| 64 | Udzilaurta HPP | 7.7 | 38.3 | Daily Reg | 01.01.2021 | 3 |
| 65 | Barisakho HPP | 15.3 | 77 | Seasonal reg | 01.01.2021 | 3 |
| 66 | Laskadura HPP | 6.6 | 33 | Run-of-River | 01.01.2021 | 3 |

TEN-YEAR NETWORK DEVELOPMENT PLAN OF GEORGIA 2018-2028

| | | | | | | |
|--------------|------------------------|-------------|--------------|--------------|----------------|---|
| 67 | Dolra HPP 3 | 30 | 124 | Run-of-River | 11.02.2021 | 3 |
| 68 | Koromkheti HPP | 150 | 463 | Run-of-River | 28.10.2021 | 2 |
| 69 | Magana and Iqarde HPPs | 40.6 | 213.4 | Run-of-River | 11.12.2021 | 2 |
| 70 | Mestiachala HPP 1 | 23.7 | 103.5 | Run-of-River | 25.12.2021 | 2 |
| 71 | Samkuristskali HPP 1 | 4.8 | 24 | Run-of-River | 2021 | 3 |
| 72 | Majieti HPP | 12.3 | 56.4 | Daily Reg | 01.01.2022 | 3 |
| 73 | Gebi HPP | 14 | 72.8 | Daily Reg | 01.01.2022 | 3 |
| 74 | Gere HPP | 8.3 | 44.7 | Run-of-River | 01.01.2022 | 3 |
| 75 | Chiora HPP | 14.9 | 68.8 | Run-of-River | 01.01.2022 | 3 |
| 76 | Sakaura HPP | 12 | 56.7 | Run-of-River | 01.01.2022 | 3 |
| 77 | akhdabaha HPP | 93 | 494 | Run-of-River | 01.01.2022 | 3 |
| 78 | Zoti HPP | 48 | 225.1 | Run-of-River | 25.04.2022 | 2 |
| 79 | Khertvisi HPP | 65 | 239 | Run-of-River | 28.10.2022 | 3 |
| 80 | Tskhvandiri HPP | 9.8 | 44.1 | Run-of-River | 01.01.2023 | 3 |
| 81 | Okrili HPP | 7 | 30.5 | Run-of-River | 01.01.2023 | 3 |
| 82 | Surebi HPP | 6.9 | 40.8 | Run-of-River | 01.01.2023 | 3 |
| 83 | Vani HPP | 7.6 | 44.5 | Run-of-River | 01.01.2023 | 3 |
| 84 | Bukistsikhe HPP | 7.4 | 40.7 | Run-of-River | 01.01.2023 | 3 |
| 85 | Sufsa small HPP | 1.1 | 6.3 | Run-of-River | 01.01.2023 | 3 |
| 86 | Larsi HPP 2 | 4.2 | 21.8 | Run-of-River | 15.11.2023 | 3 |
| 87 | Oni cascade | 177.2 | 789 | Run-of-River | 16.10.2023 | 3 |
| 88 | Tskhenistskali cascade | 357.1 | 1576.9 | Seasonal reg | 12.02.2024 | 3 |
| 89 | Namakhvani cascade | 433 | 1500 | Seasonal reg | 2024 | 2 |
| 90 | Khudoni HPP | 702 | 1500 | Seasonal reg | 2025 | 2 |
| 91 | ENGURI 7 HPP | 173.6 | 831.7 | Run-of-River | Studying stage | 3 |
| 92 | ENGURI 8 HPP | 173.6 | 821.7 | Run-of-River | Studying stage | 3 |
| 93 | ENGURI 6 HPP | 150.3 | 734 | Run-of-River | Studying stage | 3 |
| 94 | ENGURI 5 HPP | 50.6 | 255.2 | Seasonal reg | Studying stage | 3 |
| 95 | ANDEZITI HPP | 129.2 | 291.6 | | Studying stage | 3 |
| 96 | KHRAMI 3 HPP | 1.1 | 4.3 | | Studying stage | 3 |
| 97 | KHRAMI 4 HPP | 16.1 | 112.4 | | Studying stage | 3 |
| 98 | KHRAMI 5 HPP | 15 | 102 | | Studying stage | 3 |
| TOTAL | | 3814 | 15222 | | | |

4.4.2 TPPs

| No | NAME | Instaled capacity (MW) | Efficiency (%) | Type | Commissioning date | Category ³ |
|----|-----------|------------------------|----------------|------|--------------------|-----------------------|
| 1 | 1-Thermal | 250 | 55 | CCGT | 01.01.2020 | 3 |
| 2 | 2-Thermal | 250 | 55 | CCGT | 01.01.2026 | 3 |
| 3 | 3-Thermal | 150 | 40 | Coal | 01.01.2020 | 3 |

³ Feasibility and environmental impact study has been done. Negotiations about tariffs are being held.

4.4.3 Solar⁴, wind⁵, geothermal⁶ or other⁷ renewables

| No | NAME | Type | Commissioning date | Category * |
|----|---|------|--------------------|------------|
| 1 | Chorokhi, Poti, Kutaisi, Mountain Sabueti 1+2, Gori, Kaspi, Samgori, Rustavi, Paravani, Akhalkalaki | Wind | Unknown | 3 |
| 2 | Imereti | Wind | Studying stage | 3 |
| 3 | Rikoti | Wind | Studying stage | 3 |

| | | | | |
|----|----------------------|--------|----------------|---|
| 4 | Power plants of Pona | Wind | Studying stage | 3 |
| 5 | Central power plants | Wind | Studying stage | 3 |
| 6 | Nigoza | Wind | Studying stage | 3 |
| 7 | Kartli 2 | Wind | Studying stage | 3 |
| 8 | Gardabani | Solar | Studying stage | 3 |
| 9 | Desert power plants | Solar | Studying stage | 3 |
| 10 | Gardabani | Biogas | Studying stage | 3 |

Category 1 - projects at construction stage

Category 2 - projects at license stage

Category 3 – Projects at feasibility study stage

4,5,6,7 - 400 MW is the total capacity coming from Wind power plants that can be integrated into the Georgian transmission network for 2025. In addition, it's not allowed to integrate more than 45 MW renewables in total in each of wind regions. Working on permissible amounts of power coming from Solar power plants is in progress (Chapter 18).

4.4.4 Power plants to be decommissioned

| № | Name | Instaled capacity (MW) | Type | Decommissioning date |
|---|-----------------|------------------------|----------|----------------------|
| 1 | Thermal Unit №3 | 130.0 | Steam PP | 01.01.2019 |
| 2 | Thermal Unit №4 | 140.0 | Steam PP | 01.01.2019 |
| 3 | Thermal Unit №9 | 300.0 | Steam PP | 01.01.2021 |

4.5 Forecasted prices of transmission system elements

| | |
|--|---|
| 1 km sin-circuit 110 kv. ohl – 0.136 mln euros ¹ 1 km doub-circuit 110 kv. ohl – 0.210 mln euros 1 km sin-circuit 220 kv. ohl – 0.210 mln euros 1 km sin-circuit 220 kv. ohl - 0.310 mln euros 1 km sin-circuit 400 kv. ohl – 0.372 mln euros 1 km doub-circuit 400 kv. ohl – 0.558 mln euros 1 km sin-circuit 500 kv. ohl – 0.372 mln euros 1 km doub-circuit 500 kv. ohl – 0.620 mln euros 350 MW Converter - 60 mln euros ² Extension of converter SS – 31-37 mln euros ² | 500 MVA 500/220 kv SS - 25 mln euros ² 500/220 or 500/110 kv SS – 17 mln euros 250 MVA 220/110 kv SS - 14 mln euros 125 MVA 110/35 kv SS - 8 mln euros Consulting services 5% (of construction cost) Land redemption 10% Environmental work 5% Unforeseen expenses 5% |
|--|---|

1 – **Cost of OHL**, may be changed in $\pm 25\%$ range according to the route relief.

2 – **Cost of construction/extension of substation / HVDC back-to-back link**, may be changed in $\pm 20\%$ range according to the route relief.

Costs are including VAT.

4.6 Agreements with neighboring TSOs and their TYNDPs

According to the paragraph 2 of article 29 of grid code, dispatch licensee provides information exchange with neighboring TSOs.

Information about development of bordering networks is one of the important input for TYNDP. Information about trans boundary given in this document is based on different agreement between countries and they may be shown in the relevant TYNDP (if it exists).

Georgia has trans-boundary infrastructure with all four countries. Possibility of power transfer to Azerbaijan exceeds 1000 MW. Reinforcement and increasing of reliability is planned in directions to Turkey, Armenia and Russia.

4.6.1 To Turkey

Drivers. Main drivers for Projects to Turkey are the increase of export capabilities in Georgia due to construction of new HPPs and electricity Transmit from neighboring countries. Also intense increase in Consumption of electricity of Turkey. Besides, it is planned to build new transmission lines from Tortum's neighboring areas to rest of Turkey.

Basis.

Agreements. According to the agreement about reinforcement of trans boundary infrastructure between ministries of energy of Georgia and Turkey, signed in september 29, 2010 between these two countries was reached an agreement about construction of OHL Batumi – Muratli and technical study of Akhlatsikhe–Tortum project. According the mentioned Mou the grouping of the technical team is being processed. In September 7, 2015, at the meeting between TEIAS and GSE, in Ankara, parties agreed that at the end of 2016 will be signed agreement about construction of 400 kV Akhlatsikhe–Tortum OHL, construction of which will be completed for the end of 2019 or 2020.

Development of neighboring network. During 2015-2017, transit grid of Turkey bordering of Georgia will be developed in the directions of Borchka as well as Tortum, Keban and other its neighbor bulk power consumption centers (fig. 4.1). In particular:

400 kV ohl Bagistash-Keban was constructed in 2016.

400 kV ohl Ispir-Arkun was constructed in 2016.

Here are completion dates for planned projects of transmission network reinforcement in Turkey which are bordering Georgian system for near future:

400 kV ohls Borchka-Ispir-Erzurum - till the end of 2016;

400 kVohl Ispir-Bagistash - till the end of 2016;

400 kV ohl Ordu-Resadie - till the end of 2016;

400 kV ohl Ispir-Koze-Resadie – till the end of 2018;

400 kV ohl Kalkandere-Koze – till end of 2019;

400 kV ohl Resadie-Iozgat-Ich Anadolu power plant (Ankara) – end of 2020;

400 kV ohl Erzurum-Alpaslan HPP-Kalekoi HPP – end of 2020.

400 kV ohl Koze-Decheko-Iozgat-Ich Anadolu power plant (Ankara)– end of 2021.




Diagram 4.1 Power system enhancement projects in Turkey

Also, will be enhanced the ability of capacity transit from the black sea directions, which provides reliable transfer of electricity to huge consumption centers located in west part of Turkey. Therefore, since 2019-2020 years, 1400 MW power transfer from Georgian power system to Turkish consumption centers most likely will be possible in a safe and reliable manner. Based on the above, starting from 2020. 1400 MW power export from Georgia to Turkey is considered.

4.6.2 To Armenia

Drivers. Main drivers to that direction are: increasing of reliability of Georgian and Armenian power systems and digestion of electricity trade potential between Russia-Armenia-Iran trough Georgia.

Basis

Agreements. According the agreement about construction of interconnection line between Armenia and Georgia signed on 26 January 2010, and changes in this agreement made on 6 July 2011 and 16 April 2014 between GSE, Armenian high voltage grid operator and Armenian power system operator, Georgia will construct the part of that 500 kv line till border, Armenia – the rest part of this line from border to Airum and 700 MW DC B2B station in Airum. Construction of these elements will be completed for 2018.

Development of neighboring network. In 2018-2019 it is planned important reinforcement of Armenian network constructing following elements: 500kv ohl from Georgian border to Airum, 500/400 kv 350 MW DC back to back station in Airum (with probability of adding additional 350MW block in 2021), SS Noravan, SS Damashen, Gas turbine station and 400 kv SS Hiusisian, 400 kv ohl Airum-Damashen, 400 kv ohl Damashen-Hiusinian, 400 kv ohl Damashen-Noravan, double-circuit 400 kv Noravan-Iran (Diagram 4.2)




Fig. 4.2 Power system enhancement projects in Armenia

4.6.3 To Russia

Drivers. Main drivers to that direction are: increasing of reliability of Georgian and Russian power systems and digestion of electricity trade potential between Russia-Armenia-Iran through Georgia and improvement of stability of north Caucasus and east Georgian system.

Basis

Agreements.

At the meetings between GSE and Russian system operator held in 2013 has been launched and in 2015 march 31, proceeding of technical feasibility study of 500 kv ohl Ksani-Stephantsminda-Mozdok has been agreed.

Development of surrounding grid of Georgia. According to 2013-2019 years development plan of Russian power system (fig. 4.3), in surrounding grid of Georgia implement the following projects are planned: 330 kv substation "Ilenko" and tie line from this SS to 330 kv ohl "Cherkesk-Baskan" till 2017. 330 kv ohl "Nalchik-Sverokavkaskaia", 500 kv ohl "Stavropolskaia-Nevinominsk", 500 kv substation "Mozdok" and 500 kv ohl "Nevinominsk-Mozdok". Till 2020, 500 kv substations "Chernomorskaia" and "Novosvobdnaia", 500 kv ohl "Chernomorskaia-Novosvobodnaia" and 500 kv ohl "Novosvobodnaia-Nevonominsk" will be constructed, also, 500 kv ohl "Kavkasioni" (Enguri-Centralnaia) will be cut into substation "Novosvobnaia", which will reduce the length of "Kavkasioni" by 100 km and thus improve its reliability. Also substations "Sunja", "Alagir" will be constructed along with HPP "Zaramag" in which ohl "Nalchik-Severokavkasia" will be entered.




Fig 4.3 Reinforcement projects of part of Russian power system neighboring of Georgia

Thus, till 2020 north Caucasus network is significantly developed and in case of connection of 500 kv ohl “Stepantsminda-Mozdok” to it, on one hand the stability of that grid will be improved (will be reserved through Georgian transmission network) and on the other hand this network will backup Georgian network.

4.6.4 To Azerbaijan

There is already strong enough cross border infrastructure between Georgia and Azerbaijan (500 kV OHL Gardabani-Samukh). However, this line has not been in operation yet, in presense, testing works and analysis of necessity of reactor installation in SS Samukh are in progress. After full readiness of above mentioned OHL, transit potential between Georgia and Azerbaijan will be increased up to 1000 MW. In addition, Azerbaijan side is considering to construct second circuit of 330 kV OHL “Gardabani” (Gardabani-Agstafa) which will increase power exchange capabilities between Georgia and Azerbaijan up to 1000 MW in N-1 mode.

4.6.5 Project “North-South” AGIR (Armenia-Georgia-Iran-Russia)

As a result of meeting held in Batumi city (Georgia) on 16 September 2016, agreement among Armenia, Georgia, islamic republic of Iran and Russia about analysis of reasonableness of infrastructure connecting power systems of above mentioned countries has been signed. Countries were presented by the following companies – JSC “Georgian state electrosystem” (Georgia); “Power system operator” and “High voltage grids” (Armenia); “Company of management of power generation, transmission and distribution of Iran” [TAVANIR] and “Management company of network of Iran” [IGMC] (Iran); “SO UPS” [System operator], “Rosseti” [Network company] and “Inter RAO” [Energy trade company] (Russia).

This project is very important for electricity trading between two large power systems like Russia and Iran which will use corridors of Georgian and Armenian power systems in order to realize above mentioned task. United systems of Georgia-Russia and Armenia-Iran will be connected to each other asynchronously – by planned 500/400 kV HVDC back-to-back station in “Airum” SS (Armenia).

The most important element of above mentioned project is perspective 500 kV cross-border OHL Stepantsminda-Mozdok. It has been mentioned by parties that all rest highway ensuring realization of Project “North-South” are completed or on construction stage.

- In Georgia:
 - Constructed
 - New 500/220 kV SS „Marneuli“
 - Rehabilitated 500/220 kV SS „Ksani“
 - 500 kV OHL „Asureti“ (Ksani-Marneuli) connected with SS „Marneuli“
 - On construction stage
 - 500 kV OHL „Sno“ (Ksani-Dariali HPP [Stepantsminda])
- Georgia-Armenia section
 - Working
 - 220 kV OHL „Alaverdi“ (Gardabani-Alaverdi)
 - On construction stage
 - 500 kV OHL „Debeda“ (Marneuli-Airumi)
- In Armenia
 - On construction stage
 - 500/400 kV B2B SS „Airumi“
 - 400 kV OHL „Marneuli“-„Ddmasheni“
 - 400 kV OHL doub-circuit OHL „Ddmasheni“-„Noravani“
- In Armenia-Iran section
 - Working
 - 220 kV OHL Cottage-Ahari
 - 220 kV OHL Cottage-Sunguni
 - On construction stage
 - 400 kV OHL Norovani-Jilpa (Completed territory of Iran)
 - 400 kV OHL Norovani-Herisi (Completed territory of Iran)
- In Russia
 - On construction stage
 - 500 kV OHL Nevinomisski-Mozdok
- In Georgia-Russia section
 - Working
 - 500 kV OHL „Kavkasioni“ (Enguri-Tsentralnaya)
 - Be considered
 - 500 kV OHL „Gergeti“ (**Stepantsminda-Mozdok**) – main part of the project
AGIR is reasonableness analysis of this line construction.




Fig. 4.4 Basic elements of AGIR project

4.7 The minimum technical requirements for power stations and generators.

Transmission network provides power delivery from generations to users. Sustaining high quality of Electricity transmission network provides the transport energy from the sources to consumers. And even electricity transmission network itself is reliable, parameters required to ensure the quality of electricity and is carried out in by the sources - power plants and the relevant units / blocks. The NCC of transmission system operator JSC "Georgian State Electric System" national control center in real time compensates the change of power balance caused by consumption through a change of generation. Therefore, in order to ensure acceptable quality of supply of electricity, maintaining the reliability of the power system, its operational parameters, the power sources must to meet the minimum technical requirements. The requirements in the following regulations

1. Network Code (Approved by the GNERC, 17.04.2015)
2. Technical Operational Rules of Power Plants and Networks. (N 434 Resolution of Government, 31.12.2013)
3. Concept of System Services (GSE, 01.07.2015)

It must be noted that the units of power plants have to satisfy the requirements for system services, such are primary, secondary and tertiary reserves, voltage control, black start (except the situation when there is different clarification in their projects and this is agreed with transmission system operator (dispatch licensee) – JSC "Georgia State Electrosystem".

In addition especial capabilities, particular capability of compensation must implemented on the power plants which will be connected with 500 kV and 220 kV nodes, remote from consumption centers, particularly HPPs of Racha and Svaneti regions.

In addition, GSE is intensively working with European power energy community, with the support of Ministry of Energy and Energy and Water Supply Regulatory Commission, to adopt Entso-e network codes (European united power transmission system operator). RfGs are elaborated and ready for discussion, as well as consumer requirements and HVDC codes. After these codes are adopted,

minimal technical requirements for these equipment will become more flexible, simple and understandable, that will provide system reliability and efficiency.

4.8 Special requirements for Back to Back stations

4.8.1 Adding of third 350MW HVDC back-to-back unit in Akhalstikhe SS is planned for 2021 which will have to meet the same requirements existing for already installed ones.

4.8.2 As for HVDC back-to-back stations in Batumi and Airum (Armenia) substations, they should be charged with following requirements:

1. **Type.** “HVDC light”
2. **Reactive power support, voltage control.** B2Bs should have possibilities to control reactive power in full permissible range according to pattern required from dispatchers. This means that despite the direction of active power flow, back-to-back units must vary reactive power by its amount and direction according to the requirements of specific regime in order to achieve desired voltage level.
3. **Black start.** In case of blackout in one of the system, back to back station should provide voltage for system black start according to the dispatcher requirement.
4. **Frequency control.** Based on preliminary agreement HVDC units should have readiness to activate control function of active power by frequency or frequency derivative in any time.
5. **Participation in RAS system.** Back to backs should be able to receive or transmit signals necessary for Ras or other system protection systems.

4.9 The changes made into the projects according to instruction made by Ministry of Energy and The MoUs signed between the Government of Georgia and Power plants

1. For the purpose of integration of Svaneti's new 560 MW HPP cascade (Dizi-250 MW, Kvanchianari-230 MW, Ieli-80 MW) into the network (presumably in 2029), double-circuit 110 kV OHL Nenskra-Mestia will be constructed within 220 kV range.
2. Based on the Decree N 1557 dated July 24, 2017 of the Government of Georgia on Additional Measures for Supply of Electricity to the City of Tbilisi“, GSE was tasked to a) plan and construct new 220/110 kV substation in Teleti, b) integrate this substation to 220/110 kV network and c) tie-line 220 kV OHL “Algeta” to it.

4.10 Information for the request of the postponement of existent projects by transmission licensees

As an annex for letter N 5466/09 dated 08/12/2015, technical condition with the requirements presented in 4.8.2 paragraph for Energo-Pro Georgia's prospective HVDC back-to-back station to be connected to 220 kV SS Batumi has been issued by JSC GSE.

Respective to the request received by letter N 2216960 dated 02/08/2016 from Energo-Pro Georgia, GSE agreed on postponement of construction of above mentioned HVDC station and respective 154 kV OHL Batumi-Muratli till 31 December 2020 with the condition of fulfilling above mentioned requirements.

5 Drivers of Georgian Transmission System Development

Development of the transmission network is influenced by various factors that are specific to individual electric power systems. For Georgia, these are: Network Security, connection of new power plants and consumers, usage of transit potential etc which are underpinned with Georgian legislation. Currently Georgian electric power system is in transition – transformation of transmission network developed for operation with big power system in order to create reliable transmission network ready for presence and future challenges; Replace of aged Soviet Union equipment with modern one of European standards.




Fig. 5.1 Map illustrating development drivers of Georgian electric power network

Some of the foregoing development drivers are reviewed in detail in the following sections.

5.1 Primary Development Drivers of Georgian Transmission Network

Georgian Legislation According to 3² article (Ten-Year Network Development Plan of Georgia) of Georgian Law about "Electricity and Natural Gas": The purpose of working out the Ten-year Transmission Network of Georgia Development Plan shall be the reliability, safety, and sustainable development of the transition network, provision of electricity of adequate quality, and raising the

transit capacity of the electricity network of the country. *According to Article 33 of Georgian Grid Code* The Dispatch Licensee is obliged to conduct necessary studies for transmission network planning periodically or upon necessity for providing economical, safe, reliable and stable functioning.

So development drivers, given below, are implications of Georgian Legislation.

Improvement of security of supply/system reliability. According to the grid code article 30, paragraph 2, *for estimation of network reliability two criteria : a) adequacy – ability of the system to uninterruptedly meet the demand for electricity, in both planned outages and emergency cases. b) stability – ability of the system to withstand disturbances such as short circuit or unexpected outages of system elements.*

During power transfer from generation facilities to the loads, the loss of any single line may cause load shedding or even full blackout. From such lines the major one is 500 kV OHL Imereti connecting Enguri HPP to the load centres located east of Zestaponi, and at Akhaltsikhe substation providing power export to Turkey. The Emergency Control System (ECS) provides certain reliability level, however its activation causes short-term disconnection of the customers and, in addition, even ECS can not provide 100% guarantee of network survival. Therefore, for ensuring required reliability level, it is necessary to design the system in conformity with single contingency (N-1) condition, such as when any single line is lost, other lines should be capable to undertake the load without disconnecting the customers, subject to maintaining power quality within prescribed limits.

Transmission of the existing generation. Under certain operating regimes, topology of the transmission system may limit transportation of the existing generation to the load centres. The major power supply source of Georgia is Enguri HPP, which during summer months covers more than a half of total country consumption, as well as participates in electricity export to Turkey. Despite construction of SS “Jvari”, SS “Khorga” and double-circuit 220 kV OHL “Khorga-Menji”, during summer excessive water period, the only 500 kV OHL “Imereti” from Enguri HPP into the Georgian network as well as 220 kV route “Enguri HPP – Vardnili HPP – Zugdidi – Menji” still restricts power transit from Russian Federation and from Enguri-Vardnili nod towards eastern Georgia, Turkey and Armenia.

Reclamation of the new energy resources. No transmission network of any country, despite its scale, can guarantee integration and reliable transfer of the new generation without appropriate pre-arrangements. Georgia is among the richest countries around the globe by its hydropower resources. Hydro power plants generate the cheapest and ecologically clean electric power. Meanwhile, demand on electric power steadily grows as in Georgia, so in Turkey and European countries interconnected with Turkish power system.

The major power potential of Georgia is associated with water (hydro), wind, solar and geothermal energy resources. Also, Georgia has some fossil deposits (natural gas, oil, peat, coal), however they are available in insufficient quantities to allow economical use. Assuming instability of wind and solar radiation patterns, solar and wind energy, despite consistent development and cost reduction of relevant technologies, call for availability of the additional reserve capacities in the power system, and hence, in general, provoke negative effects in terms of system stability. Georgian power system is small scale, with radial topology of its western part and only 500 kV synchronous link with Russia provided by OHL Kavkasioni. Therefore, for the sake of stability and reliability, bulk integration of wind and solar power facilities into Georgian network prior to 2021 is unreasonable. Meantime, the opposite is true regarding hydropower potential.

The hydropower resources have the largest share in the entire Georgian natural wealth. There are 26,060 rivers with aggregated length of about 60,000 km recorded on the territory of Georgia. The total volume of Georgia’s fresh waters stored in glaciers, lakes and man-made reservoirs amounts to 96.5 km³. The major hydropower potential is concentrated in 300 rivers with total feasible power potential of 15,000 MW that is equivalent to average annual generation of 50 billion kWh.

The hydro power plants are characterized by high flexibility allowing adjustment of their outputs in line with load changes, and even several start-ups and shutdowns during a day. Such type power plants are distinguished by high stability and reliability ensuring the same of the entire power system. Besides these, hydropower still provides the cheapest technological opportunity for electricity production. All above makes reclamation of hydropower resources the major direction in course of developing Georgian electric power system.

Therefore, integration of hydro power plants into the network is the essential driver for development of Georgian transmission grid.

Dully considering such importance, the following 10-15 years will be devoted to construction of the new hydro power plants, mostly in the West Georgia, and evacuation of their output will require considerable enforcement of the transmission system from the west to the east, towards the major load centres and cross-border lines.

Increasing network transit potential. Shortage or surplus of domestic power in the interconnected national systems, as well as considerable differences in electricity prices may necessitate bulk cross-border electricity trade. This is particularly true about Georgian power system characterized by clearly distinguished seasonality, expressed as power excess and shortage during flood and low water periods respectively. Therefore, assuming integration of significant hydropower capacity into the network during the next ten years, increasing the power exchange capabilities with neighbouring states via new cross-border line obviously comes to agenda. In addition, due to its geographical position, Georgia may provide the transit route for power trade among its neighbouring countries, which do not border each other. At present, such trade between Russia and Iran is limited by transmission capacity of 220 kV OHL Alavardi interconnecting Georgian and Armenian transmission systems. In similar, energy transits between Russia and Turkey are limited by transmission capacity of OHL Kavkasioni. Meanwhile, considering growing demand on electricity in Turkey, its market should be attractive not only for Georgia, but also for other countries having links with Georgian power system, provided that sufficient power transfer capabilities from Caucasian states to Turkey are available. Therefore, this Ten-Year Plan assumes construction of 500 kV SS Stepantsminda which will be connected with Russian power system by 500 kV OHL. 350 MW HVDC back-to-back link near 220 kV SS Batumi, additional (third) 350 MW HVDC back-to-back link will be installed at SS Akhaltsikhe and 400 kV OHL Akhaltsikhe-Tortum will be constructed leading to increase net transfer capacity between Georgia and Turkey by 700 MW. 500 kV OHL Marneuli-Alaverdi will be constructed and connected to the 700 MW HVDC back-to-back link in SS Airum (Armenia). For 2022, Georgia's total cross-border power transfer capacities with Turkey will be 1400 MW, 1000-1200 MW with Azerbaijan, 700 MW with Armenia and 1400 MW with Russia. This will allow both evacuation of the bulk power from Georgia, and increase of electricity trade volumes among its neighbouring states through Georgia's territory.

Construction of the reliable power supply centres for supporting potential developments in production and tourist industries. Generally, development of the national economy entails creation of the bulk power supply centres responding to the demands of factories, ports, tourist centres and construction of the new cities. In this course, development of Georgian transmission network will serve as one of the supporting factors to development of production industry. This assumes construction of the powerful 500/220 kV and 220/110 kV substations planned for power supply of the specific bulk load centres developed around certain large cities such as **500/220 kV SS Tskaltubo**, **500/220 kV SS Jvari** and **500/220 kV SS Khudoni** as well as **500/220 kV SS Marneuli** serving as alternative to SS Gardabani for interconnection of the new large production facilities, possibly including chemical or metallurgical plants, or refinery, **220/110 kV Khorga** supplying power to the existing and future ports in Poti and

Anaklia respectively, and supporting to development of the new production facilities in this cities, **220/110 kV SS Ozurgeti** facilitating realization of the regional agricultural potential including processing of tea, citrus, hazelnut, etc., and **500/110 kV SS Stepantsminda** backing development of the tourist infrastructure in Stepantsminda region.

Replacement of the aged thermal units with flexible and cost-effective combined cycle thermal power plants. In Georgian power system, the base load power is generated by thermal power units Nos. 3, 4 and 9 installed in Gardabani Thermal Power Plant (TBILSRESI). These units are overaged both physically and morally, and their efficiency does not exceed 30%. Neither of these units participates in system frequency regulation. Moreover, units nos. 3 and 4 are also not involved in system voltage control. Therefore, for the nearest futures, it has been envisaged to replace all these units by the new combined cycle thermal power plants, with efficiencies around 55% (i.e. the new plants will generate 90% more energy from the same fuel), and capable to participate in both frequency and voltage regulation. The new plants will also serve as secondary and tertiary operating control reserves. However, even the reserve capacity supplied by them may currently be received at their interconnection points (mainly at SS Gardabani), undertaking of such function still requires modification of the transmission network (adding 500 kV or 220 kV bay in SS Gardabani and/or tying any 500 kV or 220 kV lines outgoing from this substation into the prospective plants, for example, cut of 220 kV ohl “Navtlugi” into 230 MW Gardabani CCGT).

Responding to the growing demand on electricity. The changes in electricity consumption depend on dynamics of the national economical parameters. During preparation of this plan, 1.0%, 3.5%, and 5% growth rates were applied during simulation for internal power demand in Georgia, and 8-10 % for demand in Turkey. Generally, any increase in demand shall be compensated by growth of generation or import (the latter conventionally considered as a generation source). Both cases entail increase of power flows from generation to customer, and hence new substations and transmission lines shall be added to the network to allow continuous reliable and stable operation of entire power system.

Improvement of power quality. Provision of sufficient operating reserves will allow to address the problem related with frequency that is one of the power quality parameters.

As regards to the second power quality parameter – voltage, it shall be regulated by automatic regulators installed on the generators and tap changers of transformers and autotransformers that are approximately in the similar state as the speed governors, i.e. their one part is inoperable and other damaged. Therefore, the following is necessary for dealing with voltage instability problems:

- Rehabilitation of the voltage regulators installed in the existing power plants;
- Obligation of all power plants to participate in voltage regulation;
- Periodic testing/checking of voltage regulators at each power plant;
- Installation/upgrading of automatic tap changers of power transformers and autotransformers installed in the substations.

Flexibility of the power system was significantly improved during recent years, mainly due to projects implemented in Georgian State Electrosystem, which are still ongoing, specifically:

- Installation of the generators’ grouped regulation system in the national dispatch centre and gradual (staged) integration of the regulated plants into the network;

- Improvement of Emergency Control System, which allows to maintain system stability during loss of any critical OHLs or autotransformers;
- Automation of the substations allowing their full remote control from dispatch centre;
- Rehabilitation of OLTC (on-load tap changer) of transformers;
- Installation of regulating reactors;
- The need for the automatic phase-shifting transformers is under study, and if found necessary such equipment may be installed:
 - between 500 kV parallel OHLs connecting Georgian and Russian power systems for regulating power flows, specifically between OHL Kavkasioni and OHL Stepantsminda (Stepantsminda-Mozdok), from SS Ksani or SS Stepantsminda;
 - In SS Batumi, for regulating power flows between 220 kV mains Tskaltubo-Kutaisi-Zestaponi and Batumi-Akhaltzikhe.

6 Strategy, Scenarios and Methodology for Planning Ten-Year Development of Georgian Transmission Network

6.1 Development Strategy

Electric power sector is an important part of economy with high influence on social status of Georgian people, and as such, development of the power infrastructure is among the most important national tasks.

The emerged cross-border electricity trade opportunities, high electricity demand growth and need for evacuation of the energy generated by the planned power plants, call for investments in the transmission infrastructure for ensuring adequate development of the network. Such objective targets availability of the transmission network capable ensuring of the consistent response to generation and demand growth by reliable and safe transportation of electricity, without any interruptions caused by outage of any single network element.

In general, development of the transmission system is a long-term process targeting reinforcement, expansion and upgrading of the network in line with generation and demand growth.

This document covers all components relevant to evolution of Georgian power system. However, other projects that are not included in this Ten-Year Plan may also be reviewed in current and/or subsequent years. In addition, some projects described herein may be modified, implemented in shorter timeframes or delayed. All such changes will be accounted for in 2018 revision of the plan.

Generation adequacy constitutes one of the major conditions for reliable power supply. Sufficient generation shall be always available to cover national demand without any negative influence on the power quality parameters. Such adequacy shall provide for availability of the system services including primary, secondary and tertiary frequency controls and voltage regulation as stipulated in the Grid Code that should obviously require centralized control of the generation facilities. GSE aims improving current technical environment in cooperation with power plants, and integrating into the network only such prospective generators, which are capable to provide the system services (provided that their capacities and outputs are sufficient to allow desired effect on Georgian power system).

The goal of GSE is to develop stable, reliable, cost-effective and efficient transmission system ensuring at any development stage:

- Network security;
- Power quality;
- Sufficient transfer capacity for
 - integration of renewable energy sources into the network; and
 - power exchange with neighbouring countries;
- Preparedness for integration into ENTSO-E's Ten-Year Network Development Plan

The reason of long-term development planning is explained by the need for the future transmission network satisfying all applicable design requirements, the most important from which is single contingency (N-1) criteria.

This Ten-Year Plan has been prepared based on the following principles:

- At any network development stage, power supply from generating facilities to the customers shall be carried out in compliance with N-1 criterion;
- The most cost-efficient network development option satisfying N-1 criterion shall be selected for implementation;
- Reliable operation of the power system shall be ensured;
- Power shall be supplied to the customers with high level of reliability;
- The network shall be developed in consistent and sustainable manner;
- Efficient operation of the power system shall be ensured.

This plan covers 500/400/330/220/154/110 kV overhead lines and substations that are important for the network, i.e. which existence or operation affects stability of the entire power system. Comparing to 220 kV lines, transmission capacities of 500 kV OHLs are about 5-times higher, while the losses are significantly less, although such lines entail higher construction and operation costs. Therefore, 500 kV OHLs are used for bulk power transit.

The eastern part of Georgian transmission network where the bulk loads are concentrated is well-developed at both 500 kV and 220 kV voltage levels, while the western part of the network has weak points despite the most portion of the domestic generation facilities (both existing and prospective) are accumulated therein. Therefore, the underlying trend in the development of Georgian transmission system will be reinforcement of the western network and its interconnection with the eastern part of the grid (Akhalsikhe node).

Since cross-border power exchange is one of the key drivers of Georgian transmission network development, this Ten-Year Plan envisages reinforcement of the lines connecting Georgia with Turkey, Armenia, Azerbaijan and Russia. The parallel synchronous operation with the power systems of neighbouring states provides the optimal regime for Georgian power system reflected in increased reliability and reduced need for operating reserves. However, possibility of contingent outages of cross-border lines should not be excluded, and therefore developments included in the Ten-Year Plan are intended for allowing continuous operation of Georgian power system under the island mode while providing its customers (and export to Turkey) with reliable and secure power supply.

Considering above, this Ten-Year Plan has been prepared assuming stability and reliability of the national power system at each development stage, with **specific focus on fulfilment of N-1 criterion that is essential design condition of Georgian transmission network**. For this purpose, GSE's specialists have performed number of calculations (power flow modelling, short circuit, stability and harmonic analyses, assessing capabilities for network integration of HPPs and determining system transfer capacities) allowing identification of the bottlenecks (weak points) of both existing and prospective network considering several alternative development options. From these, the best option as in terms of compliance with design (N-1) criterion so from the economical point of view was adopted for detail planning.

To achieve satisfaction of N-1 criterion without the need for shedding customer loads, that is an essential goal of Georgian transmission network development, requires mobilization of technical resources, as well as provision of sufficient finance (investments) that obviously may not occur immediately. However, within its available capabilities, GSE strives to compliance with single contingency criterion that, assuming the current network topology will be achieved during 2015-2019, subject to short-term demand limitations initiated by emergency control system.. Meanwhile, beginning from 2020, after commissioning of 500 kV transmission main Jvari-Tskaltubo-Akhalsikhe fully

backing up the existing 500 kV OHL Imereti, this criterion will be unconditionally satisfied without any impact on demand.

The major development drivers of Georgian transmission network include:

1. Increased reliability of power transmission from the existing generation sources to the loads;
2. Safe evacuation of the generation from prospective power plants;
3. Realization of power transfer potential with neighbouring states.

Reliability of the power transmission from the existing power plants to the customers is limited by geographical layout of Georgian power system with the largest plants, such as Enguri HPP and Vardnili HPPs located at the west of Georgia, and major loads distributed in the central (Kutaisi, Zestaponi), south (Akhalsikhe export line) and east (Tbilisi, Rustavi) parts of the country. Originally, when developing hydropower resources of Enguri River basin, essential intention was supplying of peak power to the south part of Russian power system. Therefore, 500 kV OHL Kavkasioni was considered as the major transmission line outgoing from Enguri HPP, while 500 kV Imereti transported only smaller power flows from Enguri River basin towards the bulk loads located at the east, since the latter were mainly supplied from the thermal plants located near Tbilisi-Rustavi node. Rocketed increase of fuel prices experienced during previous two decades, necessitated power supply of the eastern demand from Enguri basin reducing loads on OHL Kavkasioni and increasing burden on OHL Imereti. Such situation was further aggravated after construction of 700 MW HVDC back-to-back station in Akhalsikhe and 400 kV OHL Meskheta resulting in additional loads on OHL Imereti. Meantime, any outage of this line causes overloading of paralleling 220 kV mains posing risk to reliability of the entire power system. Therefore, reinforcement of 500/220 kV transmission system in the West Georgia is of high necessity that will be achieved in the first phase, by OHLs of Jvari-Khorga Interconnection Project, followed by the second phase envisaging construction of 500 kV **OHL Jvari-Tskaltubo Akhalsikhe that is the most necessary and strategic project for development of Georgian transmission network.**

The projects to be implemented in the transmission network have been divided into the following three groups:

1. **Internal Projects**, including the projects affecting power transit and reliability;
2. **Cross-Border Projects**, i.e. the projects affecting capacity and reliability of the transit flows among the power systems of Georgia and its neighbouring states;
3. **Local Projects**, comprising 220 kV and 110 kV dead-end feeder lines.

Transit and system importance projects are considered in detail in this development plan. Meanwhile, Cross-Border and Internal projects are further classified by their specific functions. Such division is reasonable considering that part of the network development projects target construction of cross-border lines intended for increasing power trade between Georgia and its neighbouring countries, and hence their implementation depends on special agreements and arrangements between participating states. Other part of such projects aims integration of HPPs into the network, and their implementation timing will be directly dictated by availability of relevant generation facilities. Third part of the projects included in the Ten-Year Plan are intended for increasing transfer capacity and reliability of the internal transmission network to satisfy N-1 design criterion, and therefore their implementation shall not depend either on integration of HPPs or on demand growth rates.

1. **Projects aiming at integration of HPPs into the network.** Construction deadlines and necessity of these projects will depend on construction of matching new HPPs, and include:

- **Double-circuit 220 kV OHL Batumi-Akhaltzikhe**, intended for evacuation of the generation of Shuakhevi HPP, Koromkheti HPP and other hydro power plants to be constructed in Adjara, increasing reliability of power supply in Adjara and Guria regions, and improving reliability of the power export from SS Batumi to Turkey via HVDC back-to-back station.
 - **North Ring (500/220/110 kV SS “Nenskra”, 500/220 kV SS “Lajanuri” and 500 kV OHL “Lajanuri – Tskaltubo”, single-circuit 500 kV OHL “Kvari – Nenskra”. Double-circuit 110 kV OHL “Nenskra – Mestia” (within 220 kV range), 220 kV OHL “Lentekhi – Tsageri – Lajanuri”, 220 kV OHL “Oni cascade–Lajanuri)**
designed for integration of the HPPs of Khudoni, Nenskra, Tskenishtskali Cascade as well as HPPs in Mestia region and Oni-Sadmeli HPPs into the grid.
 - **Double-circuit 220 kV OHL Tvishi-Namakhvani-Tskaltubo**, intended for network integration and reliable evacuation of the power generated by Namakhvani Cascade HPPs (410 MW).
 - **220/110 kV SS Guria**, which will integrate HPPs from Guria district into the grid and increase reliability of evacuation capacities of Kutaisi HPPs.
 - **Reinforcement of Kakheti infrastructure** main purpose of which is integration of HPPs from Kakheti region into the network and improving of reliability of evacuating power generated by HPPs in Kutaisi.
 - **Zestaponi**, new 500/220 kV, 500 MVA Autotransformer and 250 MVAR reactor in SS Zestaponi, designed to implement reliable evacuation of power generated by Oni cascade HPPs into the 500 kV network.
- 2. Strategic projects of system wide importance intended for upgrading reliability and capacity, as well as integration of prospective HPPs and/or for increasing internal network transmission capacity.** Implementation of these projects are of highest necessity both from technical and economical perspectives, and therefore shall be affected notwithstanding actual progress of matching planned hydropower projects.
- **Jvari-Khorga Interconnection Project**, including construction of 500/220 kV SS Jvari, 220/110 kV SS Khorga and double-circuit 220 kV OHL Jvari-Khorga (Odishi-1,2). This project aims to respond on growing demand in Black Sea region (Abkhazia, Poti Industrial Zone, Guria, Adjara), increasing capacity of 220 kV transmission main Enguri-Zestaponi, upgrading reliability level of the West Georgia’s transmission network and integration of the Khobi cascade HPPs into the network. Constuction of all components is complete, except for 220 kV OHL “Jvari – Khorga” and tie-line of 500 kV OHL “Kavkasioni” to SS “Jvari” (project to be fully completed in 2018).
 - **Tskaltubo-Zestaponi Interconnection Project.** This project envisages construction of 220 kV OHLs from SS Tskaltubo to Kutaisi (forming parallel link to OHL Sataplia) and from SS Kutaisi to SS Zestaponi (in parallel to OHL Ajameti-1,2). It’s purpose is improvement of reliability of the West Georgia’s network and reduction of the load/generation shedding effects in result of operation of the Emergency Control System. When implemented, this project will allow safe transfer of 700-750 MW power eastwards under emergency tripping of above mentioned 500 kV lines. Moreover, this project will implement integration of Tekhura cascade HPPs into the grid. Completed.
 - **Rehabilitation of Kolkhida-1.** After commissioning the projects “Tskaltubo-Zestaponi” and “Jvari-Khorga” this overhead line is the most loaded one in case of “Imereti” outage. Hence, in

order to avoid contingency severing, it is necessary to reinforce “Kolkhida-1” which will be the important part of reliability improvement of west part of transmission network.

- **500 kV OHL Jvari-Tskaltubo-Akhaltzikhe and 500 kV switchyard with 220 kV linkage in SS Tskaltubo.** This project is intended for improving security and reliability of the power evacuation from Khudoni-Enguri node to Turkey and East Georgian regions (to Armenia); from Russia to Turkey and Armenia – increase of power transit ability and reliability; supporting to opportunities related with development of production and tourist facilities in Kutaisi-Tskaltubo region, and evacuation of power generated by Khudoni, Nenskra HPPs as well as HPPs of Mestia district, Tskhenistskali and Oni-Sadmeili Cascade HPPs (through SS Jvari and SS Tskaltubo respectively) along with transmission of their generation to Akhaltzikhe (for export to Turkey) and East part of Georgia (for supply of Tbilisi-Rustavi bus bars and for export to Armenia).
 - **Rehabilitation of 500 kV OHL Imereti.** Jvari-Tskaltubo-Akhaltzikhe project will not have any effect unless its parallel 500 kV branch is not rehabilitated, present transfer capacity of which does not exceed 750-87 MW.
3. **Cross-border projects**, purposed for increasing power exchange and using the energy trade opportunities with neighbouring countries. Implementation timing of these projects are less dependant on dynamics of the national generation/demand, but instead are mainly linked to special bilateral arrangements supporting cross-border electricity trade. Such projects include:
- **400 kV OHL Akhaltzikhe-Tortum and 350 MW HVDC back-to-back link at SS Akhaltzikhe**, intended for increasing power exchange potential between Georgia and Turkey, providing redundancy for 400 kV OHL Meskheti and upgrading security of the power export to Turkey.
 - **500 kV OHL Ksani-Stepantsminda-Mozdok and 500/110 kV SS Stepantsminda**, designed for increasing potential and security of power exchange between Russia and Georgia (along with Armenia and Iran), and integration of Tergi River HPPs into the network.
 - **500 kV OHL Marneuli-Airum, 500 kV switchyard with linkage to 220 kV switchyard in SS Marneuli, and connection of existing 500 kV OHL Asureti (Mukhrani) to SS Marneuli.** This project aims at increasing power transfer potential between Georgia and Armenia (as well as Russia and Iran), and improving reliability of Tbilisi power supply (provided by resulting new 500 kV link between SS Ksani and SS Marneuli and backing up 500/220 kV AT at Gardabani). All the elements are already commissioned except 500 kV OHL Marneuli-Airum.
 - **154 kV OHL Batumi-Muratli and 350 MW HVDC back-to-back link at SS Batumi**, intended for partly evacuating generation of new Shuakhevi and Koromkheti HPPs and increasing power exchange potential between Georgia and Turkey.

6.2 Planning Methodology

Development of transmission system is a long-term process for upgrading the network in line with growth of generation and demand. This document describes the planning process encompassing all stages of transmission network development along with applicable planning criteria.

The planning process is divided into two phases, as Technical Planning and Cost Benefit Analysis (CBA).

6.2.1 Technical Planning

The first phase of the planning involves identification of development scenarios that should provide consistent, complete and realistic description of the future. Analysis of the scenarios shall target

Impact assessment described in this document shall be applicable to all projects.

Planning Scenarios and Cases

Planning scenarios are defined to represent the future environment. Scenario analysis is necessary to obtain realistic picture of a future. Scenarios are means to approach the uncertainties and acknowledge interaction between these uncertainties.

In other words, planning scenarios shall provide coherent, comprehensive and internally consistent description of a plausible future (in general composed of several time horizons) built on the imagined interaction of key economic parameters (including economic growth, variation of losses, reduction of outages etc.). Planning scenarios are characterized by generation portfolio (generation integration forecast, types of generation, etc.), demand forecasts (demand growth rate, shape of demand curve, etc.), and estimated patterns of the power exchange between different systems. Such scenarios may be based on local specifics (bottom-up scenarios) or targets of energy policy (top-down scenarios). Then each scenario shall be represented by several planning cases.

The planning shall adequately consider relevant input data and number of specific assumptions. The scenarios take into account technical and economical state of the network, along with forecasts of demand/generation growth and cross-border power flows.

Each scenario encompasses several planning cases, i.e. particular situations that may occur within the framework of the specific planning scenario, taking into account the following issues:

- Projected generation and power exchange for various time horizons, and specific number of network facilities to be commissioned during planning period;
- Daily, seasonal and annual variations of demand and generation (e.g. peak/off-peak, winter/summer, and annual);
- Detail locations of generation and demand;
- Cross-border power exchange forecasts; and
- Grid development assumptions.

Representative Planning Scenario(s) and Cases

The planning is intended to address the challenges faced by Georgian power network with due consideration of network peculiarities and need for approaching European network standards. Therefore, only scenarios considering above issues will be presented herein.

Representative planning scenarios shall cover representative planning cases in order to assess the need for grid reinforcement and/or optimization. Planning cases are defined based on criticality and/or frequency of occurrence.

Each selected scenario shall be assessed by analyzing its representative cases that are defined by TSO taking into account regional and national particularities

Time Horizons:

At least the following three time horizons shall be considered:

- Short-term horizon (typically 1-3 years);

- Mid-term horizon (typically 4-5 years);
- Long-term horizon (typically 6-10 years).

The following issues may have been taken into account during development of the representative planning cases:

- Estimated power exchange values with neighbouring state's transmission systems;
- Seasonal variation (e.g. winter/summer);
- Demand variation (e.g. peak/valley);
- Weather variation (e.g. temperature, wind, sun, precipitation etc.) [if necessary].

Planned Transmission System

Investments in new transmission assets envisaged for reinforcement of the network that are considered in this plan shall include all representative cases and take into account the forecasted commissioning dates of new network elements.

1. 500 kV substation is being built with the 3/2 (1.5) scheme, 220 kV substation – with double system with bypass bus bars.
2. In order to improve network reliability and stability, construction of tie-lines from 220 kV OHLs to power plants below 100 MW is maximally avoided due to two reasons:
 - 2.1 Substation of power plant will be constructed on transmission route which will complicate harmonization of modern relay protection and automatic and the rest systems.
 - 2.2 Both ends of overhead lines are being switched off in case of short circuit in power plant.
3. Connecting is wind farms to the network is permissible by 110 kV and lower voltage with maximum 45 MW capacity for one point – wind zone (opportunities of connection of these marginal capacities are presented in chapter 18).

6.2.2 Technical Criteria for Planning

Technical methods and criteria shall be defined and used when assessing the planning scenarios in order to identify future problems and determine required network reinforcements. **The lines that are of critical importance for the country shall be identified considering fulfilment of N-1 criterion without limiting customer demand.**

The general methodology includes:

- **Network analysis**
 - Investigation of base case topology (all network elements are available)
 - Different type contingencies (failures of network elements, loss of generation, etc.) to be considered depending on their probability of occurrence.
- **Evaluation of consequences**
 - Evaluation of consequences by checking the main technical indicators, such as:
 - thermal limits,
 - voltages,
 - loss of demand,
 - loss of generation,
 - short circuit levels,
 - stability conditions,
 - angular difference,

- cascade tripping
- Acceptable consequences can depend on the probability of occurrence of a contingency.

Deterministic criteria are currently used in network planning.

6.2.3 Grid Analysis

Data used for network analysis are mainly determined by the planning cases. For any relevant point of time, the expected state of the entire system “with all network elements available”, forms the basis for the analysis (Base case analysis).

Contingencies

Contingency is a loss of one (or several) elements of transmission system. A determination is made between high, medium and low probability contingencies.

- **High probability (ordinary) contingencies** include loss of one of the following elements:
 - generator;
 - transmission line (underground or overhead);
 - single transformer/autotransformer or several transformers connected to the same busbar;
 - shunt equipment (e.g. reactor, capacitor, etc.);
 - single DC link;
 - network equipment for load flow control (phase-shifting transformer, FACTS devices, etc.)
- **Medium probability (exceptional) contingencies** are defined as loss of the following elements:
 - OHL with two or more circuits on the same towers;
 - single busbar system;
 - loss of two or more generators or entire power plant;
 - loss of two DC links.
- **Low probability (out-of-range) contingencies** include loss of the following elements:
 - two OHLs simultaneously;
 - substation with more than one busbar system;
 - loss of two or more generation units in different power plants.

Due to general small scale of Georgian power system, occurrence of only ordinary contingencies may be occurred, since exceptional and out-of-range contingencies may occur only in different geographical areas of very large interconnected systems. Therefore, in this plan, only ordinary contingencies are taken into account.

N-1 Criterion for Grid Planning

Single contingency (N-1) criterion shall be fulfilled, i.e. system shall remain within acceptable limits following outage of one of the elements from the list of high probability (ordinary) contingencies given above.

Required Studies

Power flow analysis assumes normal condition of the network, i.e. when all elements are in the operable condition and operating parameters are in the acceptable ranges, defined as the “base case” (N) and deals with N-1 case, i.e. failure of any single network element.

Short circuit analysis involves evaluation of maximum and minimum three-phase short-circuit currents for any node of the transmission network according to IEC 60 909. This analysis aims at estimating maximum short-circuit current values to ensure that power equipment selected for designed power plants and substations are capable to withstand thermal and electrodynamic loads.

Voltage collapse study. The analysis of the planning cases assumes certain growth of both average and peak loads that will affect reactive power demand and voltage level.

Stability analysis includes transient simulations and other detailed analysis only in cases where the problems with stability significantly affecting the power system are expected.

Harmonic analysis assumes study of the power quality in critical points of the power system with respect to susceptibility to harmonic distortion. Performance of such analysis is of particular importance for Georgian power system, since HVDC back-to-back links integrated into the network are acting as sources of harmonics. The total capacity of these back-to-back links amount to almost a half of the total demand on power in Georgia, and is expected to triple in future accounting to the HVDC links to be installed in Armenia, near Georgian border.

6.2.4 Criteria for Assessment of Consequences

Steady State Criteria

- **Cascade tripping.** A single contingency must not result in any cascade tripping that may lead to a serious interruption of supply within any region (this may occur when additional trappings are initiated by system protection schemes after tripping of the primarily failed element).
- **Maximum permissible thermal load.** Permitted thermal rating of the network equipment shall not be exceeded neither in base nor in contingency cases. Taking into account duration, short-term overload capability can be considered, but only assuming that the overloads can be eliminated by operational countermeasures within the defined time interval, and do not cause a threat to safe operation.
- **Maximum and minimum voltage levels.** Neither in normal nor in contingency cases shall any voltage collapse occur, as well as shall not result in unacceptably long-lasting shortfall/excess of minimum/maximum voltage levels beyond prescribed limits necessary for maintaining integrity of the transmission network.

Loss of maximum load or generation

Maximum amount of load / generation to be lost should not exceed primary operating reserve available in the system.

Short circuit criteria

The rating of installed equipment shall be adequate for withstanding thermal and mechanical loads of maximum single-phase and three-phase circuit currents. The breakers of these equipment shall be

capable to withstand multiple commutation of such currents without any damage. Minimum short-circuit currents must be assessed in busbars where HVDC installations are connected.

Voltage collapse criteria

The reactive power output of generators and compensation equipment should not exceed their continuous rating, taking into account transformer tap ranges.

Stability Criteria

Taking into account definitions and classifications of system stability phenomena, and depending on specific task, the objective of stability analysis in case of ordinary contingencies includes rotor angle stability, frequency stability and voltage stability. Stability analysis allows identification of the bottlenecks of the transmission network along with appropriate reinforcement measures, as well as determining maximum permitted short circuit clearance time.

- **Dynamic stability analysis** studies power system behaviour and ability of maintaining synchronous operation of the generators during limited contingencies, for ensuring that:
 - System can maintain stability during tripping of internal lines in 500 kV and 220 kV networks by major protection devices (0.12 sec);
 - Wind power plants should not cause any significant impact on system stability, particularly they should continue operation during short circuit failures without consuming reactive current, and be provide for voltage and frequency regulation.
- **Static stability analysis** simulates system behaviour under minor contingencies that may occur during start-up/shutdown operations. Stability shall be deemed maintained if after such operations resulting swings in the transmission network are damped in the desired pattern.
- **Voltage security level.** In steady state situation, voltage deviation from nominal value shall not exceed -5% +10% in 110 kV, -5% +7% in 220 kV and +5% in higher voltage networks. During emergencies, similar limits shall be $\pm 10\%$ for 220 kV and higher voltage grids.

Possible Counter Measures

Inability to fulfil above criteria will require reinforcement of the planned network. Such reinforcement measures may include (without any limitation):

- Construction of the new overhead lines and underground cables;
- Expansion and/or construction of substations;
- Reinforcement of transmission lines for increasing their capacities (e.g. increasing the clearance to ground, replacement of conductors, etc.);
- Duplication of cables to increase rating;
- Replacement of the network equipment and/or reinforcement of the substations (e.g. based on short-circuit rating);
- Installation of reactive power compensation equipment (e.g. capacitor banks, synchronous condensers);
- Adding active power flow equipments (phase-shifting transformer) in the network;
- Changing of voltage levels of existing transmission infrastructure.

6.3 Cost Benefit Analysis

Economical appraisal of technically feasible projects has been performed applying the cost-benefit analysis (CBA) methodology. Using this method, expected benefits and relevant estimated investment costs and environmental impacts were individually assessed for each planned project.

The analysed factors included:

- **Increase of Network Transfer Capacity**, providing estimate of the incremental power transfer capacity between two cross-border points of transmission system (MW);
- **Project Cost**, specifying estimated total project value (mln Euros);
- **Social and Environmental Impacts**, reflecting level of certainty with respect to the planned commissioning time of the project and its impacts on the environment;
- **Security of Power Supply**, evaluating project impact on reliability status of the connected part of the network;
- **Socio-Economic Welfare**, specifying annual income generated by operation of the project (mln Euros/year);
- **Integration of Renewable Energy Sources (RES)**, estimating installed capacity of the renewable power plants (major Georgian HPPs) integrated into the network (MW) via the planned project;
- **Effect on Transmission Losses (Energy Efficiency)**, comparing losses (in MWs) relevant to the scenarios with and without project (or its specific components);
- **Effect on CO₂ Emissions**, specifying changes in carbon emissions in result of project implementation as proportional coefficient determined for RES;
- **Technical resilience / system safety margin**, evaluating project influence on entire system reliability;
- **Reliability / Flexibility**, specifying dependence of the specific project on various factors (RES integration, load growth, etc); Project is assessed as flexible if its implementation remains necessary for any alternative development scenarios.

Each project was assessed in terms of compliance with above criteria applying the scores from 0 to 3.

6.4 Scenarios of Georgian Transmission Network Development

Applying the methodology described above, several scenarios of Georgian transmission network development were reviewed. Information about prospective generation facilities to be integrated into the network was used as the input data for planning. Such facilities were divided into the following categories:

| | |
|-------------------|---|
| Category 1 | Power plants under construction, which are provided with relevant executed Memorandums; |
| Category 2 | Power plants that are objects of interests formally expressed by reputable investor companies, which feasibility studies have been commenced; |
| Category 3 | Large strategic power plants of country wide importance, which feasibility studies will commence in the nearest future. |

Table 6.1 Scenarios of transmission grid development of Georgia

| GROWTH OF LOAD GENERATION | “G1” 100% K1, 50% K2 | “G2” 100% K1, 50% K2, 25% K3 | “G3” 100% K1, 100% K2, 100% K3 |
|--------------------------------|-------------------------|------------------------------------|--------------------------------------|
| 1 % growth “L1” | L1G1 | L1G2 | L1G3 |
| 3.5 % growth “L2” | L2G1 | L2G2 | L2G3 |
| 5 % growth “L3” | L3G1 | L3G2 | L3G3 |

The estimated annual demand growth rate of 7% approved by the Ministry of Energy was applied for the base scenario, along with 3% and 5% growth rates for “optimistic” and “pessimistic” cases respectively.

The table 6.1 shows various cases with different growth rates regarding demand (load) and generation, while actual development of the transmission network will depend on progress of real integration of the loads/generation into the network.

In overall, the following scenarios were analysed:

L1G1 - Annual 3% increase of consumption and commissioning of (100%) category-1 power stations and 50% of category-2 power stations; delay of commissioning of the rest of power stations by 3 years.

L1G2 - Annual 3% increase of consumption and commissioning of (100%) category-1 power stations, 50% of category-2 power stations and 25% of category-3 power stations; delay of commissioning of the remaining power stations by 3 years.

L1G3 - Annual 3% increase of consumption and commissioning of (100%) all category power stations; delay of commissioning of the remaining power stations by 3 years.

L2G1 - Annual 5% increase of consumption and commissioning of (100%) category-1 power stations only, and 50% of category-2 power stations; delay of commissioning of the remaining power stations by 3 years.

L2G2 - Annual 5% increase of consumption and commissioning of (100%) category-1 power stations, 50% of category-2 power stations and 25% of category-3 power stations; delay of commissioning of the remaining power stations by 3 years.

L2G3 - Annual 5% increase of consumption and commissioning of (100%) all category power stations; delay of commissioning of the remaining power stations by 3 years.

L3G1 - Annual 7% increase of consumption and commissioning of (100%) category-1 power stations only, and 50% of category-2 power stations; delay of commissioning of the remaining power stations by 3 years.

L3G2 - Annual 7% increase of consumption and commissioning of (100%) category-1 power stations, 50% of category-2 power stations and 25% of category-3 power stations; delay of commissioning of the remaining power stations by 3 years.

L3G3 - Annual 7% increase of consumption and commissioning of (100%) of all three category power stations; delay of commissioning of the remaining power stations by 3 years.

After consultations held with the Ministry of Energy, L3G3 was selected as the most realistic scenario that assumes annual demand growth of 7% and integration of 100% of HPPs included in all three categories. Therefore, this development plan is based on the calculations performed for this scenario, although all other scenarios were also analyzed.

7 Forecasted Energy and Capacity Balances

According to law on “electricity and natural gas”, Article 3², paragraph 2: *Ten Year Network Development Plan of Georgia contains:*

- a) *Information about existing and predicted demand supply;*
- b) *Reasonable forecast about generation, supply, load and transmission to other countries.*

According to “Grid Code” Article 29, *dispatch license is obligated to make ten year balance forecast of demand-supply.*

7.1 Hydropower Booming by 2027




Fig. 7.1 Installed capacities of the existing power plants




Fig. 7.2 Installed capacities of power plants as for 2027

At present, total installed capacity of electric power plants operated in Georgia amounts to 4106 MW. From this, 2226 MW is generated by the so called “regulated” HPPs (with water storage), 934 MW by “seasonal” (run-of-river) HPPs, 110 MW by Gas Turbines and 815 MW by thermal power plants (Fig. 7.1). Roughly 77% of the total in-country installed capacity is provided by HPPs, including 54% generated by regulated hydro power plants.

For 2027, the total installed capacity available in Georgian power system will grow to 7595 MW (Fig. 7.2). From this, 4239 MW will be attributed to regulated HPPs, 2180 MW to seasonal HPPs, 20 MW to Wind Power Plants, 110 MW to Gas turbines and 1045 MW to high efficiency combined cycle as well as coal thermal power plants, which will replace the older Gardabani TPP’s Units Nos. 3, 4 and 9. For 2027, percentage share of hydropower in total national installed capacity will grow to 85%, including 56% regulated hydro power plants. This will ensure use of the water stored during flood season for low flow periods, thus reducing dependence on import of electricity and fossil fuels necessary for operation of thermal power plants.

7.2 Annual Energy Balances

The annual electric energy balances have been developed based on forecasted growth of generation and demand (Table 7.1, Fig. 7.3) for base L2G3 scenario.

Table 7.1. Forecasted annual energy balances of Georgian electric power system (bln kWh) for L2G3 scenario

| Year | Generation | HPPs | TPPs | Wind Farms | Consumption | Export |
|------|------------|-------|------|------------|-------------|--------|
| 2016 | 11.37 | 9.08 | 2.29 | - | 11.25 | 0.12 |
| 2017 | 12.9 | 10.23 | 2.58 | 0.093 | 11.64 | 1.26 |
| 2018 | 12.97 | 10.76 | 2.12 | 0.093 | 12.05 | 0.92 |
| 2019 | 14.61 | 11.99 | 2.53 | 0.093 | 12.47 | 2.14 |
| 2020 | 17.61 | 14.12 | 3.4 | 0.093 | 12.9 | 4.71 |
| 2021 | 18.3 | 15.37 | 2.84 | 0.093 | 13.35 | 4.95 |
| 2022 | 19.51 | 17.08 | 2.34 | 0.093 | 13.82 | 5.69 |
| 2023 | 20.15 | 17.63 | 2.43 | 0.093 | 14.3 | 5.85 |
| 2024 | 23.84 | 21.2 | 2.55 | 0.093 | 14.8 | 9.04 |
| 2025 | 25.66 | 22.96 | 2.61 | 0.093 | 15.32 | 10.34 |
| 2026 | 26.15 | 22.96 | 3.09 | 0.093 | 15.86 | 10.29 |
| 2027 | 26.3 | 22.96 | 3.24 | 0.093 | 16.4 | 9.9 |

Energy (bln. kWh)




Fig. 7.3 Georgian generation, consumption and export graphs corresponding to table 7.1

In case commissioning of generation and demand growth during a long period is less optimistic, then energy balance will be different, in particular, the annual output of HPPs will be less. However, less intensity of load increment will lead to increase export and during a long period, considering L2G2 scenario, compared to L2G3 one, there will be more electricity export in neighbor countries.

Table 7.2. Forecasted annual energy balances of Georgian electric power system (bln kWh) for L2G2 scenario

| Year | Generation | HPPs | TPPs | Wind Farms | Consumption | Export |
|------|------------|-------|------|------------|-------------|--------|
| 2016 | 11.37 | 9.08 | 2.29 | - | 10.98 | 0.39 |
| 2017 | 12.9 | 10.23 | 2.58 | 0.093 | 11.09 | 1.81 |
| 2018 | 12.97 | 10.76 | 2.12 | 0.093 | 11.2 | 1.77 |
| 2019 | 14.61 | 11.99 | 2.53 | 0.093 | 11.31 | 3.3 |
| 2020 | 17.61 | 14.12 | 3.4 | 0.093 | 11.42 | 6.19 |
| 2021 | 18.3 | 15.37 | 2.84 | 0.093 | 11.53 | 6.77 |
| 2022 | 19.51 | 17.08 | 2.34 | 0.093 | 11.64 | 7.87 |
| 2023 | 20.15 | 17.63 | 2.43 | 0.093 | 11.76 | 8.39 |
| 2024 | 23.84 | 21.20 | 2.55 | 0.093 | 11.88 | 11.96 |
| 2025 | 25.66 | 22.96 | 2.61 | 0.093 | 12.0 | 13.66 |
| 2026 | 26.15 | 22.96 | 3.09 | 0.093 | 12.12 | 14.03 |
| 2027 | 26.3 | 22.96 | 3.24 | 0.093 | 12.24 | 14.06 |

The relation between hydro power generation and consumption growth shows that:

1. In case of timely commissioning of HPPs (optimistic scenario), for any scenario of consumption growth, Georgia's power supply system will not be depended on imported power or fuel required for its generation, after 2020-2022. Moreover, in case of slow or moderate consumption growth scenario, electricity export might amount to 6-11 billion kWh annually.
2. In case of moderate scenario of construction of HPPs, based on the consumption growth scenario, Georgia's power supply system will maintain existing level of power independence, or will increase this level.
3. In case of pessimistic scenario of HPP construction, in case moderate or high consumption growth maintains, Georgia's power supply system's reliance on imported electricity and/or fuel will increase significantly and the deficit might amount to 5-9 billion kWh a year.

7.3 Specific regimes of Georgian Electrical System (Power Balances)

According to "Grid Code" article 39²: "In transmission network development plan, must be included forecasted regimes according to years..."

Power system consumption and peak load growth forecast. Although there exists load increasing indicator, one of the hardest task is peak demand forecasting. Determine this values are the most important because at the peak loads network elements take the most of the stress, in particular overhead lines and autotransformers. Hence, in case of peak load growth forecast, there will be timely relieved necessity of reinforcement of network elements and by such way their overload and damage will be avoided.

On the other hand it is noteworthy that peak consumption growth is less depended on the total load of consumers in service.

Projection of peak increases in 2018-2028 regimes of Georgia's power transmission network has been discussed in the following manner:

Table 7.3 The Georgian power system consumption, summer and winter loads ten years Statistics

| | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 |
|-------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|-------|
| | Y-10 | Y-9 | Y-8 | Y-7 | Y-6 | Y-5 | Y-4 | Y-3 | Y-2 | Y-1 | Y |
| L_{SUM} | 1074 | 1075 | 1167 | 1106 | 1200 | 1347 | 1374 | 1422 | 1540 | 1574 | 1631 |
| L_{WIN} | 1679 | 1712 | 1651 | 1538 | 1620 | 1682 | 1681 | 1811 | 1851 | 1869 | 2100 |
| E | 8303 | 8146 | 8411 | 7908 | 8746 | 9647 | 10194 | 10093 | 10619 | 10872 | 11327 |
| KL_{SUM} | 1.0009 | 1.0856 | 0.9477 | 1.0850 | 1.1225 | 1.0200 | 1.0349 | 1.0830 | 1.0221 | 1.0241 | |
| KL_{WIN} | 1.0197 | 0.9644 | 0.9316 | 1.0533 | 1.0383 | 0.9994 | 1.0773 | 1.0221 | 1.0097 | 1.0112 | |
| K_E | 0.9811 | 1.0325 | 0.9402 | 1.1059 | 1.1030 | 1.0568 | 0.9901 | 1.0522 | 1.0238 | 1.0419 | |

On the basis of this 10-year statistic data, relation between 2006-2017 relative peak growths and relative consumption growths has been determined.

$$\frac{KL_{SUM}}{K_E} = \frac{1}{N} \sum \frac{L_{SUM(Y)}/L_{SUM(Y-1)}}{E(Y)/E(Y-1)} = 1.0136$$

$$\frac{KL_{WIN}}{K_E} = \frac{1}{N} \sum \frac{L_{WIN(Y)}/L_{WIN(Y-1)}}{E(Y)/E(Y-1)} = 0.9920$$

Relatively, in case of 3, 5 and 7% growth, following scenarios of winter and summer peak load growth will occur:

| | | | |
|------------------------|--------|--------|--------|
| K_E | 1.03 | 1.05 | 1.07 |
| L_{SUM} | 1.044 | 1.0643 | 1.0846 |
| L_{WIN} | 1.0218 | 1.0416 | 1.0615 |

Table 7.4
Georgian power system consumption of the summer and winter loads ten years forecast for the annual consumption growth of 3.51%

| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 |
|---------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| | Y+1 | Y+2 | Y+3 | Y+4 | Y+5 | Y+6 | Y+7 | Y+8 | Y+9 | Y+10 | Y+11 |
| L_{SUM} | 1731 | 1815 | 1904 | 1997 | 2095 | 2197 | 2304 | 2417 | 2535 | 2659 | 2789 |
| L_{WIN} | 1915 | 1940 | 1966 | 1992 | 2018 | 2045 | 2072 | 2100 | 2128 | 2156 | 2184 |
| (L_{WIN}) | (2153) | (2207) | (2263) | (2320) | (2378) | (2438) | (2500) | (2563) | (2627) | (2693) | (2761) |
| E | 11725 | 12136 | 12562 | 13004 | 13460 | 13933 | 14422 | 14929 | 15453 | 15995 | 16557 |
| KL_{SUM} | 1.0489 | 1.0489 | 1.0489 | 1.0489 | 1.0489 | 1.0489 | 1.0489 | 1.0489 | 1.0489 | 1.0489 | 1.0489 |
| KL_{WIN} | 1.0132 | 1.0132 | 1.0132 | 1.0132 | 1.0132 | 1.0132 | 1.0132 | 1.0132 | 1.0132 | 1.0132 | 1.0132 |
| (KL_{WIN}) | (1.0252) | (1.0252) | (1.0252) | (1.0252) | (1.0252) | (1.0252) | (1.0252) | (1.0252) | (1.0252) | (1.0252) | (1.0252) |
| K_E | 1.0351 | 1.0351 | 1.0351 | 1.0351 | 1.0351 | 1.0351 | 1.0351 | 1.0351 | 1.0351 | 1.0351 | 1.0351 |

Considering that the proportion between the growths of consumption and load is constant, ie:

$$\frac{1 - KL_{SUM}}{1 - K_E} = \frac{1 - 1.0489}{1 - 1.0351} = 1.314 = const$$

$$\frac{1 - KL_{WIN}}{1 - K_E} = \frac{1 - 1.0252}{1 - 1.0351} = 0.7179 = const$$

Then for the case of 1% growth we will have the following (Table 7.5):

Table 7.5
Georgian power system consumption of the summer and winter loads ten years forecast for the annual consumption growth of 1%

| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 |
|---------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| | Y+1 | Y+2 | Y+3 | Y+4 | Y+5 | Y+6 | Y+7 | Y+8 | Y+9 | Y+10 | Y+11 |
| L_{SUM} | 1633 | 1655 | 1676 | 1698 | 1721 | 1743 | 1766 | 1790 | 1813 | 1837 | 1861 |
| L_{WIN} | 1897 | 1904 | 1911 | 1919 | 1926 | 1933 | 1940 | 1948 | 1955 | 1962 | 1970 |
| (L_{WIN}) | (2115) | (2130) | (2146) | (2161) | (2177) | (2192) | (2208) | (2224) | (2240) | (2256) | (2272) |
| E | 11440 | 11554 | 11670 | 11787 | 11905 | 12024 | 12144 | 12265 | 12388 | 12512 | 12637 |
| KL_{SUM} | 1.0131 | 1.0131 | 1.0131 | 1.0131 | 1.0131 | 1.0131 | 1.0131 | 1.0131 | 1.0131 | 1.0131 | 1.0131 |
| KL_{WIN} | 1.0037 | 1.0037 | 1.0037 | 1.0037 | 1.0037 | 1.0037 | 1.0037 | 1.0037 | 1.0037 | 1.0037 | 1.0037 |
| (KL_{WIN}) | (1.0072) | (1.0072) | (1.0072) | (1.0072) | (1.0072) | (1.0072) | (1.0072) | (1.0072) | (1.0072) | (1.0072) | (1.0072) |
| K_E | 1.01 | 1.01 | 1.01 | 1.01 | 1.01 | 1.01 | 1.01 | 1.01 | 1.01 | 1.01 | 1.01 |

And 5% growth (Table 7.6):

Table 7.6
Georgian power system consumption of the summer and winter loads ten years forecast for the annual consumption growth of 1%

| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 |
|---------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| | Y+1 | Y+2 | Y+3 | Y+4 | Y+5 | Y+6 | Y+7 | Y+8 | Y+9 | Y+10 | Y+11 |
| L_{SUM} | 1718 | 1831 | 1951 | 2079 | 2216 | 2362 | 2517 | 2682 | 2859 | 3046 | 3247 |
| L_{WIN} | 1926 | 1962 | 1999 | 2037 | 2075 | 2114 | 2154 | 2195 | 2236 | 2278 | 2321 |
| (L_{WIN}) | (2175) | (2253) | (2334) | (2418) | (2505) | (2595) | (2688) | (2785) | (2885) | (2988) | (3095) |
| E | 11893 | 12488 | 13112 | 13768 | 14456 | 15179 | 15938 | 16735 | 17572 | 18450 | 19373 |
| KL_{SUM} | 1.0657 | 1.0657 | 1.0657 | 1.0657 | 1.0657 | 1.0657 | 1.0657 | 1.0657 | 1.0657 | 1.0657 | 1.0657 |
| KL_{WIN} | 1.0189 | 1.0189 | 1.0189 | 1.0189 | 1.0189 | 1.0189 | 1.0189 | 1.0189 | 1.0189 | 1.0189 | 1.0189 |
| (KL_{WIN}) | (1.0359) | (1.0359) | (1.0359) | (1.0359) | (1.0359) | (1.0359) | (1.0359) | (1.0359) | (1.0359) | (1.0359) | (1.0359) |
| K_E | 1.05 | 1.05 | 1.05 | 1.05 | 1.05 | 1.05 | 1.05 | 1.05 | 1.05 | 1.05 | 1.05 |

In accordance with above tables, statistics consumption evolution and ten-year forecasts are given on figures 7.4-7.6.




Figure 7.4
Statistic and forecast of consumption growth




Figure 7.5
Statistic and growth forecast of summer peak load




Figure 7.6-a
Statistic and growth forecast of winter peak load




Figure 7.6-b
Statistic and growth forecast of winter peak load (corrected)

Peak load forecast for Individual substations by the analysis of statistical trends. Based on the statistical variation of peak consumption in past ten-year and by the use of method of “Least Squares” various polynomial charts are being plotted base on which it is possible to determine peak values for future years. Plotting of first-order (linear) graph is the simplest and relatively reliable method:

$$P_{NX} = aX + b$$

where

a, b = coefficients are defined by least squares method

$X = Y, Y+1, Y+2...$ is any year to be planned

Peak load analysis was conducted on the basis of 2006-2017 statistic data, for winter and summer regimes.

Table 7.7 Peak load statistics, summer peak

| BUS | YEAR | | | | | | | | | | |
|------------|------|------|------|------|------|------|------|------|------|------|------|
| | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 |
| ENGURI | 10 | 10 | 11 | 11 | 12 | 9 | 11 | 11 | 13 | 10 | 11 |
| KOLKHIDA-3 | 113 | 124 | 143 | 127 | 105 | 119 | 125 | 123 | 139 | 162 | 143 |
| VARDNILI | 29 | 32 | 37 | 33 | 27 | 31 | 32 | 31 | 36 | 42 | 37 |
| ZUGDIDI | 22 | 24 | 24 | 25 | 26 | 30 | 30 | 25 | 25 | 32 | 30 |
| MENJI | 24 | 26 | 27 | 28 | 32 | 40 | 42 | 48 | 46 | 48 | 53 |
| KHORGA | - | - | - | - | - | - | - | - | - | 0 | 5 |
| BATUMI | 60 | 62 | 67 | 68 | 68 | 79 | 92 | 85 | 97 | 102 | 104 |
| KUTAIISI | 58 | 61 | 65 | 75 | 72 | 83 | 82 | 82 | 82 | 100 | 104 |
| TSKALTUBO | 20 | 21 | 22 | 25 | 24 | 28 | 28 | 28 | 28 | 34 | 33 |
| LAJANURI | 5 | 4 | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 7 | 6 |
| ZESTAFONI | 111 | 86 | 122 | 69 | 108 | 150 | 184 | 177 | 196 | 119 | 182 |
| FERO | 37 | 29 | 41 | 23 | 36 | 50 | 61 | 59 | 65 | 40 | 61 |
| KHASHURI | 24 | 22 | 24 | 26 | 24 | 35 | 27 | 36 | 42 | 47 | 45 |
| GORI | 34 | 26 | 32 | 27 | 28 | 27 | 35 | 36 | 51 | 63 | 52 |
| KSANI | 30 | 33 | 34 | 37 | 36 | 34 | 35 | 34 | 43 | 45 | 43 |
| ZHINVALI | 12 | 13 | 14 | 15 | 15 | 14 | 14 | 13 | 17 | 19 | 17 |
| GARDABANI | 42 | 50 | 48 | 49 | 52 | 51 | 53 | 62 | 61 | 61 | 64 |
| RUSTAVI | 70 | 83 | 80 | 81 | 86 | 85 | 88 | 103 | 101 | 101 | 106 |
| GURJAANI | 31 | 32 | 34 | 35 | 36 | 40 | 38 | 39 | 39 | 53 | 47 |
| MARNEULI | 21 | 20 | 23 | 24 | 23 | 25 | 28 | 34 | 37 | 32 | 36 |
| KHRAMI-2 | 5 | 5 | 5 | 5 | 5 | 6 | 6 | 8 | 9 | 7 | 8 |
| NAVTLUGI | 84 | 85 | 85 | 88 | 104 | 119 | 105 | 121 | 120 | 117 | 129 |
| GLDANI | 76 | 76 | 77 | 80 | 94 | 107 | 95 | 110 | 109 | 106 | 117 |
| DIDUBE | 83 | 82 | 79 | 80 | 97 | 96 | 84 | 81 | 95 | 120 | 105 |
| LISI | 73 | 72 | 69 | 70 | 85 | 84 | 74 | 72 | 84 | 106 | 93 |
| SYSTEM | 1074 | 1075 | 1167 | 1106 | 1200 | 1347 | 1374 | 1422 | 1540 | 1574 | 1632 |

* - 2017 summer and winter peak load data is live data

Table 7.8 Peak load statistics, winter peak

| BUS | YEAR | | | | | | | | | |
|------------|------|------|------|------|------|------|------|------|------|------|
| | 2006 | 2007 | 2008 | 2009 | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 |
| ENGURI | 15 | 16 | 17 | 18 | 18 | 28 | 21 | 34 | 23 | 17 |
| KOLKHIDA-3 | 230 | 233 | 233 | 211 | 172 | 205 | 218 | 230 | 242 | 273 |
| VARDNILI | 98 | 99 | 99 | 89 | 73 | 87 | 92 | 98 | 102 | 115 |
| ZUGDIDI | 35 | 36 | 34 | 32 | 35 | 30 | 35 | 34 | 21 | 49 |
| MENJI | 42 | 40 | 32 | 34 | 39 | 49 | 50 | 53 | 49 | 52 |
| KHORGA | - | - | - | - | - | - | - | - | - | - |
| BATUMI | 88 | 102 | 89 | 77 | 92 | 94 | 86 | 77 | 104 | 109 |
| KUTAIISI | 86 | 88 | 89 | 78 | 92 | 96 | 100 | 102 | 113 | 112 |
| TSKALTUBO | 22 | 22 | 23 | 20 | 23 | 24 | 25 | 26 | 28 | 28 |
| LAJANURI | 5 | 6 | 5 | 6 | 5 | 5 | 4 | 6 | 7 | 9 |
| ZESTAFONI | 121 | 105 | 108 | 106 | 109 | 158 | 141 | 162 | 177 | 107 |
| FERO | 41 | 35 | 36 | 36 | 37 | 53 | 47 | 55 | 59 | 36 |
| KHASHURI | 32 | 34 | 32 | 32 | 34 | 31 | 29 | 34 | 46 | 50 |
| GORI | 52 | 53 | 48 | 50 | 52 | 58 | 65 | 59 | 65 | 72 |

| | | | | | | | | | | |
|-----------|------|------|------|------|------|------|------|------|------|------|
| KSANI | 33 | 34 | 33 | 34 | 44 | 29 | 33 | 30 | 34 | 36 |
| ZHINVALI | 20 | 20 | 20 | 20 | 27 | 18 | 20 | 18 | 20 | 21 |
| GARDABANI | 75 | 88 | 78 | 76 | 81 | 66 | 68 | 80 | 68 | 72 |
| RUSTAVI | 97 | 114 | 102 | 99 | 105 | 87 | 89 | 105 | 88 | 93 |
| GURJAANI | 37 | 37 | 36 | 38 | 38 | 32 | 37 | 42 | 52 | 54 |
| MARNEULI | 37 | 37 | 34 | 34 | 34 | 23 | 37 | 39 | 37 | 38 |
| KHRAMI-2 | 13 | 13 | 12 | 12 | 12 | 9 | 14 | 15 | 14 | 14 |
| NAVTLUGI | 136 | 132 | 131 | 116 | 130 | 136 | 136 | 142 | 149 | 140 |
| GLDANI | 126 | 122 | 121 | 108 | 120 | 126 | 126 | 132 | 139 | 130 |
| DIDUBE | 132 | 137 | 133 | 118 | 138 | 132 | 116 | 132 | 119 | 134 |
| LISI | 106 | 109 | 107 | 94 | 110 | 106 | 92 | 106 | 95 | 108 |
| SYSTEM | 1679 | 1712 | 1651 | 1538 | 1620 | 1682 | 1681 | 1811 | 1851 | 1869 |

* - 2017 winter peak load data is the estimated data and will be determined in 2018

Power system peak load regimes.

Scenarios of power systems' peak load usually do not match to the sum of the loads of individual substations meaning that load of some substation is less than peak one. However, to the extent that transmission network has to be checked on marginal level of load, it is assumed that loadings for all substations are being increased in a linear way, according to the statistic trend. Gldani and Khorga substations are exceptions where there are applications about adding significant amounts received.

Summer peak loads are shown below, in case of 3 and 7% annual consumption growth.

Table 7.9

Peak load growth forecast for substations in summer. 3.5% growth of consumption

| BUS | YEAR | | | | | | | | | | |
|------------|------|------|------|------|------|------|------|------|------|------|------|
| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 |
| ENGURI | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 13 | 13 |
| KOLKHIDA-3 | 146 | 149 | 151 | 154 | 157 | 160 | 162 | 165 | 168 | 171 | 173 |
| VARDNILI | 38 | 38 | 39 | 40 | 40 | 41 | 42 | 42 | 43 | 44 | 45 |
| ZUGDIDI | 31 | 32 | 32 | 33 | 34 | 35 | 35 | 36 | 37 | 38 | 38 |
| MENJI | 56 | 59 | 62 | 66 | 69 | 72 | 75 | 78 | 81 | 84 | 87 |
| KHORGA | 35 | 65 | 95 | 125 | 155 | 185 | 215 | 245 | 275 | 305 | 335 |
| BATUMI | 109 | 114 | 119 | 124 | 129 | 133 | 138 | 143 | 148 | 153 | 158 |
| KUTAIISI | 109 | 114 | 119 | 124 | 129 | 133 | 138 | 143 | 148 | 153 | 158 |
| TSKALTUBO | 34 | 36 | 37 | 38 | 40 | 41 | 42 | 44 | 45 | 46 | 48 |
| LAJANURI | 6 | 6 | 6 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 8 |
| ZESTAFONI | 191 | 200 | 210 | 219 | 228 | 237 | 246 | 255 | 264 | 273 | 283 |
| FERO | 64 | 67 | 70 | 73 | 76 | 79 | 82 | 85 | 88 | 91 | 94 |
| KHASHURI | 47 | 50 | 52 | 55 | 57 | 60 | 63 | 65 | 68 | 70 | 73 |
| GORI | 55 | 58 | 61 | 63 | 66 | 69 | 72 | 75 | 78 | 81 | 84 |
| KSANI | 44 | 45 | 46 | 47 | 49 | 50 | 51 | 52 | 53 | 55 | 56 |
| ZHINVALI | 18 | 18 | 19 | 19 | 20 | 20 | 21 | 21 | 22 | 22 | 23 |
| GARDABANI | 66 | 68 | 70 | 72 | 74 | 76 | 78 | 80 | 82 | 84 | 86 |
| RUSTAVI | 109 | 112 | 116 | 119 | 122 | 125 | 129 | 132 | 135 | 138 | 142 |
| GURJAANI | 49 | 51 | 52 | 54 | 56 | 58 | 59 | 61 | 63 | 65 | 67 |
| MARNEULI | 38 | 40 | 41 | 43 | 45 | 47 | 48 | 50 | 52 | 54 | 55 |
| KHRAMI-2 | 9 | 9 | 9 | 10 | 10 | 11 | 11 | 11 | 12 | 12 | 13 |

TEN-YEAR NETWORK DEVELOPMENT PLAN OF GEORGIA 2018-2028

| | | | | | | | | | | | |
|----------|------|------|------|------|------|------|------|------|------|------|------|
| NAVTLUGI | 134 | 139 | 143 | 148 | 153 | 158 | 163 | 167 | 172 | 177 | 182 |
| GLDANI | 125 | 134 | 144 | 154 | 164 | 176 | 188 | 201 | 215 | 231 | 247 |
| DIDUBE | 107 | 110 | 113 | 115 | 118 | 121 | 123 | 126 | 129 | 132 | 134 |
| LISI | 95 | 98 | 100 | 102 | 105 | 107 | 110 | 112 | 115 | 117 | 120 |
| SYSTEM | 1727 | 1822 | 1919 | 2016 | 2113 | 2212 | 2311 | 2411 | 2512 | 2614 | 2717 |

Table 7.10

Peak load growth forecast for substations in summer. 5% growth of consumption

| BUS | YEAR | | | | | | | | | | |
|------------|------|------|------|------|------|------|------|------|------|------|------|
| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 |
| ENGURI | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | 21 | 22 | 24 |
| KOLKHIDA-3 | 153 | 163 | 174 | 186 | 199 | 212 | 227 | 242 | 259 | 276 | 295 |
| VARDNILI | 39 | 42 | 45 | 48 | 51 | 55 | 58 | 62 | 67 | 71 | 76 |
| ZUGDIDI | 32 | 34 | 37 | 39 | 42 | 45 | 48 | 51 | 55 | 58 | 62 |
| MENJI | 57 | 61 | 65 | 69 | 74 | 79 | 84 | 90 | 96 | 103 | 110 |
| KHORGA | 5 | 6 | 6 | 7 | 7 | 7 | 8 | 8 | 9 | 10 | 10 |
| BATUMI | 112 | 119 | 127 | 136 | 145 | 155 | 166 | 177 | 189 | 202 | 215 |
| KUTAI SI | 112 | 119 | 127 | 136 | 145 | 155 | 166 | 177 | 189 | 202 | 215 |
| TSKALTUBO | 35 | 38 | 40 | 43 | 46 | 49 | 52 | 56 | 60 | 64 | 68 |
| LAJANURI | 6 | 7 | 7 | 8 | 8 | 9 | 9 | 10 | 11 | 11 | 12 |
| ZESTAFONI | 195 | 208 | 222 | 237 | 253 | 270 | 289 | 308 | 329 | 352 | 376 |
| FERO | 65 | 69 | 74 | 79 | 84 | 90 | 96 | 103 | 110 | 117 | 125 |
| KHASHURI | 48 | 51 | 54 | 58 | 62 | 66 | 71 | 76 | 81 | 86 | 92 |
| GORI | 55 | 59 | 63 | 67 | 72 | 77 | 82 | 88 | 94 | 100 | 107 |
| KSANI | 45 | 49 | 52 | 55 | 59 | 63 | 68 | 72 | 77 | 82 | 88 |
| ZHINVALI | 19 | 20 | 21 | 23 | 24 | 26 | 28 | 29 | 31 | 34 | 36 |
| GARDABANI | 68 | 73 | 78 | 83 | 89 | 95 | 101 | 108 | 115 | 123 | 132 |
| RUSTAVI | 113 | 121 | 129 | 138 | 147 | 157 | 168 | 179 | 191 | 204 | 218 |
| GURJAANI | 50 | 54 | 58 | 61 | 66 | 70 | 75 | 80 | 85 | 91 | 97 |
| MARNEULI | 39 | 41 | 44 | 47 | 50 | 54 | 57 | 61 | 65 | 70 | 75 |
| KHRAMI-2 | 9 | 9 | 10 | 11 | 11 | 12 | 13 | 14 | 15 | 16 | 17 |
| NAVTLUGI | 138 | 147 | 157 | 168 | 179 | 192 | 205 | 219 | 233 | 249 | 266 |
| GLDANI | 125 | 134 | 143 | 152 | 163 | 174 | 186 | 198 | 212 | 226 | 242 |
| DIDUBE | 112 | 119 | 127 | 136 | 145 | 155 | 166 | 177 | 189 | 202 | 216 |
| LISI | 99 | 106 | 113 | 120 | 129 | 137 | 147 | 157 | 167 | 179 | 191 |
| SYSTEM | 1743 | 1861 | 1988 | 2123 | 2267 | 2421 | 2586 | 2762 | 2950 | 3150 | 3365 |

* - Ferro-alloy plant consumption was added.

Table 7.11-a

Peak load growth forecast for substations in winter. 3.5-5.0% growth of consumption

| BUS | YEAR | | | | | | | | | | |
|--------|------|------|------|------|------|------|------|------|------|------|------|
| | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 |
| ENGURI | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 | 38 |

| | | | | | | | | | | | |
|------------|------|------|------|------|------|------|------|------|------|------|------|
| KOLKHIDA-3 | 244 | 247 | 250 | 253 | 256 | 259 | 262 | 265 | 268 | 271 | 274 |
| VARDNILI | 103 | 104 | 105 | 106 | 107 | 108 | 110 | 111 | 112 | 113 | 114 |
| ZUGDIDI | 35 | 35 | 35 | 36 | 36 | 36 | 36 | 36 | 36 | 36 | 37 |
| MENJI | 57 | 58 | 60 | 62 | 64 | 66 | 68 | 70 | 72 | 74 | 76 |
| KHORGGA | 45 | 75 | 105 | 135 | 165 | 195 | 225 | 255 | 285 | 315 | 345 |
| BATUMI | 103 | 104 | 105 | 106 | 107 | 108 | 110 | 111 | 112 | 113 | 114 |
| KUTAIISI | 117 | 120 | 124 | 127 | 130 | 134 | 137 | 140 | 143 | 147 | 150 |
| TSKALTUBO | 29 | 30 | 31 | 31 | 32 | 33 | 34 | 34 | 35 | 36 | 37 |
| LAJANURI | 7 | 8 | 8 | 8 | 8 | 9 | 9 | 9 | 9 | 10 | 10 |
| ZESTAFONI | 161 | 166 | 171 | 176 | 180 | 185 | 190 | 195 | 200 | 205 | 210 |
| FERO | 54 | 56 | 57 | 59 | 60 | 62 | 64 | 65 | 67 | 69 | 70 |
| KHASHURI | 45 | 47 | 48 | 49 | 51 | 52 | 54 | 55 | 57 | 58 | 60 |
| GORI | 72 | 74 | 76 | 79 | 81 | 83 | 85 | 88 | 90 | 92 | 94 |
| KSANI | 36 | 37 | 37 | 37 | 37 | 37 | 37 | 38 | 38 | 38 | 38 |
| ZHINVALI | 21 | 21 | 21 | 22 | 22 | 22 | 22 | 22 | 22 | 22 | 22 |
| GARDABANI | 73 | 73 | 73 | 74 | 74 | 75 | 75 | 75 | 76 | 76 | 76 |
| RUSTAVI | 94 | 94 | 95 | 95 | 96 | 96 | 97 | 97 | 98 | 98 | 99 |
| GURJAANI | 52 | 53 | 55 | 56 | 58 | 60 | 61 | 63 | 65 | 66 | 68 |
| MARNEULI | 36 | 36 | 37 | 37 | 37 | 37 | 37 | 38 | 38 | 38 | 38 |
| KHRAMI-2 | 14 | 14 | 15 | 15 | 15 | 15 | 15 | 16 | 16 | 16 | 16 |
| NAVTLUGI | 146 | 147 | 149 | 151 | 152 | 154 | 156 | 157 | 159 | 161 | 162 |
| GLDANI | 152 | 153 | 155 | 156 | 158 | 159 | 161 | 162 | 164 | 166 | 167 |
| DIDUBE | 135 | 136 | 137 | 137 | 138 | 139 | 139 | 140 | 141 | 142 | 142 |
| LISI | 109 | 110 | 110 | 111 | 111 | 112 | 112 | 113 | 114 | 114 | 115 |
| SYSTEM | 1967 | 2027 | 2087 | 2148 | 2209 | 2269 | 2330 | 2391 | 2451 | 2512 | 2573 |

Besides above presented winter peak growth forecast based on 2006-2015 data, second option of this forecast has been elaborated base year in which is 2016 instead of 2015. Peak load 2024 MW has been recorded on 9th December. Considering this, 2100 MW is expected as winter peak load. Forecast of peak load growth for 2017-2027 has been developed according to the peak load data of 2016. Peak load for each substation has been analyzed by trend method and corrections have been submitted in tab. 7.11-a (7-11-b).

Table 7.11-b
Peak load growth forecast for substations in winter (corrected). 3.5-5.0% growth of consumption

| BUS | YEAR | | | | | | | | | | | |
|------------|------|------|------|------|------|------|------|------|------|------|------|------|
| | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 |
| ENGURI | 26 | 27 | 28 | 29 | 30 | 31 | 32 | 33 | 34 | 35 | 36 | 37 |
| KOLKHIDA-3 | 308 | 268 | 274 | 280 | 286 | 292 | 298 | 304 | 310 | 316 | 322 | 328 |
| VARDNILI | 110 | 106 | 107 | 109 | 110 | 112 | 114 | 115 | 117 | 118 | 120 | 121 |
| ZUGDIDI | 44 | 38 | 39 | 40 | 40 | 41 | 41 | 42 | 42 | 43 | 43 | 44 |
| MENJI | 52 | 56 | 57 | 59 | 61 | 63 | 65 | 66 | 68 | 70 | 72 | 74 |
| KHORGGA | 6 | 40 | 70 | 100 | 130 | 160 | 190 | 220 | 250 | 280 | 310 | 340 |
| BATUMI | 104 | 110 | 114 | 119 | 123 | 127 | 131 | 135 | 139 | 144 | 148 | 152 |
| KUTAIISI | 126 | 128 | 133 | 139 | 145 | 150 | 156 | 162 | 167 | 173 | 179 | 184 |

| | | | | | | | | | | | | |
|-----------|------|------|------|------|------|------|------|------|------|------|------|------|
| TSKALTUBO | 40 | 41 | 45 | 49 | 54 | 58 | 62 | 66 | 70 | 75 | 79 | 83 |
| LAJANURI | 9 | 9 | 9 | 10 | 10 | 10 | 10 | 10 | 11 | 11 | 11 | 11 |
| ZESTAFONI | 160 | 161 | 162 | 163 | 164 | 165 | 166 | 167 | 168 | 169 | 170 | 171 |
| FERO | 58 | 59 | 59 | 60 | 60 | 61 | 61 | 62 | 62 | 63 | 63 | 64 |
| KHASHURI | 42 | 50 | 53 | 56 | 58 | 61 | 64 | 67 | 70 | 72 | 75 | 78 |
| GORI | 82 | 78 | 81 | 85 | 88 | 91 | 94 | 97 | 101 | 104 | 107 | 110 |
| KSANI | 36 | 39 | 41 | 43 | 45 | 47 | 49 | 51 | 53 | 55 | 57 | 59 |
| ZHINVALI | 22 | 22 | 22 | 22 | 22 | 22 | 22 | 22 | 22 | 22 | 22 | 22 |
| GARDABANI | 83 | 79 | 80 | 82 | 83 | 84 | 86 | 87 | 88 | 89 | 91 | 92 |
| RUSTAVI | 100 | 100 | 102 | 103 | 105 | 107 | 109 | 111 | 112 | 114 | 116 | 118 |
| GURJAANI | 58 | 59 | 63 | 66 | 69 | 73 | 76 | 80 | 83 | 86 | 90 | 93 |
| MARNEULI | 42 | 42 | 43 | 44 | 45 | 46 | 47 | 48 | 49 | 50 | 51 | 52 |
| KHRAMI-2 | 16 | 15 | 15 | 15 | 16 | 16 | 16 | 16 | 16 | 17 | 17 | 17 |
| NAVTLUGI | 145 | 149 | 152 | 154 | 156 | 159 | 161 | 163 | 166 | 168 | 170 | 173 |
| GLDANI | 165 | 230 | 235 | 237 | 241 | 245 | 248 | 252 | 255 | 259 | 262 | 265 |
| DIDUBE | 158 | 144 | 146 | 149 | 152 | 155 | 158 | 161 | 163 | 166 | 169 | 172 |
| LISI | 107 | 108 | 110 | 111 | 113 | 114 | 116 | 118 | 119 | 121 | 122 | 124 |
| SYSTEM | 2100 | 2158 | 2242 | 2323 | 2406 | 2489 | 2571 | 2654 | 2736 | 2819 | 2902 | 2984 |

7.4 Specific working regimes for Georgian Grid (Power Balances)

Winter Maximum corresponds to the peak demand at the end of December that is 1950 (2100) MW for 2016. At this period flow on seasonal HPPs is low, and therefore those HPPs generate less power. Also power demand is higher at this time span, therefore Georgian power system has deficit. Regulating HPPs (ENGURI, KHRAMI 1,2, VARDNILI, DZEVRULA, SHAORI, LAJANURI), thermal power plants (№3, 4, 9 Blocks and Gas Turbine) and import from neighbor countries take by themselves this lack of generation. In 2020-2026 №3, 4 and 9 blocks will be replaced by more effective combined thermal power plants.

As it is seen from table 7.12 and on diagram 7.7, in winter months till 2025 power demand is smoothly increased. Significant export and import growth is anticipated till 2023. Export-import volumes from 2023 till 2026 is sated, caused by the fact that generation growth in the system balances the consumption growth. Import increases from 2026 till 2028. This occurs because no new source of generation enters the system, thus the consumption increases, which is covered through the electric power imported into the country.

Table 7.12-a Forecasted balance (MW)

| YEAR | WINTER MAXIMUM | | | |
|------|----------------|------|--------|--------|
| | GENERATION | LOAD | EXPORT | IMPORT |
| 2016 | 2009 | 1950 | 50 | 0 |
| 2017 | 2359 | 1966 | 700 | 350 |
| 2018 | 2373 | 2027 | 700 | 400 |
| 2019 | 2533 | 2087 | 1045 | 650 |
| 2020 | 3130 | 2148 | 1045 | 100 |
| 2021 | 3136 | 2209 | 2085 | 1250 |
| 2022 | 3241 | 2269 | 2085 | 1200 |
| 2023 | 3255 | 2330 | 2085 | 1250 |
| 2024 | 3858 | 2391 | 2085 | 700 |
| 2025 | 4377 | 2451 | 2235 | 400 |
| 2026 | 4433 | 2512 | 2235 | 400 |
| 2027 | 4496 | 2573 | 2235 | 400 |




Fig 7.7-a Winter maximum

Table 7.12-b Forecasted balance (MW)

| YEAR | WINTER MAXIMUM (CORRECTED) | | | |
|------|----------------------------|------|--------|--------|
| | GENERATION | LOAD | EXPORT | IMPORT |
| 2016 | 2070 | 2100 | 0 | 50 |
| 2017 | 2421 | 2158 | 700 | 480 |
| 2018 | 2507 | 2242 | 700 | 480 |
| 2019 | 2624 | 2323 | 1045 | 800 |
| 2020 | 3199 | 2407 | 1045 | 300 |
| 2021 | 3227 | 2490 | 2085 | 1445 |
| 2022 | 3351 | 2571 | 2085 | 1400 |
| 2023 | 3438 | 2655 | 2085 | 1400 |
| 2024 | 3960 | 2735 | 2085 | 950 |
| 2025 | 4466 | 2819 | 2235 | 700 |
| 2026 | 4640 | 2903 | 2235 | 600 |
| 2027 | 4724 | 2984 | 2235 | 600 |




Fig 7.7-b Winter maximum (corrected)

Winter Minimum corresponds load at night minimum regime, that for 2016 is approximately 1002 mw. At this period thermal blocks work at their base power and their load is the same as in winter maximum regimes. Power generation of seasonal HPPs is same. Power generation of regulating HPPs is decreased. In 2017-2027 the cause of power balance change is the same as in winter maximum regimes.

Table 7.8 Forecasted power balance (MW)

| YEAR | WINTER MINIMUM | | | |
|------|----------------|------|--------|--------|
| | GENERATION | LOAD | EXPORT | IMPORT |
| 2016 | 1042 | 1002 | 0 | 50 |
| 2017 | 1460 | 1032 | 694 | 300 |
| 2018 | 1488 | 1061 | 694 | 300 |
| 2019 | 1720 | 1090 | 1045 | 450 |
| 2020 | 2250 | 1120 | 1295 | 200 |
| 2021 | 2255 | 1144 | 2085 | 1050 |
| 2022 | 2335 | 1179 | 2085 | 1050 |
| 2023 | 2365 | 1205 | 2085 | 996 |
| 2024 | 2686 | 1237 | 2085 | 700 |
| 2025 | 2879 | 1267 | 2385 | 850 |
| 2026 | 3059 | 1296 | 2535 | 850 |
| 2027 | 3090 | 1326 | 2535 | 850 |




Fig 7.7 Winter Minimum

Summer maximum corresponds the period when water flow is highest in rivers. In this period export potential is being increased. Forecasted load of Georgian electrical network for 2016 is 1612 mw. Because this HPPs are located in Enguri basin and TPPs are shut off because of increased water flow in rivers, electricity transmission is increased for the direction from west to east from Enguri-Vardnili generation nod to Akhaltsikhe and Lisi-Rustavi consumption nodes. HPPs in Enguri basin provide energy export in Turkey that increases power flow on OHL “Imereti” to 700-800 mw.

Despite of surplus amount of generation, during 2018-2020 years, power will be imported (for transit) from Armenia, Russia and Turkey. Starting from 2021, due to the commissioning of powerful HPPs import will totally be eliminated by their generation. From 2017 to 2027, generation significantly increases and this happens along with increase of consumption by only 3.5% annually, and hence there is a significant increase in export.

Table 7.9 Forecasted power balance (MW)

| YEAR | SUMMER MAXIMUM | | | |
|------|----------------|------|--------|--------|
| | GENERATION | LOAD | EXPORT | IMPORT |
| 2016 | 1985 | 1612 | 448 | 53 |
| 2017 | 2270 | 1727 | 700 | 200 |
| 2018 | 2415 | 1822 | 700 | 150 |
| 2019 | 2726 | 1919 | 1300 | 550 |
| 2020 | 3194 | 2016 | 1394 | 300 |
| 2021 | 3398 | 2113 | 2085 | 900 |
| 2022 | 3788 | 2212 | 2085 | 600 |
| 2023 | 3887 | 2311 | 2085 | 600 |
| 2024 | 4905 | 2411 | 2685 | 300 |
| 2025 | 5535 | 2512 | 2885 | 0 |
| 2026 | 5643 | 2614 | 2885 | 0 |
| 2027 | 5647 | 2717 | 2785 | 0 |




Fig 7.8 Summer maximum

Summer Minimum Summer Minimum corresponds to high water flood period. Total consumption of Georgian electrical system is 900 MW. Because main HPPs are located in Enguri basin and Gardabani TPP is switched off, power flow from west to east is increased. During 2017-2017, power flow balance change is derived from the same factor as in summer maximum regimes.

Table 7.10 Forecasted power balance (MW)

| YEAR | SUMMER MINIMUM | | | |
|------|----------------|------|--------|--------|
| | GENERATION | LOAD | EXPORT | IMPORT |
| 2016 | 1075 | 908 | 189 | 22 |
| 2017 | 1470 | 928 | 804 | 300 |
| 2018 | 1584 | 986 | 804 | 250 |
| 2019 | 2157 | 1014 | 1300 | 200 |
| 2020 | 2202 | 1060 | 1300 | 200 |
| 2021 | 2399 | 1098 | 2085 | 850 |
| 2022 | 2901 | 1142 | 2485 | 800 |
| 2023 | 3047 | 1188 | 2485 | 700 |
| 2024 | 3444 | 1232 | 2685 | 550 |
| 2025 | 3791 | 1275 | 2685 | 250 |
| 2026 | 3835 | 1318 | 2685 | 250 |
| 2027 | 3880 | 1362 | 2685 | 250 |




Fig 7.9 Summer minimum

7.5 Generation Adequacy

According of of Network Code (point 3 of Article 30) “... criteria ..used in this Code for assessing reliability of the transmission network:

a) *Adequacy – ability of the electricity system to uninterruptedly satisfy the consumers’ requirements on electricity, taking into account the both scheduled and unscheduled outages of system elements”.*

Adequacy of power generation is determined by 2 methds:

1. Deterministic – minimizes time required for calculations, but is based on just a few scenarios. This requires deep knowledge of the system and may not cover all accidents;
2. Probabilistic – requires software with strong mathematical equipment, requires more time for calculations (a second, or tenths of seconds), although reflects the influence of reliability of each element of the system on the adequacy of power generation.

Hence the adequacy may be expressed as the ability of Power System’s generation to satisfy 100% of peak load with 95% probability. If less than 100% of peak load is satisfied, than the system treated as inadequate and installation of new generation sources and reinforcement of cross border transmission is required.

Thereto, by adding generation, 10% of total NTCs of cross border lines can be used as well.

The assessment of Generation adequacy conducted with simplified approach for estimated peak loads of Winter and Summer (Table 7.9, 7.11) by taking in account of following assumptions:

It was established that

1. Operation of HPP with reservoir
 - a) At summer peak, without one unit (reserved unit) with installed capacity will occur with high probability

$$P_{HPP} = P_i \cdot (k - 1)$$

$$A_{HPP} = 1.0$$

- b) At winter peak, without one unit (reserved unit) with 80% of installed capacity, occurs with the same probability as in summer peak

$$P_{HPP} = 0.8 P_i \cdot (k - 1)$$

$$A_{HPP} = 1.0$$

- c) In addition, this probability for Enguri HPP and Vardnili HPP will be limited till 2022 (until additional 500 kV OHL is constructed to the east of Enguri basin) with the reliability of 500 kV OHL “Imereti” (Table 3.2) $1 - 0.002 = 0.998$ and result in:
- Reliability of combined power plants (Gardabani 2, Gardabani 3), air turbines and new thermal station included at 0.995; №4 unit reliability at 0.995; №3 and №9 unit reliability at 0.98.
 - Small HPP generation with probability equal to 1.0 is 50% of the plants install capacity in summer mode, and 30% of installed capacity during winter peak.

LSI (Load Supply Index) shows the ratio between generation capacity (with respective availability) and peak load of country.

If $LSI > 1.0$ then the generation and interconnection capacity of power system is treated as adequate otherwise system is inadequate and new generation sources and the reinforcement of transmission capacity is required.

For Georgian power system the analysis was conducted for 95% of generation availability (standard for central European countries) for Summer and Winter peak loads and for scenarios made by combination of generation and consumption growth (see the table 6.1). Generation and NTC information are given in table 7.16, Peak loads are given in table 7.17 where L1 corresponds to 1%, L2 – 3.5% and L3 – 5.0% annual load growth. LSI results are presented in table 7.18.

Table 7.16
With 95% of probability generation readiness, according to regimes and scenarios.

| G SCEN | REGIME | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 |
|--------|--------|------|------|------|------|------|------|------|------|------|------|------|
| G1 | SUMMAX | 2764 | 2766 | 2771 | 2814 | 2961 | 2966 | 2981 | 2999 | 3090 | 3162 | 3215 |
| | WINMAX | 2258 | 2260 | 2263 | 2393 | 2444 | 2459 | 2455 | 2473 | 2492 | 2585 | 2585 |
| G2 | SUMMAX | 2764 | 2767 | 2777 | 2864 | 3157 | 3167 | 3198 | 3235 | 3415 | 3560 | 3665 |
| | WINMAX | 2258 | 2263 | 2268 | 2527 | 2631 | 2661 | 2653 | 2687 | 2727 | 2913 | 2913 |
| G3 | SUMMAX | 2764 | 2771 | 2791 | 2965 | 3550 | 3570 | 3632 | 3705 | 4067 | 4356 | 4567 |
| | WINMAX | 2258 | 2268 | 2278 | 2797 | 3004 | 3064 | 3048 | 3117 | 3196 | 3568 | 3568 |

Table 7.17
Peak load, according to regimes and scenarios

| L SCEN | REGIME | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 |
|--------|----------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| L1 | SUMMAX | 1633 | 1655 | 1676 | 1698 | 1721 | 1743 | 1766 | 1790 | 1813 | 1837 | 1861 |
| | WINMAX | 1897 | 1904 | 1911 | 1919 | 1926 | 1933 | 1940 | 1948 | 1955 | 1962 | 1970 |
| | (WINMAX) | (2115) | (2130) | (2146) | (2161) | (2177) | (2192) | (2208) | (2224) | (2240) | (2256) | (2272) |
| L2 | SUMMAX | 1731 | 1815 | 1904 | 1997 | 2095 | 2197 | 2304 | 2417 | 2535 | 2659 | 2789 |
| | WINMAX | 1915 | 1940 | 1966 | 1992 | 2018 | 2045 | 2072 | 2100 | 2128 | 2156 | 2184 |

| | (WINMAX) | (2153) | (2207) | (2263) | (2320) | (2378) | (2438) | (2500) | (2563) | (2627) | (2693) | (2761) |
|----|----------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| L3 | SUMMAX | 1718 | 1831 | 1951 | 2079 | 2216 | 2362 | 2517 | 2682 | 2859 | 3046 | 3247 |
| | WINMAX | 1926 | 1962 | 1999 | 2037 | 2075 | 2114 | 2154 | 2195 | 2236 | 2278 | 2321 |
| | (WINMAX) | (2175) | (2253) | (2334) | (2418) | (2505) | (2595) | (2688) | (2785) | (2885) | (2988) | (3095) |

Table 7.18
LSI (Load Supply Index) according to regimes and scenarios

| SYS SCEN | REGIME | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 |
|----------|----------|------|------|------|------|------|------|------|------|------|------|------|
| G1L1 | SUMMAX | 1.69 | 1.67 | 1.65 | 1.66 | 1.72 | 1.7 | 1.69 | 1.68 | 1.7 | 1.72 | 1.73 |
| | WINMAX | 1.19 | 1.19 | 1.18 | 1.25 | 1.27 | 1.27 | 1.27 | 1.27 | 1.27 | 1.32 | 1.31 |
| | (WINMAX) | 1.07 | 1.06 | 1.05 | 1.11 | 1.12 | 1.12 | 1.11 | 1.11 | 1.11 | 1.15 | 1.14 |
| G1L2 | SUMMAX | 1.6 | 1.52 | 1.46 | 1.41 | 1.41 | 1.35 | 1.29 | 1.24 | 1.22 | 1.19 | 1.15 |
| | WINMAX | 1.18 | 1.17 | 1.15 | 1.2 | 1.21 | 1.2 | 1.19 | 1.18 | 1.17 | 1.2 | 1.18 |
| | (WINMAX) | 1.05 | 1.02 | 1.00 | 1.03 | 1.03 | 1.01 | 0.98 | 0.97 | 0.95 | 0.96 | 0.94 |
| G1L3 | SUMMAX | 1.61 | 1.51 | 1.42 | 1.35 | 1.34 | 1.26 | 1.18 | 1.12 | 1.08 | 1.04 | 1 |
| | WINMAX | 1.17 | 1.15 | 1.13 | 1.17 | 1.18 | 1.16 | 1.14 | 1.13 | 1.11 | 1.13 | 1.11 |
| | (WINMAX) | 1.04 | 1.00 | 0.97 | 0.99 | 0.98 | 0.95 | 0.91 | 0.89 | 0.86 | 0.87 | 0.84 |
| G2L1 | SUMMAX | 1.69 | 1.67 | 1.66 | 1.69 | 1.83 | 1.82 | 1.81 | 1.81 | 1.88 | 1.94 | 1.97 |
| | WINMAX | 1.19 | 1.19 | 1.19 | 1.32 | 1.37 | 1.38 | 1.37 | 1.38 | 1.39 | 1.48 | 1.48 |
| | (WINMAX) | 1.07 | 1.06 | 1.06 | 1.17 | 1.21 | 1.21 | 1.20 | 1.21 | 1.22 | 1.29 | 1.28 |
| G2L2 | SUMMAX | 1.6 | 1.52 | 1.46 | 1.43 | 1.51 | 1.44 | 1.39 | 1.34 | 1.35 | 1.34 | 1.31 |
| | WINMAX | 1.18 | 1.17 | 1.15 | 1.27 | 1.3 | 1.3 | 1.28 | 1.28 | 1.28 | 1.35 | 1.33 |
| | (WINMAX) | 1.05 | 1.03 | 1.00 | 1.09 | 1.11 | 1.09 | 1.06 | 1.05 | 1.04 | 1.08 | 1.06 |
| G2L3 | SUMMAX | 1.61 | 1.51 | 1.42 | 1.38 | 1.42 | 1.34 | 1.27 | 1.21 | 1.19 | 1.17 | 1.13 |
| | WINMAX | 1.17 | 1.15 | 1.13 | 1.24 | 1.27 | 1.26 | 1.23 | 1.22 | 1.22 | 1.28 | 1.26 |
| | (WINMAX) | 1.04 | 1.00 | 0.97 | 1.05 | 1.05 | 1.03 | 0.99 | 0.97 | 0.95 | 0.98 | 0.94 |
| G3L1 | SUMMAX | 1.69 | 1.67 | 1.67 | 1.75 | 2.06 | 2.05 | 2.06 | 2.07 | 2.24 | 2.37 | 2.45 |
| | WINMAX | 1.19 | 1.19 | 1.19 | 1.46 | 1.56 | 1.59 | 1.57 | 1.6 | 1.63 | 1.82 | 1.81 |
| | (WINMAX) | 1.07 | 1.06 | 1.06 | 1.29 | 1.38 | 1.40 | 1.38 | 1.40 | 1.43 | 1.58 | 1.57 |
| G3L2 | SUMMAX | 1.6 | 1.53 | 1.47 | 1.48 | 1.69 | 1.63 | 1.58 | 1.53 | 1.6 | 1.64 | 1.64 |
| | WINMAX | 1.18 | 1.17 | 1.16 | 1.4 | 1.49 | 1.5 | 1.47 | 1.48 | 1.5 | 1.66 | 1.63 |
| | (WINMAX) | 1.05 | 1.03 | 1.01 | 1.21 | 1.26 | 1.26 | 1.22 | 1.22 | 1.22 | 1.33 | 1.29 |
| G3L3 | SUMMAX | 1.61 | 1.51 | 1.43 | 1.43 | 1.6 | 1.51 | 1.44 | 1.38 | 1.42 | 1.43 | 1.41 |
| | WINMAX | 1.17 | 1.16 | 1.14 | 1.37 | 1.45 | 1.45 | 1.42 | 1.42 | 1.43 | 1.57 | 1.54 |
| | (WINMAX) | 1.04 | 1.01 | 0.98 | 1.16 | 1.20 | 1.18 | 1.13 | 1.12 | 1.11 | 1.19 | 1.15 |

Based on tab 7.18, LSI diagrams have been plotted for Winter and Summer periods, for all scenarios of system development (fig 7.11, 7.12-a, 7.12-b). It seems that in summer the system is adequate for 95% availability of generation. As for winter period, in case of pesimistic scenario of generation and optimistic and moderate scenarios of consumption growth (G2L3, G1L3), it is anticipated that LSI will be reduced below 1.0. If generation objects are connected to the network by more pessimistic scenarios than G1, LSI may drop below 1.0 not only in winter, but in summer as well. Thus, in case of pessimistic generation scenarios, generation adequacy risk will be created. that in order to avoid reduction of SoS (security of supply), timely implementation of projects of generation and transmission infrastructure are necessary.




Fig. 7.11 LSI during summer




Fig. 7.12-a LSI during winter




Fig. 7.12-b LSI during winter (corrected)

() - Corrected data based on information obtained in January 2017

According on above mentioned, in order to avoid the reduction of security of supply and the adequacy of power system, following recommendations have to be take in account:

1. Construction of 500 kV parallel line of 500 kV OHL "Imereti" in order to increase reliability of power evacuation from Enguri node;
2. Timely construction of cross border transmission infrastructure;
3. Future Generation objects have to be in operation at least according the schedule;
4. Existing generation objects must (!) improve their technical situation, according the "Grid Code" and "Technical Operation Rules";
5. HPPs with Reservoirs (Khudoni and Nenskra HPPs, Tskhenistskali, Mtkvari and Namakhvani cascades) have to be commissioned on time in order to "save energy" for winder period;
6. It is recommended to construct pypmed-storage HPPs which will lead to improve generation adequacy, power system stability and flexibility and to make opportunity to integrate additional capacities coming from sources of variable generation (solar and wind) to the network.
7. Conduct measures to ensure increased power efficiency and mitigation of consumption growth.

8 Identified Projects and Investment Needs for Infrastructure strengthening

According to Georgian law on “electricity and natural gas” Article 3² (Network Development Plan of Georgia) paragraph 2: *Georgian Ten Year Network Development Plan should contain:*

...

C) Information about transmission system infrastructure that should be built or strengthen during the next 10 years according to investment dates.

According to grid code Article 39, paragraph 3: *In network development plan... Should be indicated locations where new electrical installations or rehabilitation of old ones are needed.*

8.1 Identified Projects

As noted above (ref. to Sections 2 and 6), the projects to be implemented in the transmission network has been divided into the following three groups:

1. **Internal Projects**, including the projects affecting power transit and reliability;
2. **Cross-Border Projects**, i.e. the projects affecting capacity and reliability of the transit flows among the power systems of Georgia and its neighbouring states;
3. **Local Projects**, comprising 220 kV and 110 kV dead-end feeder lines.

The direct affect on development of the transmission network is provided only by Cross-Border and Internal Projects.

The estimated costs, as well as lengths and commissioning dates of these projects are of a forecasted nature, and GSE shall in no event be liable for their inaccuracy. These data shall be subject of review and specification during implementation of the projects by consultants and/or project developers.

Fifteen projects described below are of the system wide importance, and when implemented, will address current and future challenges. Each of these projects will provide individual infrastructural elements of the transmission network, although consisting of several sub-projects and/or power lines and substations operated at one or several rated voltages.

Thirteen from described projects assume construction of overhead line or substation, and the remaining two – construction of HVDC link along with AC transmission line.